

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard
Vice President Plant Operations

July 15, 1994

WO 94-0092


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: June, 1994, Monthly
Operating Report

Gentlemen:

Attached is the June, 1994, Monthly Operating Report for Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Technical Specification 6.9.1.8.

Very truly yours,



Otto L. Maynard

OLM/jad

Attachment

cc: L. J. Callan (NRC), w/a
D. Graves (NRC), w/a
G. A. Pick (NRC), w/a
M. A. Miller (NRC), w/a
W. D. Reckley (NRC), w/a

JE24, 11

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: JUNE YEAR: 1994

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 112

SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of June, 1994. This report is being provided pursuant to Technical Specification 6.9.1.8.

I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100% power the entire month of June.

II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

No major safety related maintenance was performed during the month of June.

OPERATING DATA REPORT
DOCKET NO. 50-482
WOLF CREEK GENERATING STATION
WOLF CREEK NUCLEAR OPERATING CORPORATION
DATE 07-01-94
TELEPHONE 316-364-8831

OPERATING STATUS

1. Reporting Period: June, 1994 Gross Hours in Reporting Period: 720
 2. Currently Authorized Power Level (MWt): 3565 Max. Depend. Capacity (MWe-Net): 1160
Design Electrical Rating (MWe-Net): 1170
 3. Power Level to Which Restricted (If Any) (MWe-Net): N/A
 4. Reasons for Restriction (If Any): N/A
- | | This Month | Yr. to Date | Cumulative |
|---|------------------|-------------------|--------------------|
| 5. Number of Hours Reactor was Critical | <u>720.0</u> | <u>4,262.2</u> | <u>62,624.6</u> |
| 6. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>339.8</u> |
| 7. Hours Generator on Line | <u>720.0</u> | <u>4,225.7</u> | <u>61,879.1</u> |
| 8. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 9. Gross Thermal Energy Generated (MWH) | <u>2,520,895</u> | <u>14,574,319</u> | <u>203,838,730</u> |
| 10. Gross Electrical Energy Generated (MWH) | <u>866,884</u> | <u>5,063,090</u> | <u>70,916,639</u> |
| 11. Net Electrical Energy Generated (MWH) | <u>833,053</u> | <u>4,862,414</u> | <u>67,708,086</u> |
| 12. Reactor Service Factor | <u>100.0</u> | <u>98.1</u> | <u>81.0</u> |
| 13. Reactor Availability Factor | <u>100.0</u> | <u>98.1</u> | <u>81.4</u> |
| 14. Unit Service Factor | <u>100.0</u> | <u>97.3</u> | <u>80.0</u> |
| 15. Unit Availability Factor | <u>100.0</u> | <u>97.3</u> | <u>80.0</u> |
| 16. Unit Capacity Factor (Using MDC) | <u>99.7</u> | <u>98.4</u> | <u>77.3</u> |
| 17. Unit Capacity Factor (Using Design MWe) | <u>98.9</u> | <u>95.7</u> | <u>74.8</u> |
| 18. Unit Forced Outage Rate | <u>0.0</u> | <u>1.4</u> | <u>5.4</u> |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each):
Refueling outage scheduled to begin September 15, 1994, lasting 58 days
 20. If Shut Down at End of Report Period, Estimate Date of Startup: N/A

AVERAGE DAILY UNIT POWER LEVEL
DOCKET NO. 50-482
WOLF CREEK GENERATING STATION
WOLF CREEK NUCLEAR OPERATING CORPORATION
DATE 07-01-94
TELEPHONE 316-364-8831

MONTH June, 1994DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	1163
2	1161
3	1157
4	1167
5	1164
6	1164
7	1163
8	1165
9	1168
10	1156
11	1167
12	1165
13	1164
14	1164
15	1165
16	1166

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	1165
18	1103
19	1118
20	1154
21	1152
22	1151
23	1156
24	1153
25	1158
26	1159
27	1158
28	1156
29	1154
30	1152

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-482

WOLF CREEK GENERATING STATION

WOLF CREEK NUCLEAR OPERATING CORPORATION

DATE 07-01-94

TELEPHONE 316-364-8831

No	Date	Type F: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS

SUMMARY: The unit operated at or near 100% power the entire month of June.

- 1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUED
 5. REDUCED LOAD
 9. OTHER

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH June, 1994

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

DATE	TIME	EVENT
June 1, 1994	0000 hours	Unit at 100% power.
June 30, 1994	2400 hours	Unit at 100% power.