NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NCBEP2 (2) | 00-000-00 (3) | 4111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 05 0-032 4 (7) | 011882 (8) | 012828 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During routine surveillance, it was discovered that suppression chamber water tempera-
03 ture recorder, 2-CAC-TR-778, located on the remote shutdown panel, was showing normal
04 expected indications of temperatures, but was not recording them on the chart recorder.
05 A similar event involving this recorder occurred on 12-7-81 and was reported in LER
06 2-81-134. This event did not affect the health and safety of the public.
07 Technical Specifications 3.3.5.2, 6.9.1.9b
08

09 SYSTEM CODE IC (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE R (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 — SEQUENTIAL REPORT NO. 017 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN B (18) | FUTURE ACTION G (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER B415 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The recorder print head actuation linkage had separated from the print actuation
11 solenoid due to an apparent lack of proper linkage retaining spring tension. The
12 linkage was reattached to the actuation solenoid, retaining spring tension was
13 properly adjusted, and the recorder, Model No. 551, returned to service. Applicable
14 maintenance procedures will be revised to check the recorder linkage adjustment.

15 FACILITY STATUS E (28) | % POWER 066 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Surveillance

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY: TYPE Z (42) | DESCRIPTION (43) NA

PUBLICITY (44) NA

NRC USE ONLY

8203080567 820212
PDR ADOCK 05000324
S PDR

NAME OF PREPARER M. J. Pastva, Jr. PHONE: (919) 457-9521

GPO 917-924