

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 | 51 | 52 | 53 | 54 | 55 | 56 | 57 | 58 | 59 | 60 | 61 | 62 | 63 | 64 | 65 | 66 | 67 | 68 | 69 | 70 | 71 | 72 | 73 | 74 | 75 | 76 | 77 | 78 | 79 | 80 | 81 | 82 | 83 | 84 | 85 | 86 | 87 | 88 | 89 | 90 | 91 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 | 100

REPORT SOURCE: L | 0 | 5 | 1 | 0 | 0 | 0 | 3 | 4 | 1 | 8 | 0 | 6 | 2 | 6 | 8 | 2 | 0 | 7 | 2 | 2 | 8 | 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

At 1410 on 6/26/82 during the performance of FNP-1-STP-20.0 (Penetration Room Filtration System Train A Operability and Valve Inservice Test), the "A" Train Penetration Room Filtration System was declared inoperable when the main control board handswitch for the recirculation fan suction damper (3362A) fractured. Tech. Spec. 3.7.8, in part, requires this penetration room filtration system to be operable. Tech. Spec. 3.7.8 action statement requirements were met. Health/Safety of the public was not affected.

CAUSE CODE: A | A | E | C | CK | TB | R | K | E | Z

LER/RO REPORT NUMBER: 8 | 2 | SEQUENTIAL REPORT NO.: 0 | 3 | 4 | OCCURRENCE CODE: 0 | 3 | REPORT TYPE: L | REVISION NO.: 0 | COMPONENT MANUFACTURER: X | 9 | 9 | 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

This event was due to a broken shaft in the main control board handswitch. Following the replacement of the handswitch, "A" train penetration room filtration system was declared operable at 1830 on 6/26/82.

FACILITY STATUS: E | % POWER: 1 | 0 | 0 | OTHER STATUS: NA | METHOD OF DISCOVERY: A | DISCOVERY DESCRIPTION: Operational Event

ACTIVITY CONTENT: Z | AMOUNT OF ACTIVITY: NA | LOCATION OF RELEASE: NA

PERSONNEL EXPOSURES: 0 | 0 | 0 | TYPE: Z | DESCRIPTION: NA

PERSONNEL INJURIES: 0 | 0 | 0 | DESCRIPTION: NA

LOSS OF OR DAMAGE TO FACILITY: Z | DESCRIPTION: NA

PUBLICITY: N | ISSUED DESCRIPTION: 8208020122 B20722 PDR ADOCK 05000348 S PDR

NAME OF PREPARER: W. G. Hairston, III

PHONE: (205) 899-5156