

CONTROL BLOCK: [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | S | C | N | E | E | 1 | 2 | 0 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CONT

0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 6 | 9 | 7 | 0 | 6 | 2 | 3 | 8 | 2 | 8 | 0 | 7 | 2 | 1 | 8 | 2 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On June 23, 1982 both trains of Reactor Building Spray (RBS) were inoperable due to the B train RBS pump being out of service while the A train RBS pump suction valve was shut. The Reactor Building Cooling System was operable, and capable of limiting containment pressure below design pressure during a LOCA; thus, the health and safety of the public were not affected by this incident.

0 9 | SYSTEM CODE | S | B | 11 | CAUSE CODE | A | 12 | CAUSE SUBCODE | A | 13 | COMPONENT CODE | P | U | M | P | X | X | 14 | COMP. SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16

17 | LER/RO REPORT NUMBER | 8 | 2 | 21 | 22 | SEQUENTIAL REPORT NO. | 0 | 1 | 2 | 24 | 26 | OCCURRENCE CODE | 1 | 0 | 1 | 27 | 29 | REPORT TYPE | T | 30 | 31 | REVISION NO. | 0 | 32 | ACTION TAKEN | X | 18 | 33 | FUTURE ACTION | H | 19 | 34 | EFFECT ON PLANT | Z | 20 | 35 | SHUTDOWN METHOD | Z | 21 | 36 | HOURS | 0 | 0 | 0 | 0 | 22 | 37 | 40 | ENT'D FORM SUB. | N | 24 | 42 | PRIME COMP. SUPPLIER | L | 25 | 43 | COMPONENT MANUFACTURER | I | 0 | 7 | 5 | 26 | 44 | 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of this incident was personnel error. The B train was made operable by racking in the RBS pump breaker. The Assistant Shift Supervisor was counseled regarding his error, and all operators will review this incident.

1 5 | FACILITY STATUS | E | 28 | 9 | 5 | % POWER | 1 | 0 | 0 | 29 | 10 | 13 | OTHER STATUS | NA | 30 | 44 | METHOD OF DISCOVERY | A | 31 | 45 | DISCOVERY DESCRIPTION | Operator Observation | 32 | 46

1 6 | ACTIVITY RELEASED OF RELEASE | Z | 33 | 7 | 9 | 10 | 11 | CONTENT | Z | 34 | 12 | 13 | AMOUNT OF ACTIVITY | NA | 35 | 44 | 45 | LOCATION OF RELEASE | NA | 36 | 46

1 7 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | 7 | 9 | 11 | TYPE | Z | 38 | 12 | 13 | DESCRIPTION | NA | 39 | 44

1 8 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | 7 | 9 | 11 | 12 | DESCRIPTION | NA | 41 | 44

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | 7 | 9 | 10 | 11 | DESCRIPTION | NA | 43 | 44

2 0 | FACILITY ISSUED | N | 44 | 7 | 9 | 10 | 11 | DESCRIPTION | 8208020164 820721 PDR ADOCK 05000269 PDR | 45

NAME OF PREPARER J. F. Kutzer PHONE (704) 373-7139

NRC USE ONLY