p.m.

	CONTROL BLOCK:
0 1	T N S N P 2 () 0 0 - 0 0 0 0 - 0 0 0 4 1 1 1 1 1 0 0 0 0 0 0 0 0 0 0 0
CON'T	REPORT L 6 0 5 10 10 0 3 2 8 7 0 6 2 5 8 2 8 0 7 2 3 8 2 9
0 2	With unit 2 in mode 3 (0% power) at 0004 CST on 06/25/82, automatic control valve
0 3	1-PCV-3-122 of the auxiliary feedwater system was declared inoperable due to failure
0 4	to open on demand. A similar event occurred at 0750 CST on 06/25/82. In both
0 5	events, the unit entered action statement "a" of LCO 3.7.1.2. There was no effect
06	upon public health and safety. Previous occurrences - five (SQRO-50-327/81142,
0 7	81159, 82048, 82074, and 50-328/81141).
0 8	<u></u>
0 9 8	SVSTEM CAUSE CAUSE SUBCODE COMPONENT CODE SUBCODE SUBC
	LER/RO EVENT YEAR SEQUENTIAL REPORT NO. 17 REPORT NUMBER 2 0 8 1 0 3 L 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
10	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) L In the first event, it was found that the oil was low in the hydraulic reservoir
11	due to a leaking fitting. The leak was repaired and oil added. The valve was
1 2	returned to service at 0245 CST on 6/24/82. In the second event, the Moog, Inc.,
1 3	servo valve failed due to foreign material in oil. The servo valve was replaced
	and oil filters changed and the valve returned to service at 1400 CST on 06/25/82.
1 5	ATTION TO POWER OTHER STATUS (30) NA DISCOVERY DESCRIPTION (32) NA POWER DISCOVERY DESCRIPTION (32) B (31) Operator observation
A	LEASED OF RELEASE AMOUNT OF ACTIVITY 35 NA LOCATION OF RELEASE 36
1 7	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (3) NA NA
18	NUMBER DESCRIPTION 41 NA
119	COSS OF OR DAMAGE TO FACILITY 43 Z 42 NA
20	PURLICITY SSUED DESCRIPTION 45 PDR ADOCK 05000328 N 44 NA S PDR NAC USE ONLY
	Name of Preparer: H. R. Rogers /M. R. Harding Phone: (615) 751-0349