

Ye/How

MAY 11 1983

Duke Power Company
ATTN: Mr. H. B. Tucker, Vice President
Nuclear Production Department
422 South Church Street
Charlotte, NC 28242

Gentlemen:

SUBJECT: MEETING SUMMARIES - DOCKET NOS. 50-269/83-12, 50-270/83-12 AND
50-287/83-12

This refers to the enforcement meeting and a followup management meeting held between you and others of your staff, with myself, and others of my staff. The meetings were arranged at our request and your request in the Region II office on March 23, 1983 and April 19, 1983, respectively. These meetings related to activities authorized by NRC License Nos. DPR-38, DPR-49 and DPR-55 for Oconee Units 1, 2 and 3. The subjects discussed are detailed in the enclosed inspection report.

Our concerns regarding the identification of an open pressurization line test valve on Unit 3 emergency hatch, a partially open inner emergency hatch on Unit 1, and the need for independent verification were expressed to you during the first meeting. Your positive response to our concerns as noted in the second meeting is appreciated.

It is our opinion that both meetings were beneficial and have provided for a better understanding of inspection and enforcement issues. In accordance with Section 2.790 of NRC's "Rules of Practice", Part 2, Title 10, Code of Federal Regulations, a copy of this letter and enclosure will be placed in the NRC's Public Document Room.

Should you have any questions regarding this matter, we will be pleased to discuss them.

James P. O'Reilly
Regional Administrator

Enclosure:
Inspection Report Nos. 50-269/83-12,
50-270/83-12 and 50-287/83-12

cc w/encl:
J. Ed Smith, Station Manager

8305270425 830511
PDR ADOCK 05000269
PDR
G

IE01

MAY 11 1983

Duke Power Company

2

bcc w/encl:
NRC Resident Inspector
Document Management Branch
State of South Carolina

RII

Algnatonis:blh

4/1/83

5/10

RII

HCD

HCDance

4/1/83

5/10

RII

BUCKETT

LEAlderson

4/1/83

5