	CAP 1202
	CAR 1393  CONTROL BLOCK: (PLEASE PHINT OR TYPE ALL REQUIRED INFORMATION)
0 1	N Y R E G 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5  9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
O 1 8	REPORT L 6 0 5 0 - 2 4 4 4 7 0 6 2 2 8 2 8 0 7 2 4 8 2 9  SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80
0 2	While at steady state 100% operation, a periodic test identified the containment
0 3	gas radiation monitor reutrn line check valve was not sealing tight. This is
0 4	reportable under Tech Spec 6.9.2.b.2. This is the same valve that failed on LER
0 5	81-021 and LER 82-011.
06	
0 7	
08	9 80
0 9	SYSTEM CAUSE CODE SUBCODE SUBC
	LER RO REPORT NO.  LER RO REPORT NO.  SEQUENTIAL REPORT NO.  OCCURRENCE CODE TYPE  NO.  NO.  17 NUMBER 21 22 23 24 26 27 28 29 30 31 32
	ACTION FUTURE TAKEN ACTION ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED FORM SUB. PRIME GOMP. SUPPLIER MANUFACTURER R 3 4 0 26
	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)    Dirt possibly from the veins of the monitor pump deposited on the seat of the carbon
1 0	steel Rockwell 2" 600 psi. Air was blown through the valve to clear it out. After
	the last failure, the valve was replaced with this bolted bonnet check valve.
1 2	Modifications are being expedited to install a filter in this line.
1 3	Productions are being disposition to an arrangement of the second of the
	FACILITY (30) METHOD OF DISCOVERY DESCRIPTION (32)
1 5	E 28 1 0 0 29 NA B 30 Periodic Testing of Check Valve
	ACTIVITY CONTENT  RELEASED OF RELEASE AMOUNT OF ACTIVITY 35  NA LOCATION OF RELEASE 36  NA 80
1 7	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39  0 0 0 37 Z 38 NA
7 8	9 11 12 13 PERSONNEL INJURIES NUMBER DESCRIPTION 41
7 8	0 0 0 40 NA 80
1 9	LOSS OF OR DAMAGE TO FACILITY 43  TYPE DESCRIPTION 43  Z 42 NA
7 8	PUBLICITY   8208020321 820724   NRC USE ONLY   ISSUED   DESCRIPTION (45)   PDR   ADDCK 05000244   PDR   PDR
7 8	9 10 80.3 NAME OF PREPARER S. M. Spector PHONE 315-524-4446 Ext. 214 8