

PLANT SYSTEMS

SURVEILLANCE REQUIREMENT (Continued)

that may be generically susceptible; and (2) the affected snubber is functionally tested in the as-found condition and determined OPERABLE per Specification 4.7.8.e or 4.7.8.f, as applicable. All snubbers found connected to an inoperable common hydraulic fluid reservoir shall be counted as unacceptable for determining the next inspection interval. A review and evaluation shall be performed and documented to justify continued operation with an unacceptable snubber. If continued operation cannot be justified, the snubber shall be declared inoperable and the ACTION requirements shall be met.

d. Snubber Tests

\*\*

At least once per eighteen (18) months during shutdown, a representative sample (10% of the total of each type of snubber, mechanical and hydraulic, except steam generator hydraulic snubbers in use in the plant) shall be tested either in place or in a bench test. For each snubber that does not meet the test acceptance criteria of Specification 4.7.8.e or 4.7.8.f, as applicable, an additional 5% of that type of snubber shall be tested.

Testing shall continue until no additional inoperable snubbers are found within a sample or until all snubbers have been tested. The representative sample selected for testing shall include the various configurations, and the range of size and capacity of snubbers.

Snubbers identified as "Especially Difficult to Remove" or in "High Radiation Zones During Shutdown" shall also be included in the representative sample.\*

In addition to the regular sample, in locations where snubbers had failed the previous test due to operational or environmental conditions (excessive vibration, water hammer, high radiation, extreme heat or humidity, etc.), the snubbers currently installed in these locations shall be tested during the next test period. Test results of these snubbers may not be included for the resampling. All replacement snubbers shall have been tested prior to installation.

All steam generator hydraulic snubbers shall be tested and refurbished every seven years or less in accordance with the preventative maintenance program, in lieu of the functional test requirements of this specification.

\*Permanent or other exemptions from functional testing for individual snubbers in these categories may be granted by the Commission only if a justifiable basis for exemption is presented.

ADD \*\* Except that the surveillance requirement due no later than August 21, 1994, may be deferred until the next refueling outage, but no later than October 31, 1994, whichever is earlier.

Docket No. 50-336  
B14909

Attachment 3

Millstone Nuclear Power Station, Unit No. 2

Proposed Revision to Technical Specifications  
One-Time Extension to 18 Month Snubber Surveillance  
Retyped Pages

July 1994

## PLANT SYSTEMS

### SURVEILLANCE REQUIREMENT (Continued)

---

that may be generically susceptible; and (2) the affected snubber is functionally tested in the as-found condition and determined OPERABLE per Specification 4.7.8.e or 4.7.8.f, as applicable. All snubbers found connected to an inoperable common hydraulic fluid reservoir shall be counted as unacceptable for determining the next inspection interval. A review and evaluation shall be performed and documented to justify continued operation with an unacceptable snubber. If continued operation cannot be justified, the snubber shall be declared inoperable and the ACTION requirements shall be met.

#### d. Snubber Tests

At least once per eighteen (18) months\*\* during shutdown, a representative sample (10% of the total of each type of snubber, mechanical and hydraulic, except steam generator hydraulic snubbers in use in the plant) shall be tested either in place or in a bench test. For each snubber that does not meet the test acceptance criteria of Specification 4.7.8.e or 4.7.8.f, as applicable, an additional 5% of that type of snubber shall be tested.

Testing shall continue until no additional inoperable snubbers are found within a sample or until all snubbers have been tested. The representative sample selected for testing shall include the various configurations, and the range of size and capacity of snubbers.

Snubbers identified as "Especially Difficult to Remove" or in "High Radiation Zones During Shutdown" shall also be included in the representative sample.\*

In addition to the regular sample, in locations where snubbers had failed the previous test due to operational or environmental conditions (excessive vibration, water hammer, high radiation, extreme heat or humidity, etc.), the snubbers currently installed in these locations shall be tested during the next test period. Test results of these snubbers may not be included for the resampling. All replacement snubbers shall have been tested prior to installation.

All steam generator hydraulic snubbers shall be tested and refurbished every seven years or less in accordance with the preventative maintenance program, in lieu of the functional test requirements of this specification.

---

\*Permanent or other exemptions from functional testing for individual snubbers in these categories may be granted by the Commission only if a justifiable basis for exemption is presented.

\*\*Except that the surveillance requirement due no later than August 21, 1994, may be deferred until the next refueling outage, but no later than October 31, 1994, whichever is earlier.