



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 17, 1983

JAMES P. McGAUGHY, JR.  
VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Special Report 83-001/1 -  
Update Report - Smoke  
Detectors in the LPCS Pump  
Room Covered to Perform  
Planned Maintenance  
AECM-83/0279

83 MAY 31 11:23  
USNRC REGION II  
ATLANTA, GEORGIA

This is an update to a previous report submitted on March 16, 1983. The event for which the report was submitted occurred on February 2, 1983, when smoke detectors in the LPCS pump room were covered in order to perform a planned activity. An hourly fire watch was established in accordance with Technical Specification 3.3.7.9. The event was reported pursuant to Technical Specification 6.9.2.

The work is still in progress. This condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The purpose of this report is to provide an estimated restoration date of June 15, 1983, for the smoke detectors.

Yours truly,

*J.P. McGaughy*  
for J.P. McGaughy

JPM:sap

cc: (See Next Page)

8306070089 830517  
PDR ADOCK 05000416  
S PDR

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0279

Page 2

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555