

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the staff on this date.

Facility: Indiana & Michigan Elec.
D.C. Cook Nuclear Power Plant
Unit 2 - Docket No. 50-316
Stevensville, MI 49127

Licensee Emergency Classification:
____ Notification of Unusual Event
____ Alert
____ Site Area Emergency
____ General Emergency
____ xx Not Applicable

Subject: OUTAGE GREATER THAN 48 HOURS TO REPAIR CRACK IN
FEEDWATER DRAIN LINE

Unit 2 will be shut down for about three days while the licensee repairs a weld crack in a 1-inch feedwater drain line between the containment penetration for the number one steam generator and the last feedwater check valve. The licensee discovered the leak about 2:15 p.m. (EDT) September 30, 1982, and commenced shutdown about 3:15 p.m. (EDT).

There has been no news media interest and none is expected. Neither the licensee nor Region III (Chicago) plans a press release.

The State of Michigan will be notified.

The Senior Resident Inspector was notified of the event at 3 p.m. (EDT), September 30, 1982. This information is current as of 10 a.m., October 1, 1982.

Contact: 955 L. Reyes
384-2540

955 J. Streeter
384-2541

A R. Spessard
384-2552

B210080189 B21001
PDR I&E
PNO-III-82-105 PDR

DISTRIBUTION:

H. St. 1134
Chairman Palladino
Comm. Gilinsky
Comm. Ahearne
Comm. Roberts
Comm. Asselstine
SECY
ACRS
CA

MNBB 1200
EDO
PA
MPA
ELD

Phillips 1139
NRR

Air Rights 1140
SP

E/W 1157
IE
OIA
AEOD

INPO 114
NSAC 114

Willste 1158
NMSS
RES

MAIL:
ADM:DMB
DOT: Trans Only

PDR Regions I 105, II 107, IV 109, V 111 Licensee (Corporate Office) 1141

FE34