

LICENSEE EVENT REPORT

Attachment to AECM-82/439

Page 1 of 1

CONTROL BLOCK: (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

| M | S | G | G | S | | | 1 | | (7) | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | (3) | 4 | 1 | 1 | 1 | 1 | (4) | | | | (5)

CON'T
 | L | (6) | 0 | 5 | 0 | 0 | 0 | 4 | 1 | 6 | | (7) | 0 | 9 | 0 | 9 | 8 | 2 | | (8) | 1 | 0 | 0 | 5 | 8 | 2 | (9)

0 2 | The smoke detector zone covering the hallway area elevation 93' foot Aux. building
 0 3 | and the HPCS pump room alarmed and would not clear. No smoke or fumes were present
 0 4 | and a fire watch was established in accordance with Tech. Spec. 3.3.7.9. There was
 0 5 | no effect on the health and safety of the public. This event did not constitute a
 0 6 | threat to plant or public safety.

SYSTEM CODE (11) | CAUSE CODE (12) | CAUSE SUBCODE (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE (15) | VALVE SUBCODE (16)
 LER/RO REPORT NUMBER (17) | EVENT YEAR 8 2 (21) | SEQUENTIAL REPORT NO. 0 6 6 (24) | OCCURRENCE CODE 0 3 (28) | REPORT TYPE L (30) | REVISION NO. 0 (32)

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0 0 0 0 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER H 2 6 0 (26)

1 0 | The zone failed in an alarmed condition due to dust accumulation on the ionization
 1 1 | smoke detectors. One detector was found in alarm, cleaned and returned to service on
 1 2 | 10 Sept. 82. This is a final report.

FACILITY STATUS (28) | % POWER 0 0 0 (29) | OTHER STATUS NA (30) | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION Alarmed Condition (32)

ACTIVITY CONTENT RELEASED OF RELEASE (33) | AMOUNT OF ACTIVITY NA (35) | LOCATION OF RELEASE NA (36)

PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION NA (39)

PERSONNEL INJURIES NUMBER C 0 0 (40) | DESCRIPTION NA (41)

LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA (43)

PUBLICITY ISSUED (44) | DESCRIPTION NA (45)
 8210080289 821005
 PDR ADOCK 05000416
 S PDR
 NRC USE ONLY
 68 69 80