

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 C A S 0 S 2 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 1 4 5

LICENSEE CODE      LICENSE NUMBER      LICENSE TYPE      CAT 58

01 L 6 0 5 0 0 0 0 3 6 1 7 0 9 2 2 8 2 8 1 0 2 1 8 2 9

REPORT SOURCE      DOCKET NUMBER      EVENT DATE      REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 | While in Mode 2, the Condensate Storage Tank T-120 water level fell below the

03 | Technical Specification 3.7.1.3 limit. There was no consequence to public

04 | health and safety since there was no significant decay heat in the core.

05 |

06 |

07 |

08 |

09 H H 11 B 12 A 13 Z Z Z Z Z Z Z Z 14 Z 15 Z 16

SYSTEM CODE      CAUSE CODE      CAUSE SUBCODE      COMPONENT CODE      COMP. SUBCODE      VALVE SUBCODE

17 8 2 1 2 4 1 0 3 L 0

LER/RO REPORT NUMBER      EVENT YEAR      SEQUENTIAL REPORT NO.      OCCURRENCE CODE      REPORT TYPE      REVISION NO.

X 18 F 19 Z 20 Z 21 0 0 0 0 N 23 N 24 Z 25 Z 9 9 9 9 26

ACTION TAKEN      FUTURE ACTION      EFFECT ON PLANT      SHUTDOWN METHOD      HOURS      ATTACHMENT SUBMITTED      NPRD-4 FORM SUB.      PRIME COMP. SUPPLIER      COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 | Inadequate makeup water control to Tank T-121 and a more restrictive than necessary

11 | Technical Specification limit were the cause. Corrective actions include a proposed

12 | Technical Specification change, improved level indication to facilitate control,

13 | and a design change to install automatic level control systems (expected to be

14 | installed prior to 100% power operation).

15 B 0 0 0 29 NA 30 A 31 Operator Observation 32

FACILITY STATUS      % POWER      OTHER STATUS      METHOD OF DISCOVERY      DISCOVERY DESCRIPTION

16 Z 33 Z 34 NA 35 NA 36

ACTIVITY CONTENT      RELEASED OF RELEASE      AMOUNT OF ACTIVITY      LOCATION OF RELEASE

17 0 0 0 37 Z 38 NA 39

PERSONNEL EXPOSURES      NUMBER      TYPE      DESCRIPTION

18 0 0 0 40 NA 41

PERSONNEL INJURIES      NUMBER      DESCRIPTION

19 Z 42 NA 43

LOSS OF OR DAMAGE TO FACILITY      TYPE      DESCRIPTION

20 N 44 NA 45

PUBLICITY ISSUED      DESCRIPTION

NAME OF PREPARER H. B. Ray      PHONE: 714/492-7700

8211020390 821021 PDR ADOCK 05000361 PDR

NRC USE ONLY