THE CINCINNATI GAS & ELECTRIC COMPANY



E. A. BORGMANN SENIOR VICE PRESIDENT October 25, 1982 QA-2074

U. S. Nuclear Regulatory Commission Region III 799 Roosevelt Road Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler

Regional Administrator

WM. H. ZIMMER NUCLEAR POWER STATION UNIT I 10CFR50.55(e), ITEM S-2 LAMINATING OF STRUCTURAL STEEL, DOCKET NO. 50-358, CONSTRUCTION PERMIT NO. CPPR-88, W. O. #57300, JOB E-5590, FILE NO. NRC-9, S-2

Gentlemen:

This letter constitutes our final report concerning the subject condition.

As stated in our previous report, QA-1975, dated September 14, 1982, Henry J. Kaiser Company (HJK) would ultrasonically test all A-36, 1" x 9" plate of heat #802P54610 located in the warehouse and hanger fabrication shop. This test was required per the disposition of HJK NR #E-8369. which identified an edge lamination detected when a plate was being cut in the hanger fabrication shop to be used in safety related supports.

The examination of the plate has been completed and the results indicate that no unacceptable indications were identified in accordance with the requirements of AWS D.1.1-72 for ultrasonic examination. The lamination noted on the NR was rejected using AWS D.1.1-72 criteria for visual inspection, however, it was acceptable by ultrasonic examination requirements.

On this basis, this condition is not considered reportable as the deficiency, if uncorrected, would not adversely affect the safety of operations of the plant during expected lifetime.

B211020493 B21025 PDR ADDCK 05000358 PDR PDR

Mr. J. G. Keppler Region III October 25, 1982, QA-2074

We trust the above will be found acceptable as a final report under 10 CFR 50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

Ву

E. A. BORGMANN

SENIOR VICE PRESIDENT

FKP:ec

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
Attn: W. F. Christianson
Zimmer Project Inspector
Region III