

LICENSEE EVENT REPORT

CONTROL BLOCK:

1	2	3	4	5	6
---	---	---	---	---	---

 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1
---	---

 M E M Y P 1

2	0	0	-	0	0	0	0	-	0	0
---	---	---	---	---	---	---	---	---	---	---

3	4	1	1	1	1
---	---	---	---	---	---

4	5
---	---

7 8 9 14 15 25 26 30 57 CAT 58

CON'T

0	1
---	---

 REPORT SOURCE L

6	0	5	0	0	0	3	0	9
---	---	---	---	---	---	---	---	---

7	1	1	0	9	8	2
---	---	---	---	---	---	---

8	1	2	1	4	8	2
---	---	---	---	---	---	---

9

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0	2
---	---

 SEE ATTACHMENT

0	3
---	---

0	4
---	---

0	5
---	---

0	6
---	---

0	7
---	---

0	8
---	---

0	9
---	---

 SYSTEM CODE C F

11

 CAUSE CODE X

12

 CAUSE SUBCODE Z

13

 COMPONENT CODE E N G I N E

14

 COMP. SUBCODE Z

15

 VALVE SUBCODE Z

16

7 8 9 10 11 12 13 18 19 20
(17) LER/RO REPORT NUMBER

8	2
---	---

—

 SEQUENTIAL REPORT NO.

0	3	8
---	---	---

—

 OCCURRENCE CODE

0	3
---	---

 REPORT TYPE L

—

 REVISION NO.

0

21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN X

18

 FUTURE ACTION X

19

 EFFECT ON PLANT Z

20

 SHUTDOWN METHOD Z

21

 HOURS

0	0	0	0
---	---	---	---

 ATTACHMENT SUBMITTED Y

23

 NPD-4 FORM SUB. N

24

 PRIME COMP. SUPPLIER A

25

 COMPONENT MANUFACTURER E 1 4 7

26

33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0
---	---

 SEE ATTACHMENT

1	1
---	---

1	2
---	---

1	3
---	---

1	4
---	---

1	5
---	---

 FACILITY STATUS H

28

 % POWER

0	0	0
---	---	---

29

 OTHER STATUS NA

30

 METHOD OF DISCOVERY Z

31

 NA

32

 DISCOVERY DESCRIPTION
7 8 9 10 12 13 44 45 46 80

1	6
---	---

 ACTIVITY CONTENT RELEASED OF RELEASE Z

33

 Z

34

 AMOUNT OF ACTIVITY NA

35

 LOCATION OF RELEASE NA

36

7 8 9 10 11 44 45 80

1	7
---	---

 PERSONNEL EXPOSURES NUMBER 0 0 0

37

 TYPE Z

38

 DESCRIPTION NA

39

7 8 9 11 12 13 80

1	8
---	---

 PERSONNEL INJURIES NUMBER 0 0 0

40

 DESCRIPTION NA

41

7 8 9 11 12 80

1	9
---	---

 LOSS OF OR DAMAGE TO FACILITY TYPE Z

42

 DESCRIPTION NA

43

7 8 9 10 80

2	0
---	---

 PUBLICITY ISSUED N

44

 DESCRIPTION NA

45

7 8 9 10 80
NAME OF PREPARER R. H. Nelson
A. J. Cayia
PHONE 207/882-6321
207/623-3521
NRC USE ONLY

10 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

This LER is being filed because of a difference in interpretation of Technical Specification 3.0.c between Region I and the Licensee. In response to a request from Mr. Darrel G. Eisenhut of the NRC dated April 10, 1980, Maine Yankee's Technical Specifications were modified by incorporating a proposed definition for "operability" and an associated requirement regarding operability of normal and emergency power sources to equipment considered to be operable.

The NRC requested change was intended to standardize requirements that both normal and emergency power sources be available to at least one of two redundant components for both components to be considered to be "operable." The correspondence indicated that the requirement was to be applicable except in the Cold Shutdown or Refueling Modes.

Unfortunately, the revised Maine Yankee Technical Specification is not clear and a literal interpretation could be made that the incorporated exception does not negate the requirement but negates the latitude provided while in the Shutdown modes .

The Region has chosen to interpret the Specification in such a manner, in effect, placing more stringent electrical supply requirements on the plant during Cold Shutdown modes than during power operation.

We had always interpreted the Specification 3.0.c as requiring that only one power source be available for equipment to be considered to be operable under the shutdown conditions. We believe this is consistent with NRC approved standard Technical Specifications and the NRC's intent as outlined in the referenced letter requesting the change.

The following describes the event:

During refueling shutdown operations with 24 feet of water above the core, the P-12A RHR pump was removed from service to perform maintenance on vent valve LSI-57. The P-12B RHR pump was placed in operation to provide shutdown cooling. Technical Specification 3.8 requires that one cooling mechanism be in operation with a second mechanism operable whenever there is fuel in the reactor. In excess of 23 feet of water above the core constitutes one mechanism. Improvement modification installation work rendered the DG-1B emergency power source for P-12B inoperable.

Because of the Region's interpretation of Specification 3.0.c and at the suggestion of NRR, we completed the work under the provisions of Technical Specification 3.8 which contains remedial action allowing operation in a degraded mode for 72 hours with one cooling mechanism, and under the provisions of Technical Specification 3.12 which permits one emergency diesel out of service, with other emergency power sources operable, for seven days with the reactor critical (recognizing the reactor was substantially subcritical). Degraded mode operation ended eleven hours later when P-12A, with its emergency power source operable, was returned to service.

Later that day, the refueling cavity level was lowered to less than 23 feet above the core, resulting in a further period of degraded mode operation with the "A" RHR train cooling mechanism in operation and the "B" train operable except for its emergency power source. Degraded mode operation terminated 26 hours later when the DG-1B modification was completed, allowing the "B" RHR train to meet operability criteria.

No fuel movements took place during this period. Since one cooling mechanism was always operable, there was no impact on the health and safety of the public.

27 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

A need to install an emergency diesel generator improvement modification, coupled with the lack of clearly worded Technical Specification cold shutdown and refueling station service power requirements forced the licensee into remedial actions in accordance with Technical Specifications 3.8 and 3.12. In both instances, two core cooling mechanisms were continuously operable. The Region interpreted the specifications to require that both normal and emergency power sources were required to be operable. However, NRR allowed the conservative use, during this refueling, of the remedial action in Technical Specification 3.12, which allows one diesel out of service for up to seven days when the reactor is critical. CE Standard Technical Specifications allow either the normal or emergency power source to be inoperable for each RHR Train. A proposed change to Technical Specification 3.0.c will be submitted to allow either the normal or emergency power source to be inoperable, without compromising operability, during Cold Shutdown, Refueling Shutdown or Refueling Operations conditions.