

Mailing Address

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 783-6081

F. L. Clayton, Jr.
Senior Vice President
Flintridge Building



Alabama Power

the southern electric system

January 14, 1983

Docket No. 50-364

Director, Office of Management
Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555


Dear Sir:

RE: JOSEPH M. FARLEY NUCLEAR PLANT
Unit 2
Monthly Operating Data Report

Attached are two (2) copies of the December, 1982 Monthly Operating Report for Joseph M. Farley Nuclear Plant, Unit 2, required by Section 6.9.1.10 of the Unit 2 Technical Specifications. As requested by letter from Mr. John F. Stolz to Mr. Alan R. Barton, dated October 21, 1977, a "Narrative Summary of Operating Experience" is included in the attached report.

If you have any questions, please advise.

Yours very truly,


for F. L. Clayton, Jr.

FLCJr/KWM:bhj

Enclosures

xc: Mr. Ted Cintula (1 copy)
Director, IE (10 copies)
Director, RII (1 copy)

IE24

JOSEPH M. FARLEY NUCLEAR PLANT
UNIT 2
NARRATIVE SUMMARY OF OPERATIONS
DECEMBER, 1982

The Cycle I - Cycle II Refueling Outage continued into the month of December. The unit was shutdown on December 10, 1982 for the performance of the turbine overspeed trip test.

The following safety-related maintenance was performed in the month of December:

1. Performed miscellaneous maintenance on diesel generators.
2. Adjusted valve pressure setting on Power Operated Relief Valve PCV444B.
3. Repacked #7 River Water Pump.