

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | S | C | V | C | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 0 | 0 | 0 | 4 | 5
7 8 9 14 18 23 26 30 37 41 45
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 56

CONT

0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 9 | 5 | 7 | 0 | 5 | 0 | 6 | 8 | 3 | 8 | 0 | 6 | 0 | 3 | 8 | 3 | 9
7 8 40 41 46 49 54 57 62 65 70 73 76 79 84 87 90
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On May 6, 1983, with the Plant in Mode 5, an Operations personnel inadvertently
 0 3 | stepped through a Maronite Board fire barrier located above the "A" Service Water
 0 4 | Booster Pump. The Maronite was still functional as a partial fire barrier. The
 0 5 | potential for any adverse consequence was minimized as a continuous fire watch was
 0 6 | established within one (1) hour in accordance with Technical Specifications 3.7.10
 0 7 | Action Statement (a).
 0 8 |

0 9 | A B (11) | A (12) | B (13) | X X X X X X (14) | Z (15) | Z (16)
9 10 11 12 13 14 15 16 17 18 19 20
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
 (17) LER/RO REPORT NUMBER | 8 3 | - | 0 4 3 | / | 0 3 | L | - | 0
21 22 23 24 25 26 27 28 29 30 31 32
 EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS (22) ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER (26)
 B (18) F (19) Z (20) Z (21) 0 0 0 (22) N (23) N (24) L (25) Z 9 9 9 (26)
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Cause -- see above. The barrier (27) was repaired by May 7, 1983. The subject area
 1 1 | has been posted to keep personnel off the barrier. Also, a Station Memorandum
 1 2 | has been issued to further disseminate this information. The Licensee is currently
 1 3 | evaluating possible preventive measures for long term solution. Any resulting
 1 4 | modifications will be implemented upon design approval and material procurement.

1 5 | G (28) | 0 0 0 (29) | N/A (30) | A (31) | Operator Observation (32)
7 8 9 10 11 12 13 44 45 46 80
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z (33) | Z (34) | N/A (35) | N/A (36)
7 8 9 10 11 44 45 80
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 0 0 (37) | Z (38) | N/A (39)
7 8 9 10 11 12 13 80
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 0 0 (40) | N/A (41)
7 8 9 10 11 12 80
 PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | (42) | N/A (43) | 8306100208 830603 PDR ADOCK 05000395 S PDR
7 8 9 10 44 45 80
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 C | N (44) | N/A (45)
7 8 9 10 80
 PUBLICITY ISSUED DESCRIPTION

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE 764

COLUMBIA, SOUTH CAROLINA 29218

O. W. DIXON, JR.
VICE PRESIDENT
NUCLEAR OPERATIONS

June 3, 1983

Mr. James P. O'Reilly
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II, Suite 2900
101 Marietta Street, N.W.
Atlanta, Georgia 30303

83 JUN 7 9:28
USNRC REGION I
ATLANTA, GEORGIA


SUBJECT: Virgil C. Summer Nuclear Station
Docket No. 50/395
Operating License No. NPF-12
Thirty Day Written Report
LER 83-043

Dear Mr. O'Reilly:

Please find attached Licensee Event Report #83-043 for Virgil C. Summer Nuclear Station. This Thirty Day Report is required by Technical Specification 6.9.1.13.(b) as a result of entry into Action Statement (a) of Technical Specification 3.7.10, "Fire Rated Assemblies," on May 6, 1983.

Should there be any questions, please call us at your convenience.

Very truly yours,



O. W. Dixon, Jr.

HCF:OWD/dwf
Attachment

cc: V. C. Summer
E. H. Crews, Jr.
T. C. Nichols, Jr., /O. W. Dixon, Jr.
E. C. Roberts
H. N. Cyrus
Group/General Managers
O. S. Bradham
R. B. Clary
C. A. Price
A. R. Koon
D. A. Lavigne

C. L. Ligon (NSRC)
G. J. Braddick
J. C. Miller
J. L. Skolds
J. B. Knotts, Jr.
I&E (Washington)
Document Management
Branch
INPO Records Center
NPCF
File (Lic./Eng.)

OFFICIAL COPY

1022

41