

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D I C I C 1 2 0 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 0 2 0 3 8 3 3 0 2 2 5 8 3 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 DURING AN OPERATIONS TOUR OF THE 4KV ROOM, FIRE DOOR #460 WAS DISCOVERED TO BE
0 3 BLOCKED OPEN. THIS CONDITION WAS NONCONSERVATIVE WITH RESPECT TO T.S. 3.7.10. THE
0 4 ACTION REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.
0 5 PREVIOUS OCCURRENCE: 82-064

0 9 SYSTEM CODE A B 11 CAUSE CODE A 12 CAUSE SUBCODE X 13 COMPONENT CODE X X X X X X X 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
17 LER/RO REPORT NUMBER 18 3 19 0 1 2 20 0 3 21 L 22 0
33 X 34 Z 35 Z 36 Z 37 0 0 0 0 38 N 39 N 40 A 41 Z 42 9 43 9 44 9 45 9 46 9 47 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 A METAL PLATE WAS FOUND BETWEEN THE DOOR STOP AND THE DOOR. THIS PREVENTED THE
1 1 DOOR FROM FULLY CLOSING. NO RESPONSIBLE PARTY OR PROBABLE CAUSE FOR BLOCKING THE
1 2 DOOR OPEN COULD BE FOUND. THE METAL PIECE WAS REMOVED FROM THE 4KV ROOM AND THE
1 3 DOOR OPERATED SATISFACTORILY.

1 5 FACILITY STATUS E 28 % POWER 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 OPERATOR OBSERVATION 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 6 ACTIVITY CONTENT Z 33 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 7 PERSONNEL EXPOSURES NUMBER 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 8 PERSONNEL INJURIES NUMBER 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

2 0 PUBLICITY ISSUED DESCRIPTION N 44 NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

8303080384 830225
PDR ADOCK 05000315
S PDR

NRC USE ONLY

NAME OF PREPARER

PAUL CARTEAUX

PHONE:

616-465-5901