

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK:

--	--	--	--	--	--

 ①

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT 58	

REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 0 1 2 9 8 3 8 0 3 0 1 8 3 9

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Routine surveillance during plant operation revealed that primary containment

03 | atmosphere oxygen analyzer, 2-CAC-AT-1263-2, indicated a 0.5% step decrease in

04 | drywell oxygen concentration. At the time of this event, redundant instrument,

05 | 2-CAC-AT-1259-2, showed an expected indication of drywell oxygen concentration.

06 | This event did not affect the health and safety of the public.

07 | Page

08 | Technical Specifications 3.3.5.3, 3.6.6.4, 6.9.1.9b

7 8 9

0 9

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

S E 11 E 12 E 13 I N S T R U 14 Y 15 Z 16

9 10 11 12 13 14 15 16 17 18 19 20

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENCE REPORT NO.	OCCURRENCE CODE		REPORT TYPE	NO.					
21	22	23	24	25	26	27	28	29	30	31	32
8	3	—	0	2	0	/	0	3	L	—	0

ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME CON: SUPPLIER	COMPONENT MANUFACTURER
E	C	Z	Z	0	0	0	N	Y	N	B 1 3 5
32	18	34	19	35	20	36	21	37	38	39
40	41	42	43	44	45	46	47	48	49	50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | This event resulted from a zero shift in the 1263-2 instrument magnetic analyzer.

1 1 The magnetic analyzer was replaced and the 1263-2, Model No. F3M3, was calibrated

and returned to service. These type CAC monitors are being replaced in accordance

1 2 with an approved plant modification.

3	4	
---	---	--

7 8 9
FACILITY STATUS (28) E
% POWER 0 7 5 (29) NA
OTHER STATUS (30)
METHOD OF DISCOVERY (31) A
DISCOVERY DESCRIPTION (32) Operator Surveillance

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z (33) Z (34) NA 45

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	40 NA

1 9		Z (42)		NA	
2	8	9	8303210317	830301	8

IS S PDR ADCK 05000324 PDR NA

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521

NRC USE ONLY

0.0000