

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

RECEIVED  
NRC

50-528  
50-529

1983 JUN 17 PM 12:20  
June 8, 1983

ANPP-24003-BSK/RQT

REGION V

U. S. Nuclear Regulatory Commission  
Region V  
Creekside Oaks Office Park  
1450 Maria Lane - Suite 210  
Walnut Creek, CA 94596-5368

Attention: Mr. D. M. Sternberg, Chief  
Reactor Projects Branch 1

Subject: Time Extension - DER 83-14  
A 50.55(e) Potentially Reportable Deficiency Relating to  
Diesel Generator Protective Relays By Westinghouse Failed Due  
to Leaking Capacitors.  
File: 83-019-026; D.4.33.2

Reference: (A) Telephone Conversation between A. D'Angelo and  
R. Tucker on March 16, 1983  
(B) ANPP-23504 dated April 14, 1983 (Interim Report)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in  
Reference (A), and an Interim Report was transmitted by Reference (B).  
At that time, it was estimated that a Final Report would be available  
by June 28, 1983.

Due to the extensive investigation and evaluation required, it is now  
expected that this information will be finalized by August 31, 1983, at  
which time a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,

*E. E. Van Brunt*

E. E. Van Brunt, Jr.  
APS Vice President  
Nuclear Projects Management  
ANPP Project Director

EEVB/RQT:ru  
cc: See Page 2

8306230318 830608  
PDR ADOCK 05000528  
S PDR

110  
IF-27

U. S. Nuclear Regulatory Commission  
Page 2

cc: Richard DeYoung, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

T. G. Woods, Jr.  
G. C. Andognini  
J. A. Roedel  
D. B. Fasnacht  
A. C. Rogers  
B. S. Kaplan  
W. E. Ide  
J. Vorees  
J. R. Bynum  
P. P. Klute/D. D. Green  
A. C. Gehr  
W. J. Stubblefield  
W. G. Bingham  
R. L. Patterson  
R. W. Welcher  
R. M. Grant  
D. R. Hawkinson  
L. E. Vorderbrueggen  
G. A. Fiorelli  
S. R. Frost

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway - Suite 1500  
Atlanta, Georgia 30339