

# CP&L

Carolina Power & Light Company

Brunswick Steam Electric Plant  
P. O. Box 10429  
Southport, NC 28461-0429

February 25, 1983

FILE: B09-13510C  
SERIAL: BSEP/83-653


Mr. James P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
Region II, Suite 3100  
101 Marietta Street N.W.  
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-324  
LICENSE NO. DPR-62  
CANCELLATION OF A 24-HOUR REPORTABLE EVENT (2-83-16)

Dear Mr. O'Reilly:

In our letter of February 10, 1983, we notified your office of what was thought to be a 24-hour reportable event per Technical Specification 3.7.7.1. This report dealt with the loss of alternate power supplies to both the motor driven and diesel driven fire pumps. Subsequent reviews and testing has determined that the surveillance performed on the diesel driven fire pump batteries had incorrectly recorded battery voltage. A review of this surveillance and retesting determined that both batteries to the diesel fire pump were within specifications and, therefore, the diesel driven fire pump was always in an operational mode. This letter is to inform you that CP&L now considers this event to be nonreportable.

Very truly yours,



C. R. Dietz, General Manager  
Brunswick Steam Electric Plant

RMP/mcg/LETDJ4

Enclosure

cc: Mr. R. C. DeYoung  
NRC Document Control Desk

83 MAR 4 11:30

NRC REGION II  
ATLANTA, GEORGIA

OFFICIAL COPY

76 25

B303210700 B30225  
PDR ADOCK 05000324  
S PDR