


Structural Dynamics Technology, Inc.
292 Gibraltar Dr., Suite A-5 • Sunnyvale, CA 94086 • (408) 745-7744

8303240487 830322
PDR ADOCK 05000313
PDR

STRUCTURAL EVALUATION
OF THE ARKANSAS NUCLEAR ONE-UNIT I
SPENT FUEL STORAGE FACILITY
FOR CONSOLIDATED FUEL STORAGE


Prepared by
Structural Dynamics Technology, Inc.
for
Arkansas Power and Light Company

Prepared By:



Thomas A. Ballard, P.E.
Project Engineer

Reviewed and Approved by:



Joseph J. Sturkey, P.E.
Engineering Manager

Controlled Copy 4



Structural Dynamics Technology, Inc.

292 GIBRALTAR DRIVE • SUITE A5 • SUNNYVALE, CA. 94086 • (408) 745-7744

REVISION CONTROL SHEET

REPORT NUMBER: APL-01-014

SUBJECT: Structural Evaluation of the Arkansas Nuclear One -
Unit 1 Spent Fuel Storage Facility for Consolidated
Fuel Storage

PREPARED BY:

Thomas A. Ballard
Principal Engineer TAB

NAME/TITLE INITIAL

Joseph J. Sturkey
Engineering Manager JJS

NAME/TITLE INITIAL

Robert D. Curley
Engineer RDC

NAME/TITLE INITIAL

NAME/TITLE INITIAL

NAME/TITLE INITIAL

NAME/TITLE INITIAL

PAGE NO.	REV. NO.	PRE-PARED	ACCURACY CHECK	CRITERIA CHECK
i	0	TAB	RDC	N/A
ii	↓	↓	↓	↓
iii	↓	↓	↓	↓
iv	↓	↓	↓	↓
v	↓	↓	↓	↓
vi	↓	↓	↓	N/A
1.1	↓	↓	↓	JJS
1.2	↓	↓	↓	↓
1.3	↓	↓	↓	↓
2.1	↓	↓	↓	↓
2.2	↓	↓	↓	↓
2.3	↓	↓	↓	↓
2.4	↓	↓	↓	↓
3.1	↓	↓	↓	↓
3.2	↓	↓	↓	↓
3.3	↓	↓	↓	↓
3.4	↓	↓	↓	↓
3.5	↓	↓	↓	↓
3.6	0	TAB	RDC	JJS

PAGE NO.	REV. NO.	PRE-PARED	ACCURACY CHECK	CRITERIA CHECK
4.1	0	TAB	RDC	JJS
4.2	↓	↓	↓	↓
4.3	↓	↓	↓	↓
4.4	↓	TAB	RDC	JJS
4.5	↓	RDC	TAB	N/A
4.6	↓	↓	↓	↓
4.7	↓	RDC	TAB	N/A
4.8	↓	↓	↓	↓
5.1	↓	TAB	RDC	JJS
5.2	↓	↓	↓	↓
5.3	↓	↓	↓	↓
5.4	↓	↓	↓	↓
5.5	↓	↓	↓	↓
6.1	↓	↓	↓	↓
6.2	↓	↓	↓	↓
6.3	↓	↓	↓	↓
6.4	↓	TAB	RDC	↓
6.5	↓	RDC	TAB	↓
6.6	0	RDC	TAB	JJS

STRUCTURAL DYNAMICS TECHNOLOGY, INC.

REVISION CONTROL SHEET

(Continuation)

SUBJECT:

REPORT NUMBER: APL-01-014

PAGE NO.	REV. NO.	PRE-PARED	ACCURACY CHECK	CRITERIA CHECK	PAGE NO.	REV. NO.	PRE-PARED	ACCURACY CHECK	CRITERIA CHECK
6.7	0	RBC	TAB	JJS					
6.8									
6.9									
6.10									
6.11									
6.12									
6.13									
6.14									
6.15									
6.16									
6.17				JJS					
6.18				N/A					
6.19									
6.20									
6.21									
6.22									
6.23									
6.24									
6.25		RBC	TAB	N/A					
7.1		TAB	RBC	JJS					
7.2									
8.1									
9.1				JJS					
A.1				N/A					
A.2									
A.3									
A.4									
A.5									
A.6									
A.7									
A.8									
A.9									
A.10									
A.11									
A.12									
A.13									
A.14									
A.15									
A.16	0	TAB	RBC	N/A					

EXECUTIVE SUMMARY

The purpose of this report is to present the results of the structural evaluation of the Arkansas Nuclear One-Unit 1 spent fuel storage facility for high density fuel storage. This activity was undertaken to determine whether it is possible to increase the fuel storage capacity of the existing spent fuel pool in the Unit 1 plant through utilization of high density fuel storage racks. This report discusses loading conditions, structural response to the critical loading conditions, definition of appropriate load combinations, and evaluation of the structural adequacy in accordance with the applicable criteria.

The evaluation utilized a detailed finite element model of the spent fuel pool to accurately quantify the structural response to various loading conditions. Computer techniques permitted assessment of all appropriate postulated load combinations, and a thorough comparison of forces and moments throughout the structure to allowable values established by the governing ACI Code.

As a result of this evaluation, it is concluded that the Arkansas Nuclear One-Unit 1 spent fuel pool has adequate capacity to resist all load combinations defined in the NRC Standard Review Plan (NUREG-0800). In addition, the margin between actual force and moment values and ACI Code allowable values may be adequate to permit future additional increase in the fuel storage capacity of the ANO Unit 1 spent fuel pool through fuel consolidation.

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
	EXECUTIVE SUMMARY	i
	TABLE OF CONTENTS	ii
	LIST OF TABLES.....	iv
	LIST OF FIGURES.....	v
1	INTRODUCTION.....	1.1
	1.1 Evaluation Criteria.....	1.2
	1.2 Analysis Methodology.....	1.2
2	SPENT FUEL POOL FINITE ELEMENT MODEL DEVELOPMENT.....	2.1
	2.1 Spent Fuel Pool Geometry.....	2.1
	2.2 Finite Element Model Boundary Conditions.....	2.3
3	LOAD DEVELOPMENT	3.1
	3.1 Development of Individual Load Cases.....	3.1
4	FINITE ELEMENT ANALYSIS RESULTS.....	4.1
	4.1 Verification of Results.....	4.1
	4.2 Controlling Load Case Results.....	4.1
5	INITIAL POST-PROCESSING AND LOAD COMBINATION FORMULATION.....	5.1
	5.1 Derivation of Section Resultant Forces and Moments.....	5.1
	5.2 Composite Load Formulation.....	5.2
	5.3 Final Load Combination Formulation.....	5.3

TABLE OF CONTENTS (Continued)

6	ACI CRITERIA POST-PROCESSING	6.1
	6.1 Flexure and Axial Loads.....	6.1
	6.2 Evaluation for Shear and Torsion	6.3
7	MISCELLANEOUS LOADINGS AND OTHER EFFECTS	7.1
	7.1 Liner Plate Evaluation	7.1
	7.2 Miscellaneous Loads	7.2
8	CONCLUSIONS	8.1
9	REFERENCES	9.1

APPENDIX - SPENT FUEL POOL FINITE ELEMENT MODEL

LIST OF TABLES

<u>TABLE</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
2-1	Summary of Material Properties.....	2.4
3-1	Individual Load Case Description Table.....	3.5
3-2	Summary of Load Definition Parameters	3.6
5-1	Summary of Composite Loads.....	5.4
5-2	Load Combination Summary Table.....	5.5
6-1	Tabulation of Controlling Section Resultant Moments.....	6.5
6-2	Tabulation of Resultant Transverse Shear Forces	6.11
6-3	Tabulation of Resultant In-plane Shear Forces.....	6.16

LIST OF FIGURES

<u>FIGURE</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
4-1	Accident Thermal Deformed Geometry Plot Plan at Elevation 404'	4.5
4-2	Accident Thermal Deformed Geometry Plot Plan at Elevation 362'	4.6
4-3	Accident Thermal Deformed Geometry Plot Elevation View of East Wall	4.7
4-4	Accident Thermal Deformed Geometry Plot Elevation View of West Wall	4.8
6-1	Floor Slab Bending Moments Causing North-South Direction Stresses	6.18
6-2	Floor Slab Bending Moments Causing East-West Direction Stresses	6.19
6-3	Floor Slab Concrete Stresses in North-South Direction on Top of Slab	6.20
6-4	Floor Slab Concrete Stresses in East-West Direction	6.21
6-5	Floor Slab Reinforcing Steel Stresses for Top North-South Reinforcing	6.22
6-6	Floor Slab Reinforcing Steel Stresses for Top East-West Reinforcing	6.23
6-7	Floor Slab Reinforcing Steel Stresses for Bottom North-South Reinforcing	6.24
6-8	Floor Slab Reinforcing Steel Stresses for Bottom East-West Reinforcing	6.25

APPENDIX: SPENT FUEL POOL MODEL DRAWINGS

<u>FIGURE</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
1	Plans and Sections.....	A.2
2	Key Diagrams and Dimensions	A.3
3	Floor Element and Node Numbers	A.4
4	East Wall Element Numbers	A.5
5	East Wall Node Numbers	A.6
6	West Wall Element Numbers	A.7
7	West Wall Node Numbers	A.8
8	Pool Wall Adjoining the Cask Laydown Area Element and Node Numbers	A.9
9	Fuel Transfer Canal Inside Wall Element and Node Numbers	A.10
10	Foundation Walls Element Numbers	A.11
11	Foundation Walls Node Numbers	A.12
12	Cask Laydown Area Floor Element and Node Numbers.....	A.13
13	Cask Laydown Area Walls Element and Node Numbers.....	A.14
14	Fuel Transfer Canal Outside Wall and Floor Element and Node Numbers	A.15
15	Fuel Transfer Canal Area West Wall Element and Node Numbers	A.16

1.0 INTRODUCTION

This report is divided into various sections that address different aspects of the evaluation process, and an Appendix is provided for drawings which document the computer model of the spent fuel pool.

Section 2.0 discusses the finite element model utilized for this evaluation, including a detailed description of the representation of the component parts of the pool, boundary conditions applied to this model, and representation of shear walls and floor diaphragms that frame into the pool at various elevations and locations. Section 3.0 discusses the load development, including a description of each of the individual load cases, with references to applicable data for their derivation. Section 4.0 discusses the results for the controlling individual load case. Section 5.0 is a discussion of the post-processing that was carried out to transform the basic analysis results into the form required for evaluation in accordance with the specified design criteria, and Section 6.0 presents the results of the design criteria evaluation. Section 7.0 discusses miscellaneous loading conditions that were not explicitly addressed in the computer analysis, and addresses other structural considerations, such as the pool liner plate. Section 8.0 presents the conclusion of this evaluation, and Section 9.0 identifies the reference documents that were utilized.

To provide non-ambiguous quality assurance traceability, and facilitate discussion of the analysis results, SDT has assigned a unique acronym identifier to each individual computer analysis run. Tabulation of the results will reference these unique computer run identifiers, which will be defined where necessary. Microfiche of the computer

output and data tapes for each of these computer analysis run will be transmitted to Arkansas Power and Light Company for archival purposes, along with full quality assurance documentation of each of these computer analysis runs. In addition, the calculations that were prepared in conjunction with the finite element model generation, load development and criteria check will also be provided to Arkansas Power and Light for archival purposes.

1.1 Evaluation Criteria

The criteria utilized for this evaluation are contained in Reference 1 (ANO-Unit 1 Design Criteria) and 4 (NRC Standard Review Plan). The original pool was designed in accordance with ACI 318-63 Code Criteria and load combinations, as specified in Reference 1. However in the interest of obtaining a more comprehensive evaluation, Arkansas Power and Light Company has elected to use NRC Standard Review Plan (Reference 4) load combinations, and take guidance from ACI 349 (Reference 2) in the reinforced concrete evaluation. All other criteria specified in Reference 1 were applied to this evaluation, with operating specifications utilized to define applicable analysis parameters. Free standing fuel rack loads on the pool structure were obtained from the fuel rack vendor (Reference 9).

1.2 Analysis Methodology

Due to the complexity of loadings and structural configuration, the finite element method was selected for the calculation of pool structural response. Since transverse shear is a relatively important concrete cross-section force component in this evaluation,

it was decided to utilize solid elements rather than thin shell elements that typically have less than adequate transverse shear formulation. The STARDYNE computer program (Reference 10) which has a long history of successful usage in the nuclear industry, and which has good quality control procedures, was used to perform the analysis.

Postprocessing was performed using a verified SDT postprocessor that performs load combinations and ACI code criteria checking for the combined effect of axial load and bending moment. Additional ACI criteria checks were carried out by hand calculations utilizing postprocessor results where appropriate.

2.0 SPENT FUEL POOL FINITE ELEMENT MODEL DEVELOPMENT

This section documents the finite element model utilized to carry out the spent fuel pool evaluation for Arkansas Nuclear One Unit 1. Included in this section is a discussion of the extent of the model, the structural boundary conditions, and the development of stiffnesses for shear walls and floor diaphragms that interact with the spent fuel pool. A set of detailed computer-generated geometry plots that fully defines the node numbers and element connectivity for the model is also provided in an Appendix. These plots serve to verify the geometry of the computer model as well as providing Arkansas Power and Light Company Engineering personnel with a means of potentially further utilizing the computer model or the detailed microfiche results.

2.1 Spent Fuel Pool Geometry

The finite element model is comprised of an assemblage of eight node, three-dimensional solid elements and four node membrane elements. The model includes the pool floor and walls, the fuel transfer canal floor and walls, and the cask laydown area floor and walls. Also included are the supporting foundation walls beneath the pool. The pool walls and floor slab are modeled with two layers of three-dimensional eight node solid elements. The reason for this detail is that, in order to apply a thermal gradient to the walls and floor, it is necessary to define that gradient has a uniform temperature of differing magnitude at each brick centroid through the wall thickness. In addition to these solid elements, membranes of negligible thickness are added to the inside, outside and middle planes of the walls and floor, in order to permit stress recovery at these locations, in addition to the centroids of each solid element. In this manner, stresses are computed at

five locations through the wall thickness, and these stresses are integrated to determine the section resultant forces and moments for the criteria check phase. The south and west walls of the fuel transfer canal area, and the north and west walls of the cask laydown area are modeled with one layer of solid elements. These walls are included in the model only for the purpose of properly modeling the stiffness contribution of these components to the overall pool structure. Also, membrane elements have not been modeled for the exterior walls of the cask laydown area and fuel transfer canal area. The foundation walls below the pool floor are modeled with a single layer of solid elements since the thermal gradient defined for this region is relatively small or nonexistent. In the case where a small gradient exists, the uncracked section is assumed to resist the full thermal moment developed by this gradient. The foundation walls do include membrane elements on their inside and outside surfaces for the purpose of section force and moment derivation.

The spent fuel pool liner plate is not modeled explicitly, since this component is not meant to provide additional strength to the floors and walls. Liner plate strains, however, can be recovered from the inside membrane elements of the walls and floor to permit a structural assessment of the liner plate. The portion of the foundation beneath the cask laydown area floor is modeled for approximately six feet below the floor slab elevation. This region is extremely stiff, has no thermal gradients defined, and is considered rigid, relative to the rest of the structure. Figures 1 and 2 of the Appendix show the extent of the spent fuel pool model as discussed herein. Figures 3 through 15 fully describe the finite element model node and element numbering scheme.

2.2 Finite Element Model Boundary Conditions

The objective in applying boundary conditions to the finite element model is to correctly represent the interaction of the pool structure with adjacent auxiliary building floors and walls, and only impose rigidity assumptions at locations that are sufficiently remote, such that analysis results are not incorrectly influenced by assumed boundary conditions.

Several floor diaphragms and shear walls frame into the pool at various elevations and locations. These floors and walls are included in the finite element model as stiffness matrix additions, which economically represent the effect of these restraining structures without the expense of explicit modelling. The matrix elements are defined such that shear is transferred between adjacent nodes in the plane of these walls or floor diaphragms. The stiffness of these diaphragms is derived based on the shear stiffness of a concrete panel of the same dimensions as the component being considered, assuming that, due to cracking, one-half of this panel stiffness is available. Other boundary conditions applied to this model consist of restraining all degrees of freedom of the nodes at the bottom of the entire pool foundation, which is very remote from the pool structural areas of interest.

Table 2-1 documents the material properties utilized for the spent fuel pool finite element analysis, which were reviewed by AP & L Engineering prior to incorporation into the analysis. These properties are based on standard accepted values or the original design criteria specification for the plant. The modulus of elasticity for the pool structure is a composite value, determined based on a ratio of steel modulus to concrete modulus of 7.25.

Table 2-1

Arkansas Power and Light Company
 ANO-1 Spent Fuel Pool Evaluation
 Summary of Material Properties

<u>Item</u>	<u>Value</u>		<u>Reference</u>
Concrete Compressive Strength	5,000	lb/in ²	11
Reinforcing Yield Strength	40,000	lb/in ²	1
Reinforcing Elastic Modulus	29.0 × 10 ⁶	lb/in ²	2
Concrete Elastic Modulus	4.00 × 10 ⁶	lb/in ²	(Note 1)
Concrete Poisson Ratio	0.17		3
Concrete Thermal Expansion Coefficient	5.5 × 10 ⁻⁶	in/in/°F	2
Concrete Weight Density	8.68 × 10 ⁻²	lb/in ³	3
	(150	lb/ft ³)	

Note: 1) Concrete composite elastic modulus based on a ratio of the elastic modulus of steel to concrete equal to 7.25.

3.0 LOAD DEVELOPMENT

This section discusses the development and verification of the loads applied to the Arkansas Nuclear One-Unit 1 Spent Fuel Pool finite element model. A summary of the individual loads is presented in Table 3-1.

3.1 Development of Individual Load Cases

To provide flexibility in forming load combinations, as discussed in Section 5.0, the analysis was performed for primary, uncombined loads on an individual basis. These loads consist of dead weight of the concrete, hydrostatic pressure, accident flood load, normal operating and accident thermal loads, a nominal 1.0 g east/west seismic acceleration, a 1.0g north/south seismic acceleration, fuel rack submerged deadweight load, and fuel rack seismic reaction loads. These loads are developed on an individual basis so that they may be combined after the analysis is complete, in any required manner to represent different magnitudes and directions of the various applied loadings. The loading due to the fuel handling crane is excluded from this evaluation, since it is concluded that this effect on the overall pool structure is beneficial when considering this in combination with other loadings. This conclusion is based upon the observation that the upper portion of the pool walls are subjected to a relatively small vertical axial load when the crane load is excluded. For shear as well as axial load-moment interaction, compressive axial load is beneficial, in terms of the section's capacity to resist these forces. Therefore, excluding the crane load in combination with other live loads is conservative.

Table 3-2 identifies the parameters utilized in defining the loads discussed herein. This table, along with the indicated references, documents the assumptions utilized for load development.

Deadweight of the concrete structure is defined as a 1.0g vertical acceleration. This 1.0g vertical acceleration results in a downward vertical force at each node of the finite element model, equal to the tributary weight assigned to each node, and a total downward force equal to the weight of the reinforced concrete structure. The unit weight of reinforced concrete is defined in Table 2-1.

The pool water level is defined as 39.5 feet above the top of the pool floor slab, and water density is defined as 62.4 pounds per cubic foot. The concentrated nodal forces due to hydrostatic pressure are derived by multiplying the hydrostatic pressure at the elevation of the finite element node being considered by the tributary surface area for that node. The tributary surface area of a node is calculated as one-fourth of the surface areas of the membrane elements surrounding the node point. This total pressure force is transformed into global forces based on the direction cosines of the vector normal to the surface of the membrane elements surrounding the node being considered. This load was verified by generating a summation of the nodal forces and comparing the resulting force with manual calculations for the volume of the pool times the water density.

Accident flood load is defined as a hydrostatic pressure on the outside of the east wall of the pool structure from elevation 335 to elevation 361, and was generated in a manner similar to that described above.

Accident and operating thermal loads are defined based on the temperatures of each compartment, as shown in Table 3-2. This load is developed as a uniform thermal load on each membrane and brick element in the model, based on linear interpolation between the compartment temperatures. This is a conservative definition of thermal loads since conduction through the concrete for a true steady state condition will result in temperatures on the outside surface of each wall significantly higher than the gross air temperature in the respective compartment. Thermal gradients may not necessarily develop in a linear manner prior to the steady state condition; however, the local effect of a gradient which decays more rapidly within the concrete will not result in a more significant gross structural response than that resulting from a pure linear gradient defined based on compartment air temperature and the pool water temperature. The one exception to this assumption is the stress in the liner plate due to the thermal loads at the beginning of the transient. This is considered, however, separate from the basic finite element analysis and discussed in Section 7.1.

The operating basis earthquake (OBE) is defined utilizing six separate individual loads in order to properly account for the various possible seismic motion directions and variation in fuel rack loadings. Reference 8 defines the response spectra from which the earthquake loads discussed herein were defined.

It is not necessary to treat the vertical earthquake loadings associated with acceleration of the pool water mass and concrete mass as separate primary load cases since these loadings can be formulated in a post-processing step, utilizing the static

deadweight of concrete and hydrostatic load cases with the appropriate factor to account for dynamic amplification of the seismic motion.

The horizontal earthquake acceleration is defined by calculating the average spectral acceleration, reported in Reference 8, over the height of the pool, and applying this as an acceleration load in one horizontal direction and then in the orthogonal horizontal direction. Earthquake response of the pool water is defined based on the methodology outlined in Reference 5, Appendix F. The hydrodynamic loads are calculated as pressure profiles over the pool wetted surface and distributed to each node based on nodal tributary area. The resulting nodal forces were summed to determine the net resulting hydrodynamic forces in orthogonal directions, and these force resultants were verified using additional methodology in Reference 5, which defines the integrated pressure resultants. For simplicity, the combined east/west and north/south earthquake loadings are normalized to a 1.0g earthquake, and are combined with the appropriate g factor in a post-processing phase.

Reference 9 defines the fuel rack loads utilized in this analysis. They consist of a submerged deadweight loading, and a vertical and horizontal reaction loading due to the operating basis earthquake. These reaction loads are distributed to the pool floor node points based on the proximity of each pad to the surrounding nodes. The earthquake loads are distributed in the same proportion as the deadweight loads, with the total force equal to that specified in Reference 9. These loads were not normalized to 1.0g as was done for the pool water and concrete mass effects.

Table 3-1

Arkansas Nuclear One-Unit 1
 Spent Fuel Storage Facility Structural Evaluation
 Individual Load Case Description Table

<u>Load Case No.</u>	<u>Notation</u>	<u>Description</u>
1	D_c	Dead weight of the concrete.
2	H	Hydrostatic pressure due to water in the pool.
3	F	Accident flood load.
4	$T_o^{(1)}$	Normal operating thermal load.
5	$T_a^{(1)}$	Accident thermal load.
6	$E_{ew}^{(2)}$	Load generated by east-west 1.0g earthquake.
7	$E_{ns}^{(2)}$	Load generated by north-south 1.0g earthquake
8	D_{fr}	Fuel rack dead weight load.
9	FR_v	Reaction load of fuel racks during 0.067g vertical earthquake.
10	FR_{ew}	Reaction load of fuel racks during 0.1g east-west earthquake.
11	FR_{ns}	Reaction load of fuel racks during 0.1g north-south earthquake.

- NOTE: (1) Includes effects of thermal moment on the foundation walls due to 28° thermal gradient.
- (2) Includes effect of pool hydrodynamic load, and pool wall horizontal inertial forces.

Table 3-2

Arkansas Power and Light Company
 ANO-1 Spent Fuel Pool Evaluation
 Summary of Load Definition Parameters

<u>Item</u>	<u>Description</u>	<u>Reference</u>
Pool Properties:		
Pool Water Elevation	401'-6"	6
Pool Normal Operating Temperature	150°F	6
Pool Accident Temperature	212°F	4
Pool Hydrodynamic Forces	TID 7024, App F	5
Auxiliary Building Compartment Temperatures:		
Adjacent Pool North, East and South Walls	60°F	7
Adjacent Pool West Wall	32°F	7
Inside Foundation Walls	60°F	7
Inside Cask Laydown Area	60°F	7
Inside Fuel Transfer Canal Area	60°F	7
Outside Foundation Walls Below Elevation 356' - 6"	32°F	7
Thermal Stress Free Temperature	60°F	7
Operating Conditions		
Fuel Transfer Canal	Dry	
Cask Laydown Area	Dry	
Accident Flood Conditions	EL 335' to 361'	7
Seismic Ground Accelerations		
OBE Horizontal	0.10g	1
OBE Vertical	0.067g	1
SSE Horizontal	0.20g	1
SSE Vertical	0.133g	1

4.0 FINITE ELEMENT ANALYSIS RESULTS

This section discusses the finite element analysis results; in particular, results for the controlling load case.

4.1 Verification of Results

The results of the finite element analysis were examined to insure that realistic deflections and stresses existed for each load case. Also, stresses and deflections in the base slab are examined for several load cases and compared to classical solutions. In addition, the finite element results were compared to results from ANO-2 analytical model presented in Reference 12 with very good agreement. The conclusion of this process is that the finite element model is behaving in a reasonable manner.

4.2 Controlling Load Case Results

Based upon examination of the results for the individual primary load cases described in the previous section, one load case was determined to be controlling, and is described further in this section. The accident thermal load, defined as 212°F inside the pool, 60°F in all other compartments except those adjacent to the west wall, and the entire foundation below elevation 356 for which the temperature is defined as 32°F. This load results in a gradient across the pool walls and floor equal to 152°F, with the exception of the west wall and foundation walls which have a gradient of 180°F and 32°F, respectively.

Figures 4-1 through 4-4 are deformed geometry plots at various sections and plans. These deformed geometry plots show the restraining effects that various parts of the structure have on the components that are being heated by the pool water. Based upon thorough investigation of the results, it is concluded that the accident thermal gradient is, by far, the controlling load case. This thermal gradient causes significant bending moments about horizontal and vertical axes, resulting in significant transverse and in-plane shear forces at several locations.

The fuel transfer canal separation wall responds to the thermal gradient by deflecting outward at the upper west corner. This response causes significant transverse shear forces at the upper east corner and the lower west corner at the bottom of the gate opening. Also, the overall temperature increase on this wall causes significant in-plane shear at the bottom of the gate opening, as a result of the restraining effect that the lower portion of the wall has on the upper portion, which is free to expand because of the gate opening.

The pool east wall is expanding vertically due to the average temperature increase in that wall. The east walls of the fuel transfer canal and cask laydown area are not subjected to this thermal load, and therefore, they act as a vertical restraining force on the east wall of the pool. This results in significant vertical tensile forces in the east walls of the fuel transfer canal and cask laydown area, but more importantly, this also results in significant horizontal tensile forces in the top portion of the east pool wall, due to the poisson effect. This effect is illustrated in Figure 4-3.


The north and west walls of the pool are responding in a manner similar to the east wall, whereby adjacent walls with lower average temperature provide vertical restraint, thus inducing horizontal tension in the restrained wall. This can be observed in the pool west wall at the end adjacent to the fuel transfer canal, and for the north wall at the end adjacent to cask laydown.

The intersection of the north and west walls, however, responds in a considerably different manner. Since the north and west wall have the same average temperature, the restraint mechanism described for other regions does not exist at this corner; however, a different mechanism exists, which also results in significant horizontal tensile forces at the tops of these walls at this corner. SDT has constructed small parametric models to investigate the nature of this behavior in more detail. Based on these parametric models, it has been determined that the horizontal tensile force in this corner is primarily due to the vertical bending moment (causing vertical stresses) along the top edge of both of these walls at the corner intersection. This can be further visualized by describing the manner in which the thermal load is actually applied to a structure of this nature. A plate that is fixed on three edges and free at the top, subjected to a thermal gradient, could be idealized, for the purpose of calculating displacements, as a plate fixed on three sides and subjected to a bending moment along the free edge. This pseudo-thermal bending moment would be proportional to the moment of inertia of the plate, the elastic modulus of the material, and the thermal gradient. Extending this concept to the pool model, specifically at the corner where the west wall and the north wall intersect, it can be shown that the horizontal tension in the corner is due primarily to the membrane stiffness of these two walls resisting the bending moment applied to the top of the adjacent wall framing in at 90 degrees. Since the membrane stiffness of these

walls is much higher than the bending stiffness of the adjacent wall, most of the bending moment is resisted by this membrane tensile forces at this corner.


The base slab grows uniformly in all directions as a result of the overall temperature increase. This response results in significant in-plane horizontal tensile forces in all of the foundation walls. These foundation walls, however, are provided to primarily carry vertical load, and the fact that the sections are subjected to horizontal in-plane tensile forces is of secondary concern for the integrity of the pool. Significant transverse shears are also observed at the intersection of the foundation walls with the base mat.

Figure 4-1
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility
Accident Thermal Deformed Geometry Plot
Plan at Elevation 404'





Data from AFPSTA1A2-01

Figure 4-2
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility
Accident Thermal Deformed Geometry Plot
Plan at Elevation 362'





Data from APFSTA1A2-01

Figure 4-3
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility
Accident Thermal Deformed Geometry Plot
Elevation View of East Wall



Data from AFPSTA1A2-01

Figure 4-4
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility
Accident Thermal Deformed Geometry Plot
Elevation View of West Wall



Data from AFPSTA1A2-01

5.0 INITIAL POST-PROCESSING AND LOAD COMBINATION FORMULATION

This section discusses the process whereby the results of the finite element analysis are transformed as required for Code evaluation, and combined in various ways to arrive at the final load combinations specified in Reference 4.

5.1 Derivation of Section Resultant Forces and Moments

The results of the finite element analysis are in the form of normal stresses and shear stresses on the three orthogonal planes of the three-dimensional solid elements. Since the ACI Code is set up more directly to utilize section resultant forces and moments, the stresses resulting from the finite element analysis must be integrated to obtain these quantities. The areas of the pool considered in the evaluation include the pool foundation walls, the pool floor slab, and the four walls of the pool structure. Excluded from further evaluation are the outer walls of the fuel transfer canal area and the outer walls of the cask laydown area.

From the finite element analysis, the floor and walls of the pool structure have stresses defined at five locations through their thickness. These five points of stresses are integrated assuming a linear variation between points in order to produce the section resultant forces and moments for Code evaluation purposes. These resulting forces and moments include two normal forces in a plane for each integrated element, an in-plane shear force, two transverse shear force components, two bending moment components and one twisting moment component. These forces and moments are defined utilizing conventional shell theory, and are specified on a per-unit-length basis.

5.2 Composite Load Formulation

Following the finite element analysis, the first post-processing step necessitated combination of the individual primary load cases into composite loads, such that the final load combinations could be performed simply by applying the factor specified in Reference 4 to the appropriate composite case. These composite load cases are defined as deadload, live load, operating thermal load, accident thermal load, loads generated by 1.0g operating basis earthquake, and flood load. Table 5-1 shows the individual load cases along with the appropriate factors necessary to formulate these composite loads.

The composite deadload is obtained by combining the deadweight of concrete with the hydrostatic pressure loads. Live load consists of the submerged weight of the fuel racks, including their fuel complement. It would be logical to include only the fuel as live load, however, the loading is presented in Reference 9 as a total load, and as such, must conservatively be considered entirely as live load. Operating thermal, accident thermal and flood load are considered as their respective individual loads.

Reference 4 specifies that earthquake directions shall be combined by taking the square root of the sum of the squares (SRSS) of individual directional responses. Since this, by definition, does not consider the sign of the load, and since reinforced concrete must be evaluated based on the force and moment interaction for a particular section, it was not considered logical to proceed based on this simplifying specification of the Standard Review Plan. An alternative to this is to formulate earthquake response by adding the effects of the three orthogonal directions in various permutations to produce the same results as an SRSS methodology, but maintaining the algebraic signs associated with the

forces and moments. Table 5-1 indicates the factors applied to each of the individual loads to arrive at four composite earthquake loads. Four other composite earthquake loads are derived in a similar manner.

5.3 Final Load Combination Formulation

Reference 4 specifies the load combinations required to be evaluated for this class of structure. Table 5-2 shows the seven load cases that result by elimination of load combinations that are not applicable to this structure. Out of these seven load cases, load case seven has been determined to be the controlling combination. The basic reason for this conclusion is that the thermal accident load is by far the controlling load on this structure and, as such, results in the maximum load combination.

Load case seven is evaluated by including the effects of the SSE earthquake considering the eight possible seismic motion direction combinations as previously discussed. In accordance with the requirements of References 2 and 4, where it is determined that live load cancels out or reduces the effect of a particular earthquake load, live load is excluded from that combination. Also, when it is determined that deadweight, including hydrostatic, reduces or cancels out an earthquake load, deadweight is reduced by ten percent. SSE response is defined as 2.0 times OBE response. For the fuel rack reaction loads, this is a conservative assumption since Reference 9 specifies a value less than 2.0 times OBE for the SSE reaction forces.

Table 5-1
Arkansas Nuclear One-Unit 1
Spent Fuel Storage Facility Structural Evaluation
Summary of Composite Loads

Composite Loads	Load Factors										Description	
	D _c	H	F	T _o	T _a	E _{ew}	E _{ns}	D _{fr}	FR _v	FR _{ew}		FR _{ns}
D	1.0	-	-	-	-	-	-	-	-	-	-	Dead Load
L	-	-	-	-	-	-	-	1.0	-	-	-	Live Load
T _o	-	-	-	1.0	-	-	-	-	-	-	-	Operating Thermal Load
T _a	-	-	-	-	1.0	-	-	-	-	-	-	Accident Thermal Load
E1	0.067	0.067	-	-	-	0.1	0.1	-	1.0	1.0	1.0	Loads Generated by
E2	0.067	0.067	-	-	-	0.1	-0.1	-	1.0	1.0	-1.0	.1g Operating
E3	-0.067	-0.067	-	-	-	0.1	0.1	-	-	1.0	1.0	Basis Earthquake
E4	-0.067	-0.067	-	-	-	0.1	-0.1	-	-	1.0	-1.0	
F	-	-	1.0	-	-	-	-	-	-	-	-	Flood Load

Table 5-2
 Arkansas Nuclear One-Unit 1
 Spent Fuel Storage Facility Structural Evaluation
 Load Combination Summary Table

<u>No.</u>	<u>Load Combination</u>	<u>Reference⁽¹⁾</u>
1	$1.4D + 1.7L + 1.9E$	Load Case 2
2	$.75(1.4D + 1.7L + 1.7T_o)$	Load Case 4
3	$.75(1.4D + 1.7L + 1.7T_o + 1.9E)$	Load Case 5
4	$D + L + T_o + E'$	Load Case a
5	$D + L + T_o + F$	Load Case b
6	$D + L + T_o$	Load Case c
7	$D + L + T_o + 1.25E'$	Load Case d

- Notes: (1) Reference 4 Section 3.8.4.
 (2) E' Represents a load generated by .20g safe shutdown earthquake (SSE). For simplicity, this is taken conservatively as 2.OE.

6.0 ACI CRITERIA POST-PROCESSING

This section discusses the methodology utilized to carry out the ACI Code evaluation of the spent fuel pool facility. Included in this section is a discussion of the post-processing carried out to account for the change in the moment due to thermal loading as reinforced concrete sections experience normal tensile cracking. In addition, the methods utilized to determine the acceptability of the structure relative to in-plane shear, transverse shear, and twisting moments are discussed.

6.1 Flexure and Axial Loads

Chapter 10 of Reference 2 (ACI 349-80) is the basis for qualifying the structure for combined effects of axial force and bending moment. Capacity reduction factors are taken as .9 and .7 for axial tension and compression, respectively. The restrained thermal moments from the linear structural analysis are processed to account for changes in the thermal moment magnitude as the section cracks, such that the section's curvature and static equilibrium are maintained. The relieved thermal moment is then defined as the moment required to maintain that static equilibrium and curvature for the cracked concrete section. For a given section, subjected to the combined effect of axial load and bending moment, following accepted ACI techniques, for the given magnitude of axial force, the allowable magnitude of bending moment is calculated. Table 6-1 presents the results of this evaluation for the controlling load combination for the spent fuel pool. This table identifies the critical sections for each pool and foundation component, along with the allowable bending moment associated with the section axial force, and the ratio of the actual relieved section moment to the allowable section

moment for the applied section axial force. Redistribution of force and moment was considered in regions near the top of the pool walls. This is considered logical since, if the section yields, not only will the forces and moments be redistributed, but much of the thermally-induced force and moment will be relieved. As seen from Table 6-1, all of the locations shown have significant margin relative to their ultimate strength.

Creep effects are not considered to be important since the loads associated with the normal service life of the spent fuel pool constitute a very small percentage of the ultimate strength of the concrete sections. Accident thermal and seismic loads are considered to be short duration loads and thus do not cause appreciable creep.

Figures 6-1 through 6-6 present contour plots of the bending moments and concrete and reinforcing stresses resulting from the controlling load combination. These results were obtained by relaxation of the thermal bending moment, maintaining section equilibrium and curvature. These plots indicate the restraining effect that the portion of the floor slab in the fuel transfer canal has on the pool floor slab. This is due to the ambient condition in the fuel transfer canal versus accident thermal temperatures in the pool floor slab. Also, the slab below the cask lay down area causes a similar concentration of stresses near this region for the same reason. Since the pool walls and foundation do not provide as high a degree of restraint on the pool floor slab, the bending moments along the east and west walls tend to be lower than elsewhere in the floor slab. Concrete and reinforcing stresses follow the same pattern of stress distribution as their associated bending moments, with the top of the slab in compression and the bottom in tension.

6.2 Evaluation for Shear and Torsion

Section 11 of Reference 2 (ACI 349-80) presents the Code requirements for evaluation for concrete structures subjected to shear and torsion. Within this Reference, it is specified that walls and slabs shall be evaluated by calculation of the section force extending in a plane across the entire width or height, and located at a distance from the face of the reaction area equal to the distance from the compressive face of the section to the centroid of the tensile steel. This section of the Code allows an averaging approach to be taken when evaluating wall and slab-type structures. Tables 6-2 and 6-3 present the results for the transverse shear force and in-plane shear force evaluation, respectively.

As seen in Table 6-2, several areas of the structure are close to their allowable values. Specifically, regions of the pool walls near the corners have high transverse shear. The east and west walls of the pool have been designed with a heavily-reinforced area at the top. One function of this embedded beam is to carry the offset crane loads, however, the shear reinforcing provided in this area also serves to carry the transverse shears, and provides a significant margin.

Table 6-3 shows the results of the in-plane shear evaluation. In accordance with ACI methodology, sections for in-plane shear evaluation are defined at locations that are not closer to the base of the walls than one-half the wall height or length. The fuel transfer canal wall just above the bottom of the gate opening has very high in-plane shear due primarily to the restraining effect that the lower portion of the wall has on the free edge of the upper portion at the gate opening when subjected to thermal expansion.

The east foundation wall is shown in Table 6-3 to be over code allowable for in-plane shear. This shear is due almost entirely to the floor slab thermal growth and as such is a secondary effect. As this wall yields, not only will much of the applied shear force be reduced, but other portions of the foundation, such as the west wall will pick up the load. In addition, other walls are located in the vicinity of the foundation but were not included in the pool model. These walls will provide additional redundancy to the foundation's ability to resist the in-plane shear forces.

TABLE 6-1
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility Evaluation
Tabulation of Controlling Section Resultant Moments (1)

Location	Section Axial Force	Section Resultant Moment(2,4)	Section Allowable Moment(3)	Moment Code Ratio
Pool Floor Slab: (AFPSTAL2-09)				
East - West Section at South End (Element 320)	-47.58	1005.	1321.	0.76
North - South Section at Mid-span (Element 320)	-35.50	1093.	1869.	0.59
Pool Foundation: (AFPSTAL2-10)				
South Wall, Horizontal Section at Top (Element 2865)	-17.31	315.7	811.8	0.39
East Wall, Horizontal Section at Top (Element 2877)	-18.30	351.2	827.4	0.42
West Wall, Horizontal Section at Top (Element 2857)	-16.68	391.8	801.7	0.49

Units: Kips/Inch, Kip-inches/Inch

- Notes:
- 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
 - 2) Positive moment causes tension on outside surface of walls and lower surface of floor slab.
 - 3) Allowable moment is based on strength design method per ACI 349/80.
 - 4) T_a moments are relieved, maintaining equilibrium and curvature of section.

Table 6-1 (continued)
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility Evaluation
Tabulation of Controlling Section Resultant Moments (1)

Location	Section Axial Force	Section Resultant Moment ^(2,4)	Section Allowable Moment ⁽³⁾	Moment Code Ratio
East Pool Wall: (AFPST1A2-05)				
Vertical Section at Bottom North Corner (Element 2823)	-35.58	1262.	2235.	0.57
Horizontal Section at Bottom North Corner (Element 2329)	-38.51	1284.	2121.	0.61
Vertical Section at Top Center Span (Average Elements 6324, 5824, 5324, 4824 - AFPST1A2-12)	14.58	219.8	1027.	0.21

Units: Kips/Inch, Kip-inches/Inch

- Notes:
- 1) NUREG-0800 Load Combination ($D + L + T_a + 1.25E'$)
 - 2) Positive moment causes tension on outside surface of walls and lower surface of floor slab.
 - 3) Allowable moment is based on strength design method per ACI 349/80.
 - 4) T_a moments are relieved, maintaining equilibrium and curvature of section.

Table 6-1 (continued)
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility Evaluation
Tabulation of Controlling Section Resultant Moments (1)

Location	Section Axial Force	Section Resultant Moment(2,4)	Section Allowable Moment(3)	Moment Code Ratio
West Pool Wall: (AFPST1A2-08)				
Vertical Section at Bottom Mid-span (Element 2306)	-32.89	1298.	2219.	0.58
Horizontal Section near Bottom South End (Element 2808)	-34.82	1217.	2059.	0.59
Vertical Section at Top Mid-span (Average Elements 6304, 5804, 5304, 4804 - AFPST1A2-12)	14.97	205.0	1015.	0.20

6.7

Units: Kips/Inch, Kip-inches/Inch

- Notes: 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
- 2) Positive moment causes tension on outside surface of walls and lower surface of floor slab.
- 3) Allowable moment is based on strength design method per ACI 349/80.
- 4) T_a moments are relieved, maintaining equilibrium and curvature of section.

Table 6-1 (continued)
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Spent Fuel Storage Facility Evaluation
 Tabulation of Controlling Section Resultant Moments (1)

Location	Section Axial Force	Section Resultant Moment(2,4)	Section Allowable Moment(3)	Moment Code Ratio
Fuel Transfer Canal Separation Wall: (AFPSTAI A2-07)				
Vertical Section Below Elevation of Bottom of Gate Opening (Element 3313)	-40.93	769.2	1147.	0.67
Horizontal Section at Bottom of Wall (Element 2818)	-31.80	540.0	872.5	0.62
Vertical Section at Top East End (Average Elements 4818, 5318, 5818, 6318 - AFPSTAI A2-12A)	-6.624	166.0	397.6	0.42
Horizontal Section at West End of Wall Above Elevation of Bottom of Gate Opening (Average Elements 4314 thru 4318 - AFPSTAI A2-12A)	-16.58	369.4	587.0	0.63

Units: Kips/Inch, Kip-inches/Inch

- Notes: 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
- 2) Positive moment causes tension on outside surface of walls and lower surface of floor slab.
- 3) Allowable moment is based on strength design method per ACI 349/80.
- 4) T_a moments are relieved, maintaining equilibrium and curvature of section.

Table 6-1 (continued)
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility Evaluation
Tabulation of Controlling Section Resultant Moments (1)

Location	Section Axial Force	Section Resultant Moment(2,4)	Section Allowable Moment(3)	Moment Code Ratio
Cask Laydown Separation Wall: (AFPSTA1A2-06)				
6.9				
Vertical Section Below Elevation of Bottom of Gate Opening (Element 3335)	-34.62	466.3	664.6	0.70
Horizontal Section at Bottom Mid-span (Element 2335)	-34.35	396.7	572.4	0.69
Vertical Section at East End of Wall Above Elevation Of Bottom of Gate Opening (Element 3834)	-13.41	188.4	367.0	0.51

Units: Kips/Inch, Kip-inches/Inch

- Notes: 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
- 2) Positive moment causes tension on outside surface of walls and lower surface of floor slab.
- 3) Allowable moment is based on strength design method per ACI 349/80.
- 4) T_a moments are relieved, maintaining equilibrium and curvature of section.

Table 6-1 (continued)
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Spent Fuel Storage Facility Evaluation
 Tabulation of Controlling Section Resultant Moments (1)

Location	Section Axial Force	Section Resultant Moment(2,4)	Section Allowable Moment(3)	Moment Code Ratio
Pool North Wall: (AFPSTA1A2-11)				
Vertical Section at Middle West Edge (Element 3839)	-3.483	292.1	433.5	0.67
Horizontal Section at Middle West Edge (Element 3839)	-38.50	1002.	1384.	0.72
Vertical Section at Top West End (Average Elements 6339, 5839, 5339, 4839 - AFPSTA1A2-12)	0.496	170.2	307.3	0.55

Units: Kips/Inch, Kip-inches/Inch

- Notes:
- 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
 - 2) Positive moment causes tension on outside surface of walls and lower surface of floor slab.
 - 3) Allowable moment is based on strength design method per ACI 349/80.
 - 4) T_a moments are relieved, maintaining equilibrium and curvature of section.

6.10

TABLE 6-2
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility Evaluation
Tabulation of Resultant Transverse Shear Forces (1)

Location	Section Shear ⁽²⁾	Allowable Section Shear ⁽³⁾	Code Shear Ratio
Pool Floor Slab: (AFPSTA1A2-04)			
North-South Section at Middle (Average Elements 314 thru 320)	1.701	7.230	0.24
East-West Section at North Edge (Average Elements 300,307,314,321, 328,335)	6.257	21.69	0.29
Pool Foundation: (AFPSTA1A2-04)			
South Foundation Wall, Horizontal Section at Top (Average Elements 2364 thru 2371)	5.792	14.58	0.40
East Foundation Wall, Horizontal Section at Top (Average Elements 2374 thru 2381)	3.518	7.305	0.48

Units: Kips/Inch

- Notes: 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
- 2) Shear forces are linearly interpolated to a distance from the face of the effective support equal to the distance from the section compressive face to the centroid of the tensile steel.
- 3) Allowable shear is based on strength design method per ACI 349/80.

6.11

TABLE 6-2 (continued)
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility Evaluation
Tabulation of Resultant Transverse Shear Forces (1)

Location	Section Shear ⁽²⁾	Allowable Section Shear ⁽³⁾	Code Shear Ratio
Pool Foundation: (AFPSTA1A2-04)			
West Foundation Wall, Horizontal Section at Top (Average Elements 2350 thru 2361)	3.813	6.589	0.58
West Pool Wall: (AFPSTA1A2-04)			
Vertical Section at Top North Corner (Element 6302)	25.79	31.79	0.81
Horizontal Section at Mid-Height (Average Elements 3802 thru 3808)	3.376	7.860	0.43
Horizontal Section at Top (Average Elements 5802 thru 5808)	6.148	8.463	0.73

Units: Kips/Inch

- Notes:
- 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
 - 2) Shear forces are linearly interpolated to a distance from the face of the effective support equal to the distance from the section compressive face to the centroid of the tensile steel.
 - 3) Allowable shear is based on strength design method per ACI 349/80.

6.12


TABLE 6-2 (continued)
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility Evaluation
Tabulation of Resultant Transverse Shear Forces (1)

Location	Section Shear ⁽²⁾	Allowable Section Shear ⁽³⁾	Code Shear Ratio
East Pool Wall: (AFPSTA1A2-04)			
Vertical Section at Top South End (Element 6323)	17.80	31.79	0.56
Horizontal Section Near Top (Average Elements 5823 thru 5829)	3.875	8.372	0.46
Fuel Transfer Canal Separation Wall: (AFPSTA1A2-04)			
Vertical Section at West End Below Bottom of Gate Opening (Average Elements 2313,1813,3313)	0.898	5.018	0.18
Horizontal Section at Bottom of of Wall (Average Elements 2313 thru 2318)	1.235	5.468	0.23

Units: Kips/Inch

- Notes:
- 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
 - 2) Shear forces are linearly interpolated to a distance from the face of the effective support equal to the distance from the section compressive face to the centroid of the tensile steel.
 - 3) Allowable shear is based on strength design method per ACI 349/80.

6.13



APL-01-014
January 15, 1983

TABLE 6-2 (continued)
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility Evaluation
Tabulation of Resultant Transverse Shear Forces (1)

Location	Section Shear ⁽²⁾	Allowable Section Shear ⁽³⁾	Code Shear Ratio
Fuel Transfer Canal Separation Wall: (AFPST1A2-04)			
Vertical Section at East End (Element 6318)	4.610 ⁽⁴⁾	5.054	0.91
Horizontal Section at Top (Average Elements 5814 thru 5818)	5.179	5.869	0.88
Cask Laydown Area Separation Wall: (AFPST1A2-04)			
Vertical Section Below Gate Opening (Average Elements 2335,2835,3335)	0.741	3.861	0.19
Horizontal Section at Bottom of Wall (Average Elements 2334,2335,2336)	1.504	4.810	0.31

Units: Kips/Inch

- Notes:
- 1) NUREG-0300 Load Combination (D + L + T_a + 1.25E')
 - 2) Shear forces are linearly interpolated to a distance from the face of the effective support equal to the distance from the section compressive face to the centroid of the tensile steel.
 - 3) Allowable shear is based on strength design method per ACI 349/80.
 - 4) Transverse shear adjusted based upon cracked section equilibrium moment gradient.

6.14

TABLE 6-2 (continued)
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility Evaluation
Tabulation of Resultant Transverse Shear Forces (1)

Location	Section Shear(2)	Allowable Section Shear(3)	Code Shear Ratio
Pool North Wall: (AFPSTA1A2-04)			
Vertical Section at Top of Wall (Average Elements 5839,6339)	4.407	5.580	0.79

Units: Kips/Inch

- Notes:
- 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
 - 2) Shear forces are linearly interpolated to a distance from the face of the effective support equal to the distance from the section compressive face to the centroid of the tensile steel.
 - 3) Allowable shear is based on strength design method per ACI 349/80.

TABLE 6-3
Arkansas Power and Light Company
Arkansas Nuclear One - Unit 1
Spent Fuel Storage Facility Evaluation
Tabulation of Resultant In-plane Shear Forces (1)

Location	Section Shear	Allowable Section Shear ⁽²⁾	Code Shear Ratio
Pool Floor Slab: (AFPSTAL2-04)			
North-South Section at Mid-length (Average Elements 314 thru 320)	4.796	30.28	0.16
East-West Section at Mid-length (Average Elements 303,310,317,324 331,338)	4.329	10.43	0.42
Pool Foundation: (AFPSTAL2-04) (3)			
South Wall Section at Mid-height (Average Elements 1864 thru 1871)	7.983	14.57	0.55
East Wall Section at Mid-height (Average Elements 1874 thru 1881)	17.29	12.50	1.38
West Wall Section at Mid-height (Average Elements 1850 thru 1861)	9.847	12.38	0.80
West Pool Wall: (AFPSTAL2-04)			
Section Near Top (Average Elements 5302 thru 5308)	5.751	31.68	0.18

Units: Kips/Inch

- Notes: 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
- 2) Allowable shear is based on strength design method per ACI 349/80.
- 3) Foundation wall shear force is calculated at mid-height.

TABLE 6-3 (continued)
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Spent Fuel Storage Facility Evaluation
 Tabulation of Resultant In-plane Shear Forces (1)


Location	Section Shear	Allowable Section Shear ⁽²⁾	Code Shear Ratio
East Pool Wall: (AFPSTA1A2-04)			
Section Near Top (Average Elements 5323 thru 5329)	1.114	31.68	0.04
Fuel Transfer Canal Separation Wall: (AFPSTA1A2-04)			
Lower Wall Below Bottom of Gate Opening (Average Elements 3313 thru 3318)	11.04	23.38	0.47
Upper Wall Above Bottom of Gate Opening (Average Elements 4314 thru 4318)	12.82	13.87	0.92
Cask Laydown Area Separation Wall: (AFPSTA1A2-04)			
Section Below Bottom of Gate Opening (Average Elements 3334 thru 3336)	3.371	17.60	0.19
Pool North Wall: (AFPSTA1A2-04)			
Section Near Top of Wall (Average Elements 5838, 5839)	10.41	14.00	0.74

Units: Kips/Inch

- Notes: 1) NUREG-0800 Load Combination (D + L + T_a + 1.25E')
- 2) Allowable shear is based on strength design method per ACI 349/80.

6.17


FIGURE 6-1
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Floor Slab Bending Moments
 Causing North-South Direction Stresses



SDT
 Structural
 Dynamics
 Technology

Notes: 1) Positive moment causes tension on bottom of slab.
 2) Data from AFPSTA1A2-09

FIGURE 6-2
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Floor Slab Bending Moments
 Causing East-West Direction Stresses



6.19

Units: In-lb/in

CONTOUR LEVELS

MIN	.64687E+06
A	.64687E+06
B	.69645E+06
C	.74603E+06
D	.79561E+06
E	.84519E+06
F	.89477E+06
G	.94435E+06
H	.99393E+06
I	.10435E+07
J	.10931E+07
MAX	.10931E+07



Notes: 1) Positive moment causes tension on bottom of slab.
 2) Data from AFPSTA1A2-09.

APL-01-014
 January 15, 1983

FIGURE 6-3
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Floor Slab Concrete Stresses
 In North-South Direction on Top of Slab


6.20



Units: psi

CONTOUR LEVELS

MIN	-2489.2
A	-2489.2
B	-2426.0
C	-2362.7
D	-2299.4
E	-2236.1
F	-2172.8
G	-2109.5
H	-2046.2
I	-1982.9
J	-1919.6
MAX	-1919.6



Structural
 Dynamics
 Technology

Notes: 1) Positive stresses denote tension.
 2) Data from AFPSTA1A2-09.

FIGURE 6-4
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Floor Slab Concrete Stresses
 In East-West Direction on Top of Slab

6.21



Units: psi

CONTOUR LEVELS

MIN -2012.2

A -2012.2

B -1916.7

C -1821.2

D -1725.7

E -1630.2

F -1534.7


G -1439.2

H -1343.7

I -1248.2


J -1152.7

MAX -1152.7



Notes: 1) Positive stresses denote tension.
 2) Data from AFPSTALA2-09.

FIGURE 6-5
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Floor Slab Reinforcing Steel Stresses
 For Top North-South Reinforcing



Units: psi

CONTOUR LEVELS

MIN	-20089.
A	-20089.
B	-19490.
C	-18891.
D	-18292.
E	-17692.
F	-17093.
G	-16494.
H	-15894.
I	-15295.
J	-14696.
MAX	-14695.

Notes: 1) Positive stresses denote tension.
 2) Data from AFPSTAL2-09.

FIGURE 6-6
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Floor Slab Reinforcing Steel Stresses
 For Top East-West Reinforcing

6.23




Units: psi
 CONTOUR LEVELS

MIN	-14852.
A	-14852.
B	-14047.
C	-13242.
D	-12438.
E	-11633.
F	-10828.
G	-10023.
H	-9218.6
I	-8413.8
J	-7609.1
MAX	-7609.1




Structural
 Dynamics
 Technology



Notes: 1) Positive stresses denote tension.
 2) Data from AFPSTAL2-09.


FIGURE 6-7
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Floor Slab Reinforcing Steel Stresses
 For Bottom North-South Reinforcing



Structural
 Dynamics
 Technology

Notes: 1) Positive stresses denote tension
 2) Data from AFPSTAL2-09.

FIGURE 6-8
 Arkansas Power and Light Company
 Arkansas Nuclear One - Unit 1
 Floor Slab Reinforcing Steel Stresses
 For Bottom East-West Reinforcing



Notes: 1) Positive stresses denote tension.
 2) Data from AFPSTA1A2-09.

7.0 MISCELLANEOUS LOADINGS AND OTHER EFFECTS

This section discusses the evaluation of the pool liner plate and horizontal reinforcing in the pool walls, and addresses miscellaneous loading conditions.

7.1 Liner Plate Evaluation

Reference 12 discusses the calculations carried out to evaluate the adequacy of the liner plate for ANO-2. This evaluation considered the effect of differential coefficient of thermal expansion of the liner plate versus the concrete for the accident thermal load case. It has been shown by experience that this loading is, by far, the controlling load on the liner plate. The liner plate in ANO-Unit 1 is very similar in detail and anchorage as that in the Unit 2 pool.

The ANO-2 evaluation was carried out considering the load-deflection characteristics of the anchors, and the interaction between the stiffnesses of the liner plate panels and these anchors. This evaluation also addressed the possibility that there is a buckled liner plate in series with the unbuckled liner plates being evaluated. Based on the evaluation, it was determined that a factor of safety of 4.3 exists for the liner plate. Additional loads associated with the new horizontal fuel rack reactions are negligible when compared to the thermal effects, and in view of the substantial safety factor involved, are not of concern. Based on the similarity in anchorage and liner plate details between the pools of Unit 1 and Unit 2, it is concluded that the Unit 1 pool liner plate is adequate.

7.2 Miscellaneous Loads

Several loads have not been explicitly addressed in this report since they are not appropriate for this evaluation or since they have been eliminated by other licensing considerations. These loads include postulated cask drop, rack uplift, fuel drop, and heavy loads handling. The question of cask drop and heavy loads handling has been addressed previously by Arkansas Power and Light Company. Rack uplift and the associated impact loading have not been evaluated at this time since they are still under development by the fuel rack vendor, and fuel rod drop is to be evaluated by fuel rack vendor. However, in view of the significant reserve capacity of the pool floor to resist additional shear forces and bending moments, it is reasonable to assume that these postulated loading conditions will not affect the conclusion that the structure is adequate to resist the applied loads.

8.0 CONCLUSIONS

Based on the results presented in Section 6, it is concluded that the spent fuel pool structure is adequate to carry the additional loadings associated with high density fuel storage racks. In addition, it is believed that the pool will be adequate for higher loads due to full fuel consolidation, however, this condition has not been formally evaluated. Since the primary effect of additional fuel is to increase the forces and moments in the base slab and foundation, and these components already have significant margin, as seen in the Section 6 tables and contour plots, SDT does not believe that additional loading due to full consolidation will present a problem.


9.0 REFERENCES

1. "Structural Design Criteria for the Arkansas Power and Light Company, Arkansas Nuclear One-Unit 1, Job 6600-1," Bechtel Power Corporation, Revision 1, October 1968.
2. ACI Standard, "Code Requirements for Nuclear Safety Related Concrete Structures (ACI 349-80)," American Concrete Institute, April 1981.
3. Troxel, Davis and Kelly, "Composition and Properties of Concrete," McGraw-Hill, 1968.
4. NUREG-0800, "Standard Review Plan for Review of Safety Analysis Reports for Nuclear Power Plants," Revision 1, U.S. Nuclear Regulatory Commission, July 1981.
5. TID-7024, "Nuclear Reactors and Earthquakes," U.S. Atomic Energy Commission, Washington D.C., August 1963.
6. Arkansas Nuclear One - Unit 1, Operating Procedure 1104.6, "Spent Fuel Cooling System, Revision 4, July 16, 1975.
7. Bechtel Calculations 80, Job 6600-1, "Design of Spent Fuel Pool Walls & Slabs for Dead, Live and Hydrostatic Loads," July 1974.
8. Specification APL-C-502, "Technical Specifications for Earthquake Resistent Design of Equipment Located in Auxiliary Building for the Arkansas Nuclear One - Unit 1 Power Plant," Arkansas Power & Light Company, Little Rock, Arkansas, Revision 1, April 1, 1982.
9. Westinghouse Electric Corporation Letter GLD-82-059, dated September 2, 1982.
10. STARDYNE User Information Manual, Control Data Corporation, Revision C, 1980.
11. Bechtel Calculations 11406-080, Job 11406-080, "Check of Spent Fuel Pool for Additional Loads Caused by Increasing the Fuel Rack Capacity," April 1979.
12. SDT Report APL-02-013, "Structural Evaluation of the Arkansas Nuclear One - Unit 2 Spent Fuel Storage Facility for Consolidated Fuel Storage," Revision 0, dated November 24, 1982.


APPENDIX
ARKANSAS I NUCLEAR ONE - UNIT 1
SPENT FUEL POOL
FINITE ELEMENT MODEL

ARKANSAS NUCLEAR ONE-UNIT ONE
 SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL


APL-01-014
 January 15, 1983




SECTION B-B




PLAN AT ELEVATION 404'-0"




SECTION D-D




SECTION C-C



SECTION A-A



PLAN AT ELEVATION 352'-0"



SECTION E-E


FIGURE 1
 PLANS AND SECTIONS

SDT Structural
 Dynamics
 Technology, Inc.


ARKANSAS NUCLEAR ONE-UNIT ONE
 SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APL-01-014
 January 15, 1983


ISOMETRIC VIEWS OF SURFACE MEMBRANE ELEMENTS




INSIDE MEMBRANES




MIDDLE MEMBRANES




OUTSIDE MEMBRANES



PLAN AT ELEVATION 404'-0"



PLAN AT ELEVATION 352'-0"



SECTION D-D

FIGURE 2

KEY DIAGRAMS AND DIMENSIONS

SDT Structural Dynamics Technology, Inc.

ARKANSAS NUCLEAR ONE-UNIT ONE
 SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APL-01-014
 January 15, 1983





FIGURE 3

FLOOR ELEMENT AND NODE NUMBERS



ARKANSAS NUCLEAR ONE-UNIT ONE
 SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APL-01-014
 January 15, 1983

CUBE ELEMENTS

81	828	829	830	831	832	833	834	835	836	837	838	839	840
841	842	843	844	845	846	847	848	849	850	851	852	853	854
855	856	857	858	859	860	861	862	863	864	865	866	867	868
869	870	871	872	873	874	875	876	877	878	879	880	881	882
883	884	885	886	887	888	889	890	891	892	893	894	895	896
897	898	899	900	901	902	903	904	905	906	907	908	909	910
911	912	913	914	915	916	917	918	919	920	921	922	923	924
925	926	927	928	929	930	931	932	933	934	935	936	937	938
939	940	941	942	943	944	945	946	947	948	949	950	951	952
953	954	955	956	957	958	959	960	961	962	963	964	965	966
967	968	969	970	971	972	973	974	975	976	977	978	979	980
981	982	983	984	985	986	987	988	989	990	991	992	993	994
995	996	997	998	999	1000	1001	1002	1003	1004	1005	1006	1007	1008

INSIDE LAYER

828	830	832	834	836	838	840	842	844	846	848	850	852	854
856	858	860	862	864	866	868	870	872	874	876	878	880	882
884	886	888	890	892	894	896	898	900	902	904	906	908	910
914	916	918	920	922	924	926	928	930	932	934	936	938	940
944	946	948	950	952	954	956	958	960	962	964	966	968	970
974	976	978	980	982	984	986	988	990	992	994	996	998	1000
1004	1006	1008	1010	1012	1014	1016	1018	1020	1022	1024	1026	1028	1030
1034	1036	1038	1040	1042	1044	1046	1048	1050	1052	1054	1056	1058	1060
1064	1066	1068	1070	1072	1074	1076	1078	1080	1082	1084	1086	1088	1090
1094	1096	1098	1100	1102	1104	1106	1108	1110	1112	1114	1116	1118	1120

OUTSIDE LAYER

SURFACE MEMBRANE ELEMENTS

8128	8129	8130	8131	8132	8133	8134	8135
8136	8137	8138	8139	8140	8141	8142	8143
8144	8145	8146	8147	8148	8149	8150	8151
8152	8153	8154	8155	8156	8157	8158	8159
8160	8161	8162	8163	8164	8165	8166	8167
8168	8169	8170	8171	8172	8173	8174	8175
8176	8177	8178	8179	8180	8181	8182	8183
8184	8185	8186	8187	8188	8189	8190	8191
8192	8193	8194	8195	8196	8197	8198	8199
8200	8201	8202	8203	8204	8205	8206	8207
8208	8209	8210	8211	8212	8213	8214	8215

INSIDE SURFACE


8328	8329	8330	8331	8332	8333	8334	8335
8336	8337	8338	8339	8340	8341	8342	8343
8344	8345	8346	8347	8348	8349	8350	8351
8352	8353	8354	8355	8356	8357	8358	8359
8360	8361	8362	8363	8364	8365	8366	8367
8368	8369	8370	8371	8372	8373	8374	8375
8376	8377	8378	8379	8380	8381	8382	8383
8384	8385	8386	8387	8388	8389	8390	8391
8392	8393	8394	8395	8396	8397	8398	8399
8400	8401	8402	8403	8404	8405	8406	8407
8408	8409	8410	8411	8412	8413	8414	8415

MIDDLE SURFACE

8528	8529	8530	8531	8532	8533	8534	8535
8536	8537	8538	8539	8540	8541	8542	8543
8544	8545	8546	8547	8548	8549	8550	8551
8552	8553	8554	8555	8556	8557	8558	8559
8560	8561	8562	8563	8564	8565	8566	8567
8568	8569	8570	8571	8572	8573	8574	8575
8576	8577	8578	8579	8580	8581	8582	8583
8584	8585	8586	8587	8588	8589	8590	8591
8592	8593	8594	8595	8596	8597	8598	8599
8600	8601	8602	8603	8604	8605	8606	8607
8608	8609	8610	8611	8612	8613	8614	8615

OUTSIDE SURFACE

FIGURE 4
 EAST WALL ELEMENT NUMBERS



ARKANSAS NUCLEAR ONE-UNIT ONE
 SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APL-01-014
 January 15, 1983

2534	2539	2544	2549	2554	2559	2564	2569
2574	2579	2584	2589	2594	2599	2604	2609
2614	2619	2624	2629	2634	2639	2644	2649
2654	2659	2664	2669	2674	2679	2684	2689
2694	2699	2704	2709	2714	2719	2724	2729
2734	2739	2744	2749	2754	2759	2764	2769
2774	2779	2784	2789	2794	2799	2804	2809
2814	2819	2824	2829	2834	2839	2844	2849
2854	2859	2864	2869	2874	2879	2884	2889
2894	2899	2904	2909	2914	2919	2924	2929
2934	2939	2944	2949	2954	2959	2964	2969
2974	2979	2984	2989	2994	2999	3004	3009

INSIDE SURFACE

2534	2539	2544	2549	2554	2559	2564	2569
2574	2579	2584	2589	2594	2599	2604	2609
2614	2619	2624	2629	2634	2639	2644	2649
2654	2659	2664	2669	2674	2679	2684	2689
2694	2699	2704	2709	2714	2719	2724	2729
2734	2739	2744	2749	2754	2759	2764	2769
2774	2779	2784	2789	2794	2799	2804	2809
2814	2819	2824	2829	2834	2839	2844	2849
2854	2859	2864	2869	2874	2879	2884	2889
2894	2899	2904	2909	2914	2919	2924	2929
2934	2939	2944	2949	2954	2959	2964	2969
2974	2979	2984	2989	2994	2999	3004	3009

OUTSIDE SURFACE

2534	2539	2544	2549	2554	2559	2564	2569
2574	2579	2584	2589	2594	2599	2604	2609
2614	2619	2624	2629	2634	2639	2644	2649
2654	2659	2664	2669	2674	2679	2684	2689
2694	2699	2704	2709	2714	2719	2724	2729
2734	2739	2744	2749	2754	2759	2764	2769
2774	2779	2784	2789	2794	2799	2804	2809
2814	2819	2824	2829	2834	2839	2844	2849
2854	2859	2864	2869	2874	2879	2884	2889
2894	2899	2904	2909	2914	2919	2924	2929
2934	2939	2944	2949	2954	2959	2964	2969
2974	2979	2984	2989	2994	2999	3004	3009

MIDDLE SURFACE

FIGURE 5
 EAST WALL NODE NUMBERS



ARKANSAS NUCLEAR ONE-UNIT ONE
SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APL-01-014
January 15, 1983

CUBE ELEMENTS

6209	6208	6207	6206	6205	6204	6203	6202	6201
5104	5108	5107	5106	5105	5104	5103	5102	5101
4109	4108	4107	4106	4105	4104	4103	4102	4101
3109	3108	3107	3106	3105	3104	3103	3102	3101
2109	2108	2107	2106	2105	2104	2103	2102	2101
1109	1108	1107	1106	1105	1104	1103	1102	1101
1209	1208	1207	1206	1205	1204	1203	1202	1201
1309	1308	1307	1306	1305	1304	1303	1302	1301
1409	1408	1407	1406	1405	1404	1403	1402	1401
1509	1508	1507	1506	1505	1504	1503	1502	1501
1609	1608	1607	1606	1605	1604	1603	1602	1601

INSIDE LAYER

6409	6408	6407	6406	6405	6404	6403	6402	6401
5304	5308	5307	5306	5305	5304	5303	5302	5301
4309	4308	4307	4306	4305	4304	4303	4302	4301
3309	3308	3307	3306	3305	3304	3303	3302	3301
2309	2308	2307	2306	2305	2304	2303	2302	2301
1309	1308	1307	1306	1305	1304	1303	1302	1301
1409	1408	1407	1406	1405	1404	1403	1402	1401
1509	1508	1507	1506	1505	1504	1503	1502	1501
1609	1608	1607	1606	1605	1604	1603	1602	1601
1709	1708	1707	1706	1705	1704	1703	1702	1701
1809	1808	1807	1806	1805	1804	1803	1802	1801
1909	1908	1907	1906	1905	1904	1903	1902	1901
2009	2008	2007	2006	2005	2004	2003	2002	2001
2109	2108	2107	2106	2105	2104	2103	2102	2101
2209	2208	2207	2206	2205	2204	2203	2202	2201
2309	2308	2307	2306	2305	2304	2303	2302	2301
2409	2408	2407	2406	2405	2404	2403	2402	2401
2509	2508	2507	2506	2505	2504	2503	2502	2501
2609	2608	2607	2606	2605	2604	2603	2602	2601
2709	2708	2707	2706	2705	2704	2703	2702	2701
2809	2808	2807	2806	2805	2804	2803	2802	2801
2909	2908	2907	2906	2905	2904	2903	2902	2901
3009	3008	3007	3006	3005	3004	3003	3002	3001
3109	3108	3107	3106	3105	3104	3103	3102	3101
3209	3208	3207	3206	3205	3204	3203	3202	3201
3309	3308	3307	3306	3305	3304	3303	3302	3301
3409	3408	3407	3406	3405	3404	3403	3402	3401
3509	3508	3507	3506	3505	3504	3503	3502	3501
3609	3608	3607	3606	3605	3604	3603	3602	3601
3709	3708	3707	3706	3705	3704	3703	3702	3701
3809	3808	3807	3806	3805	3804	3803	3802	3801
3909	3908	3907	3906	3905	3904	3903	3902	3901
4009	4008	4007	4006	4005	4004	4003	4002	4001
4109	4108	4107	4106	4105	4104	4103	4102	4101
4209	4208	4207	4206	4205	4204	4203	4202	4201
4309	4308	4307	4306	4305	4304	4303	4302	4301
4409	4408	4407	4406	4405	4404	4403	4402	4401
4509	4508	4507	4506	4505	4504	4503	4502	4501
4609	4608	4607	4606	4605	4604	4603	4602	4601
4709	4708	4707	4706	4705	4704	4703	4702	4701
4809	4808	4807	4806	4805	4804	4803	4802	4801
4909	4908	4907	4906	4905	4904	4903	4902	4901
5009	5008	5007	5006	5005	5004	5003	5002	5001
5109	5108	5107	5106	5105	5104	5103	5102	5101
5209	5208	5207	5206	5205	5204	5203	5202	5201
5309	5308	5307	5306	5305	5304	5303	5302	5301
5409	5408	5407	5406	5405	5404	5403	5402	5401
5509	5508	5507	5506	5505	5504	5503	5502	5501
5609	5608	5607	5606	5605	5604	5603	5602	5601
5709	5708	5707	5706	5705	5704	5703	5702	5701
5809	5808	5807	5806	5805	5804	5803	5802	5801
5909	5908	5907	5906	5905	5904	5903	5902	5901
6009	6008	6007	6006	6005	6004	6003	6002	6001
6109	6108	6107	6106	6105	6104	6103	6102	6101
6209	6208	6207	6206	6205	6204	6203	6202	6201
6309	6308	6307	6306	6305	6304	6303	6302	6301
6409	6408	6407	6406	6405	6404	6403	6402	6401

OUTSIDE LAYER

SURFACE MEMBRANE ELEMENTS

6108	6107	6106	6105	6104	6103	6102
5808	5807	5806	5805	5804	5803	5802
5508	5507	5506	5505	5504	5503	5502
5208	5207	5206	5205	5204	5203	5202
4908	4907	4906	4905	4904	4903	4902
4608	4607	4606	4605	4604	4603	4602
4308	4307	4306	4305	4304	4303	4302
4008	4007	4006	4005	4004	4003	4002
3708	3707	3706	3705	3704	3703	3702
3408	3407	3406	3405	3404	3403	3402
3108	3107	3106	3105	3104	3103	3102
2808	2807	2806	2805	2804	2803	2802
2508	2507	2506	2505	2504	2503	2502
2208	2207	2206	2205	2204	2203	2202
1908	1907	1906	1905	1904	1903	1902
1608	1607	1606	1605	1604	1603	1602
1308	1307	1306	1305	1304	1303	1302
1008	1007	1006	1005	1004	1003	1002
708	707	706	705	704	703	702
408	407	406	405	404	403	402
108	107	106	105	104	103	102

INSIDE SURFACE

6308	6307	6306	6305	6304	6303	6302
6008	6007	6006	6005	6004	6003	6002
5708	5707	5706	5705	5704	5703	5702
5408	5407	5406	5405	5404	5403	5402
5108	5107	5106	5105	5104	5103	5102
4808	4807	4806	4805	4804	4803	4802
4508	4507	4506	4505	4504	4503	4502
4208	4207	4206	4205	4204	4203	4202
3908	3907	3906	3905	3904	3903	3902
3608	3607	3606	3605	3604	3603	3602
3308	3307	3306	3305	3304	3303	3302
3008	3007	3006	3005	3004	3003	3002
2708	2707	2706	2705	2704	2703	2702
2408	2407	2406	2405	2404	2403	2402
2108	2107	2106	2105	2104	2103	2102
1808	1807	1806	1805	1804	1803	1802
1508	1507	1506	1505	1504	1503	1502
1208	1207	1206	1205	1204	1203	1202
908	907	906	905	904	903	902
608	607	606	605	604	603	602
308	307	306	305	304	303	302
8	7	6	5	4	3	2

MIDDLE SURFACE

6508	6507	6506	6505	6504	6503	6502
6208	6207	6206	6205	6204	6203	6202
5908	5907	5906	5905	5904	5903	5902
5608	5607	5606	5605	5604	5603	5602
5308	5307	5306	5305	5304	5303	5302
5008	5007	5006	5005	5004	5003	5002
4708	4707	4706	4705	4704	4703	4702
4408	4407	4406	4405	4404	4403	4402
4108	4107	4106	4105	4104	4103	4102
3808	3807	3806	3805	3804	3803	3802
3508	3507	3506	3505	3504	3503	3502
3208	3207	3206	3205	3204	3203	3202
2908	2907	2906	2905	2904	2903	2902
2608	2607	2606	2605	2604	2603	2602
2308	2307	2306	2305	2304	2303	2302
2008	2007	2006	2005	2004	2003	2002
1708	1707	1706	1705	1704	1703	1702
1408	1407	1406	1405	1404	1403	1402
1108	1107	1106	1105	1104	1103	1102
808	807	806	805	804	803	802
508	507	506	505	504	503	502
8	7	6	5	4	3	2

OUTSIDE SURFACE

FIGURE 6
WEST WALL ELEMENT NUMBERS

ARKANSAS NUCLEAR ONE-UNIT ONE
SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APL-01-014
January 15, 1983




FIGURE 7

WEST WALL NODE NUMBERS

Structural
Dynamics
Technology, Inc.

ARKANSAS NUCLEAR ONE-UNIT ONE
 SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APL-01-014
 January 15, 1983






FIGURE 8
 POOL WALL ADJOINING THE CASK LAYDOWN AREA ELEMENT AND NODE NUMBERS



ARKANSAS NUCLEAR ONE-UNIT ONE
SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APL-01-014
January 15, 1983



ARKANSAS NUCLEAR ONE-UNIT ONE
SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APL-01-014
January 15, 1983




FIGURE 10
FOUNDATION WALLS ELEMENT NUMBERS

ARKANSAS NUCLEAR ONE-UNIT ONE
 SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APL-01-014
 January 15, 1983





FIGURE 11
 FOUNDATION WALLS NODE NUMBERS

ARKANSAS NUCLEAR ONE-UNIT ONE
 SPENT FUEL STORAGE FACILITY FINITE ELEMENT MODEL

APT-01-014
 January 15, 1983




FIGURE 12

CASK LAYDOWN AREA FLOOR ELEMENT AND NODE NUMBERS

ASDT Structural Dynamics Technology, Inc.

