

**LICENSEE EVENT REPORT**

EXHIBIT A

CONTROL BLOCK:										(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)									
1 0 1 C I A I D C I P I 1 2 0 0 0 - 1 0 0 0 0 0 0 - 1 0 0 3 4 1 1 1 1 4 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 32										5 0 1 L 6 10 15 10 0 0 0 2 1 7 5 7 0 1 5 1 8 8 3 8 0 6 1 7 8 3 9 REPORT SOURCE 50 51 DOCKET NUMBER 55 56 EVENT DATE 74 75 REPORT DATE 80									
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 0 2 Prior to fuel load, the air sample pumps for the Plant Vent Radiation 0 3 Monitors (RM-14A&B) were found in the tripped condition. Technical 0 4 Specification 3.3.3.10 Action Statements were met. A similar event was 0 5 reported in LER 82-002. No radioactive effluents were released and this 0 6 event has in no way affected the public health and safety. Reportable per 0 7 Technical Specification 6.9.1.13.b. 0 8 0 9																			
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE B B 11 X 12 Z 13 I I N S T I R U 14 Z 15 Z 16 8 10 11 12 13 18 19 20 17 LER/RO REPORT NUMBER 21 22 23 24 25 26 27 28 29 30 31 32 8 3 1 0 1 1 2 1 0 3 1 0 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPDN FORM SUB. PRIME COMP SUPPLIER COMPONENT MANUFACTURER E 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 N 25 W 1 1 2 1 0 26 33 34 35 36 37 40 41 42 43 44 47																			
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27 1 0 Rad monitor filter paper was clogged with excessive debris caused by intense 1 1 construction activities in containment, which tripped the sample pumps. The 1 2 filter paper was advanced in each unit, the pumps were restarted and the 1 3 flow rate adjusted to the correct value. No future corrective action is 1 4 required since major construction activity will diminish when fuel is loaded. 1 5 1 6 1 7 1 8 1 9 2 0																			
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION B 28 0 0 0 0 29 NA A 31 Operator observation 7 8 9 10 11 12 13 14 15 16 17 18 19 20 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE Z 33 Z 34 NA NA 7 8 9 10 11 12 13 14 15 16 17 18 19 20 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 0 0 0 0 37 Z 38 NA 7 8 9 10 11 12 13 14 15 16 17 18 19 20 PERSONNEL INJURIES NUMBER DESCRIPTION 0 0 0 0 40 NA 7 8 9 10 11 12 13 14 15 16 17 18 19 20 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION Z 47 NA 7 8 9 10 11 12 13 14 15 16 17 18 19 20 PUBLICITY ISSUED DESCRIPTION N 44 NA 7 8 9 10 11 12 13 14 15 16 17 18 19 20																			
8306280523 830617 PDR ADOCK 05000275 S PDR NAME OF PREPARER William J. Kelly PHONE 805/595-7351																			

# PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER  
MANAGER

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
NUCLEAR POWER GENERATION

June 17, 1983

Mr. John B. Martin, Regional Administrator  
U.S Nuclear Regulatory Commission, Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, CA 94596-5368


Re: Docket No. 50-275, OL-DPR-76  
Diablo Canyon Unit 1  
Licensee Event Report 83-012/03L-0  
Tripping of Radiation Monitor Sample Pumps

Dear Mr. Martin:

Pursuant to Section 6.9.1.13.b of the Technical Specifications, Appendix A to the Diablo Canyon Unit 1 Operating License, the enclosed Licensee Event Report is submitted concerning the tripping of sample pumps for the Plant Vent Radiation Monitors.

This event has in no way affected the public health and safety.

Very truly yours,



Enclosure

cc w/enc: Mr. George Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Director, Office of Management  
Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Service List

IE-22