



SAFEGUARDS INFORMATION
 UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 REGION II
 101 MARIETTA ST., N.W., SUITE 3100
 ATLANTA, GEORGIA 30303
 FEB 9 1983

Report Nos. 50-250/83-02 and 50-251/83-02

Docket Nos. 50-250 and 50-251

Licensee: Florida Power and Light Company
 Miami, Florida 33101

Facility Name: Turkey Point 3 and 4

Inspection at: Homestead, Florida

Inspection conducted: January 16-20, 1983

Date of Last Physical Security Inspection Visit: July 12-16, 1982

Type of Inspection: Unannounced Physical Security

Inspector: D. E. Moore
 D. E. Moore, Physical Security Inspector

2/8/83
 Date Signed

Approved by: D. R. McGuire
 D. R. McGuire, Chief, Physical Security
 Section, Safeguards Branch
 Division of Emergency Preparedness
 and Materials Safety

2/8/83
 Date Signed

Inspection Summary

Areas Inspected: Included review of the Security Plan and Implementing Procedures; Security Organization-Management/Personnel/Response; Security Program Audit; Records and Reports: Testing and Maintenance; Locks and Keys; Physical Barriers-Protected and Vital Areas; Security System Power Supply; Lighting; Assessment Aids; Access Control-Personnel/Packages/Vehicles; Detection Aids-Protected and Vital Areas; Alarm Stations; Communications; Additional Requirements for Power Reactor Personnel; and Safeguards Contingency Plan Implementation Review.

The inspection involved 33 inspector hours on site by one NRC inspector. The inspection was begun during an offshift period; four inspection hours were accomplished during offshift periods.

Results: The licensee was found to be in compliance with NRC requirements within the areas examined during the inspection except for the following item:

Alarm Stations - Failure to provide an audible alarm signal in the alarm stations.

SAFEGUARDS INFORMATION

ENCLOSURE CONTAINS
 SAFEGUARDS INFORMATION.
 UPON SEPARATION THIS
 PAGE IS DECONTROLLED.