

BOSTON EDISON COMPANY
800 BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199

WILLIAM D. HARRINGTON
SENIOR VICE PRESIDENT
NUCLEAR

June 16, 1983

BECo Letter No. 83-154

Regional Administrator
U.S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

License No. DPR-35
Docket No. 50-293

Subject: Status of Four Remaining Modifications for IE Bulletins 79-02 and 79-14

Reference: Boston Edison Company Letter (A.V. Morisi) to NRC (R.C. Haynes), dated July 19, 1982 (BECo Letter #2.82.195)

Dear Sir:

This letter is intended to serve as notification of the completion of all plant modifications associated with IE Bulletins 79-02 and 79-14.

In the above Reference, Boston Edison Company identified the following four minor modifications as not being complete when we submitted the final report on IE Bulletins 79-02 and 79-14.

- (1) H-29-1-95G (79-02 Fix) Salt Service Water System
Fix: Addition of washers to correct oversized bolt holes in base plate
- (2) H-30-1-286 (79-14 Fix) RBCCW System
Fix: Addition of bracing member with base plate
- (3) H-30-1-92 (79-14 Fix) RBCCW and TBCCW Systems
Fix: Increase weld sizes and add a bracing member
- (4) H-30-1-376 (79-14 Fix) RBCCW System
Fix: Increase weld sizes

These modifications were minor in nature and neither system operability nor plant safety was affected.

Proposed modifications (2), (3) and (4), as listed above, were completed in May, 1983. Proposed modification (1) was not implemented. A structural reanalysis performed in April, 1983, justified the structural acceptability of this support in its present condition.

8307010082 830616
PDR ADOCK 03000293
PDR
G

IEI
1/0

BOSTON EDISON COMPANY

Mr. Tom Murley, Regional Administrator
Page 2

These modifications and the one reanalysis were performed in conformance with the requirements of NRC IE Bulletins 79-02 and 79-14. As such, Boston Edison's FINAL REPORT to IE Bulletins 79-02 and 79-14 is now inclusive of all seismic Category 1 supports at Pilgrim Station.

Should you require further information on this issue, please contact us.

Very truly yours,

WD Harrington