

GPV 39

8307120320 790830
PDR ADOCK 05000289
P HOL

W. BRADY & WILCOX CONSULTING ENGINEERS
POWER GENERATION GROUP

ACTION

To:	R.B. LONER - MANAGER, CUSTOMER SERVICE DEPARTMENT	File No. or Ref.
From:	T.A. WYNNE - WOLACT'S, PLANT ENGINE (INT. 2315)	CSR 0002
Subj.:	RECOMMENDATION FOR "QUICK LOOK" EVALUATION OF ALL 220 MW UNITS	Date AUGUST 20, 1979

Summary

This memo describes a program to evaluate the performance of the CSW 220 during reactor trips at all operating plants. This analysis will produce a "quick look" report which describes the cause of the upset, the overall plant response, and recommends corrective action or further analysis to prevent recurrence. Plant design recommends that this program be initiated immediately and be funded by the unit such a program is sold to the 1st Owners Group.

Introduction

One of the most important lessons learned from the TMI-1 incident and its aftermath is that P&H must be more aware of the operating characteristics and problems of the CSW. The evaluation of the CSW and performance during transient and steady state conditions can lead to several advantages for both CSW and the customer.

- (1) Plant availability can be improved if lessons learned from problems at one site are applied to other sites.
- (2) Potential safety problems can be pinpointed and corrected before serious incidents occur.
- (3) A data base of operating histories and problems can provide important information for answering CSW concerns and for performance improvements.

This memo describes an expanded program for engineering evaluation of all reactor trips at CSW operating plants. This is a necessary first step to achieve the above benefits, and should be undertaken without delay.

Program Description

CSW is presently preparing a program for "Utilization of Operating Plant Data" for reactor trips at all customers around September 1, 1979. This program will cover, essentially all reactor trips, major shutdowns, major equipment failures, and periodic steady state problems. A report called the "quick look" report will be prepared. The customer will be given a week of receipt of all data specifying the abnormal conditions from operating plant performance which occurred during the upset, and recommending follow-up action.

600
Exh. For ID 39
1/3/78
CSR 1/3/78

AUGUST 20, 1979

Plant Design recommends that independent of the rejection or acceptance of this program, BSN initiate a similar program immediately. This program will prepare a "quick look" report for each reactor trip at a BSN plant. This report will directly support the Division's Site Problem Experts resolution program. Table 1 shows the type of analysis and the content of this report. Attachment 1 presents a sample Quick Look report for a reactor turbine trip at MW-11 on March 9, 1979.

Tasks

There are seven tasks to be performed. It is proposed that these tasks be implemented as shown in Table 2 and discussed below.

1. Notification of Reactor Trip

The resident engineer will be responsible for notifying the Plant Performance Section (D.F. Hollman) that a reactor trip has occurred. This should be done within 24 hours after the trip.

2. Collection of Trip Data

The proper analysis of any reactor transient requires an accurate and comprehensive set of data. The Plant Performance Services (PPS) section and resident engineer will be responsible for collecting at least the data shown in Table 3. This data should be collected and transmitted to NPSD within 24 hours of the reactor trip.

3. Preparation of Event Sequence

Using the data in Task 2, PPS will prepare an event synopsis for the reactor trip. In addition, a list of initial conditions and plots of important parameters should be made. (See Attachment 1.) Support and guidance will be given by the Power System and Controls Unit (PSCU), if required. The event synopsis, list of initial conditions, plots, and all data collected on site (Table 3) should be transmitted to PSCU (J.D. Carlton) and Training (N.B. Elliott) within one working day of receipt of all data.

4. Review Operating Performance

PPS and Training should review the data presented in Task 3 and prepare comments for transmission to PSCU. These comments should include their opinion on the following:

- (a) What unexpected plant behavior was noted?
- (b) Were operator actions timely and appropriate and in accord with existing procedures?
- (c) In what availability category will the next time be categorized?

These comments should be transmitted to PSCU within one working day of completion of Task 3. (This task should be performed concurrently with Task 3.)

5. Evaluate Performance and Classify Transactions

PMAC will evaluate the timing of unexpected plant behavior on the event, as defined in Task 3, including the installation event. The emphasis here should be on how to prevent recurrence and improve plant performance during the trip. PMAC will obtain the assistance of other units in this evaluation for problems affecting their area of responsibility. This task should be complete within one working day of completion of Task 3. (Concurrent with Task 4)

6. Prepare and Issue Quick Look Report

PMAC will prepare and issue a "Quick Look" report summarizing the results of Task 1 through 5. The format should be similar to that in Attachment 1.

This report should be issued within one day of completion of Task 5. The issuance will include a review and signature by the PMAC Unit Manager.

7. Review and Final Release

Managers of the following units or their delegates should review and sign the Quick Look Report, indicating their agreement with the conclusions.

(a) Plant Performance Section (D.F. Mallum)

(b) Training (N.S. Elliott)

PMAC will be responsible to obtain these reviews and approvals to complete the report. PPS will be responsible for maintaining, disseminating, and storing the Quick Look Reports.

Action Requested

1. Work Plan and Responsibilities: The proposed responsibility for the performance of this task, as stated above, have resulted from discussions which have included Messrs. Han and Mallum of Customer Service. Your concurrence with this working arrangement is requested.
2. Relocation of Data: Under the proposed task responsibilities, the Customer Service PPS unit assumed responsibility for obtaining complete data (initial specification in Table 3) to support these arrangements. We encourage and recommend the initiation of this process through the use of the MCALL system as quickly as possible. We will look to Customer Service to pursue aggressively the MCALL system implementation, meanwhile providing data "manually".
3. Funding: Funding estimates are shown in Tables 4 and 5. In order to begin this work within July, engineering will authorize limited funding for cost center 41 from 5 with engineering resources. We request that Customer Service submit a memo for the funds for its affected cost centers. RA's are obligated for this purpose.

S.E. Boston

- 4 -

APR 17 1979

In accord with discussions with S.E. Mac, I understand that he will be seeking Owners Group financial support for this program and will provide resources from that source as soon as authorization is received.

SAM/dsh

cc: J.D. Cotton
E.E. Elliott
S.F. Hallinan
E.E. Han
E.E. Lane
S.A. Karsvack
F.J. Lovinski
S.M. Roy
J.H. Taylor
E.E. Elliott
J.J. Kelly
F.S. Pablow
E.E. Weach

Allen Weach

TABLE 1

Initial Analysis/Check List Items

- An evaluation of the system response on the basis of expected response.
- Identification of unexpected performance and the cause or suspected cause, and suggested remedies.
- A preliminary evaluation of availability degradation and suggested improvements.
- A preliminary evaluation of safety implications, particularly as related to challenges to the safety system.
- An evaluation of the event as related to its allowable operating transient state classification and the margin to next classification (planned unless data).
- Comparison to Abnormal Transient Operating Conditions (if available) and identification of need for correction or actions.
- Identification of changes or additions needed to training program.

FORM 1
PLAN FOR TRIP LOCK ANALYSIS




TABLE 3

DATA REQUIREMENTS FOR "SWITCH LOG" REVIEW

• Initial Plant Conditions

• Key Parameters

- Average Temperature
- Hot Leg Temperature
- Cold Leg Temperature
- Reactor Power
- Pressure
- Moderator Level
- Steam Pressure
- STMS Level (Startup or Control Level as appropriate)

• Equipment Configuration

- Any equipment out of service
- Standby/Hot Stations in normal
- Special operating conditions (e.g. temporary constraints)

• Transient Plant Conditions

• Key Parameters

- Hot Leg Temperature
- Cold Leg Temperature, Flow Range
- Reactor Power
- Pressure, Steam Range unless flow range is required to span the extremes of the transient
- Moderator Level
- Steam Pressure, STMS Level
- STMS Level, Startup Range unless flow range is required to span the extremes of the transient
- Moderator Flow Rate
- Emergency Moderator Flow Rate
- No Primary System Injection and indicate Flow Status

• Sources of Events

• Key Operator Actions

Tables 3 and 4 also should be provided whenever such data exists for these parameters.

TABLE 6

Qualifying Research Requirements for Trips

<u>Trip Number</u>	<u>Task</u>	<u>Estimated Cost (Hours)</u>
1	Specification of Research Trip	1/8
2	Collection of Trip Data	8/8
3	Preparation of Event Sequence	8/8
4	Review of Operating Performance	8/8
5	Evaluate Performance and Classify Transient	12/8
6	Prepare & Issue Office Leak Report	8/8
7	Review and Final Report	12/8

TABLE 8

Preliminary Resource Requirements Per Cost Center


<u>Class or Individual</u>	<u>Cost Center</u>	<u>Manpower/CC Hours Per Year</u>	<u>Manpower/CC Staff</u>
Plant Performance Section	205	16/0	11/0
Power System & Controls	203	16/0	11/0
Reactors Engineer	126	7/0	10/0
Service Manager	125	4/0	0/0
Training	200	5/0	10/0
Other	207	4/0	0/0
Total		52/0	42/0

***Please Note:**

- (a) Estimates have not been approved by the participating sections and should be considered preliminary until such approval is given.
- (b) The number estimate assumes 25 total trips for September through December 31, 1979 (3 trips/plant x 7 plants).

*These hours are allocated to PSC (CCCS). However, they will be used by CCRP units in support of PSC.

Figure 1 SCHEDULE FOR "WITCH LOOP" REVIEW OF REACTOR TRIPS



analysis for this type of B&W plant is reported in BAW-10052² and BAW-10064³. A discussion of the applicability of this work under the guideline of the new rule presented in BAW-10104, Appendix A.

6.2. Break Location Study

To determine the worst-break location, calculations are performed for an 8.55-ft² double-ended break with $C_D = 1.0$ at the pump discharge and the pump suction, and a 14.14-ft² double-ended hot leg break with $C_D = 1.0$. The double-ended (DE) break ($C_D = 1.0$) was chosen over a split break because it has previously been shown to be the worst type of cold leg break for Category 1 plants. The hot leg break, though normally very low in temperature, is analyzed for completeness. The location of the hot leg break negates the potential for ECCS bypass, and breaks in the hot leg piping have historically been less severe.

6.2.1. 8.55-ft² DE Break at Pump Discharge, $C_D = 1.0$

The 8.55-ft² DE break is the largest possible break in the cold leg pump discharge piping. Its simulation depicts a complete severance of the pipe with enough lateral movement to prevent the interaction of fluid discharge from either side of the break. A C_D of 1.0 was assumed for this break. The resulting system pressure transient for this break is shown in Figure 6-1, with the end of blowdown occurring at 24.4 seconds. The rapid blowdown creates an early negative hot spot core flow, as shown in Figure 6-2, which recovers by 0.6 second. Core flow starts to decrease at about 5.0 seconds and finally becomes negative at 14.0 seconds. This decrease in core flow is caused by the loss of head across the pumps in the unbroken loops due to two-phase flow effects. Figure 6-12 shows the core power transient for this break.

The reflooding rate from the REFLOOD code is shown in Figure 6-3. At the end of blowdown, 1532.0 lbm of water is left in the reactor vessel. This quantity of liquid is not sufficient to fill the lower plenum, resulting in a refill period of 11.0 seconds before flooding starts. The carryout rate fraction was calculated utilizing the CRF3 correlation.

The hot pin cladding temperature response is calculated using the THETA code. The hot pin is modeled as a 2.0-ft section. Figure