

*Southern California Edison Company*

23 PARKER STREET  
IRVINE, CALIFORNIA 92718

RICHARD M. ROSENBLUM  
VICE PRESIDENT

August 26, 1994

TELEPHONE  
714-458-4550

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362  
Proposed Technical Specification Change No. NPF-10/15-439  
Control Room Emergency Air Cleanup System  
San Onofre Nuclear Generating Station  
Units 2 and 3

Provided as Enclosure (1) to this letter are Amendment Application Numbers 144 and 128 to Facility Operating License Numbers NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively. The Amendment Applications are comprised of Proposed Technical Specification Change NPF-10/15-439 (PCN-439). PCN-439 is a request to revise "Control Room Emergency Air Cleanup System," Technical Specification (TS) 3/4.7.5.

The proposed revision to TS 3/4.7.5 will provide an LCO 3.0.4 exception for MODES 5, 6, or a defueled configuration. The following APPLICABILITY statement "or during movement of irradiated fuel assemblies" will be added also. The ACTION statement "Units 2 and 3 in MODE 5 or 6" will be changed to "Units 2 and 3 in MODE 5 or 6, or defueled configuration when moving irradiated fuel assemblies." The words "or movement of irradiated fuel assemblies" will be added in ACTION b) after the words "suspend all operations involving CORE ALTERATIONS or positive reactivity changes."

Enclosure 2 contains proposed LCO 3.7.11, "Control Room Emergency Air Cleanup System (CREACUS)," which was submitted under PCN-299. Enclosure 3 identifies changes to TS 3/4.7.5 proposed by PCN-439 as well as changes proposed by PCN-407. Enclosures 2 and 3 are provided for information only.

Your approval of these amendment applications is requested by January 31, 1995, to support the Unit 2 Cycle 8 refueling outage which is scheduled to begin in February 1995.

9409010283 940826  
PDR ADOCK 05000361  
P PDR


ADD3

Document Control Desk

-2-

Should you have any questions regarding this request, please do not hesitate to call me.

Sincerely,



Enclosures

cc: L. J. Callan, Regional Administrator, NRC Region IV  
K. E. Perkins, Jr., Director, Walnut Creek Field Office, NRC Region IV  
J. A. Sloan, NRC Senior Resident Inspector, San Onofre Units 2 & 3  
M. B. Fields, NRC Project Manager, San Onofre Units 2 and 3