

NOTICE OF VIOLATION

Namco Controls Corporation
Mentor, Ohio

Docket No.: 99900378/94-01

During an NRC inspection conducted at Namco Controls Corporation (Namco) facilities on July 25 through 29 and August 1 through 3, 1994, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1994), the violation is listed below:

Section 21.21, "Notification of Failure to Comply or Existence of a Defect and Its Evaluation," of 10 CFR requires, in part, that each corporation subject to the regulations adopt appropriate procedures to evaluate deviations and failures to comply. In addition, Section 21.6, "Posting Requirements," of 10 CFR requires, in part, that each corporation subject to the regulations post a current copy of 10 CFR Part 21.

Contrary to the above requirements, Namco had not revised its procedures to address the substantive revisions to 10 CFR Part 21 since 1987, and had not posted a current copy of 10 CFR Part 21.

This is a Severity Level V violation (Supplement VII).
(99900378/94-01-01)

Pursuant to the provisions of 10 CFR 2.201, Namco Controls Corporation is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Chief, Vendor Inspection Branch, Division of Reactor Inspection and Licensee Performance, Office of Nuclear Reactor Regulation, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

Dated at Rockville, Maryland
this _____ day of _____, 1994

9409140033 940908
PDR GA999 EMVNAMCO
99900378 PDR