



June 30, 1976

L-76-244

Director of Nuclear Reactor Regulation
Attn: Mr. Victor Stello, Jr., Director
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555



Dear Mr. Stello:

TURKEY POINT UNIT 4
DOCKET NO. 50-251
INSPECTION OF SAFETY RELATED
HYDRAULIC PIPE RESTRAINTS

The subject inspection was completed on April 21, 1976 in accordance with the continuing requirements of the Directorate of Licensing letter dated November 8, 1973.

All safety related hydraulic pipe restraints located outside containment were in satisfactory condition.

Very truly yours,

A handwritten signature in cursive script, reading "Robert E. Uhrig".

ROBERT E. UHRIG
Vice President

REU/MAS/ao

cc: Mr. Norman C. Moseley
Jack R. Newman, Esquire

8304070190 760812
PDR ADOCK 05000250
PDR

COPY SENT REGION

601