

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | FIL | S | L | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

7 3 | 3 | 14 | 15 | 25 | 26 | 30 | 37 | 38

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

0 1 | L | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 5 | 7 | 0 | 3 | 0 | 1 | 8 | 3 | 8 | 0 | 3 | 3 | 1 | 8 | 3 | 9

7 3 | 30 | 31 | 38 | 39 | 49 | 74 | 75 | 80

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During cold shutdown with the loops filled and prior to refueling, the

0 3 | "A" steam generator was drained so that work could be performed. Subsequent

0 4 | to that, the "B" Low Pressure Safety Injection (LPSI) pump was placed out

0 5 | of service. This resulted in the plant having less than the minimal re-

0 6 | quired equipment. Action was taken in accordance with T.S. 3.4.1.4.1. At

0 7 | no time was the health and safety of the public in jeopardy. This is the

0 8 | first event of this type.

0 9 | SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE

7 3 | 9 | 10 | 11 | 12 | 13 | 18 | 19 | 20

C F A A P U M P X X B Z

17 | LER/RO REPORT NUMBER | 8 | 3 | SEQUENTIAL REPORT NO. | 0 | 1 | 2 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | L | REVISION NO. | 0 |

21 | 22 | 23 | 24 | 26 | 27 | 28 | 29 | 30 | 31 | 32

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPD- FORM SUB | PRIME COMP SUPPLIER | COMPONENT MANUFACTURER

H Z Z Z 0 0 0 0 N N N 1 0 7 5

33 | 34 | 35 | 36 | 37 | 40 | 41 | 42 | 43 | 44 | 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event was caused by operator unfamiliarity with a new Tech Spec re-

1 1 | quiring two steam generators and one shutdown cooling loop. The "B" LPSI

1 2 | pump was out of service approximately two hours when the error was discov-

1 3 | ered. The LPSI pump was immediately placed back in service. The operators

1 4 | were counselled as to the importance of the minimum equipment list.

1 5 | FACILITY STATUS | H | % POWER | 0 | 0 | 0 | OTHER STATUS | NA | METHOD OF DISCOVERY | A | DISCOVERY DESCRIPTION | Operator observation

7 3 | 8 | 9 | 10 | 12 | 13 | 30 | 44 | 45 | 46 | 80

1 6 | ACTIVITY CONTENT | Z | Z | AMOUNT OF ACTIVITY | NA | LOCATION OF RELEASE | NA

7 3 | 9 | 10 | 11 | 44 | 45 | 80

1 7 | PERSONNEL EXPOSURES | 0 | 0 | 0 | Z | DESCRIPTION | NA

7 3 | 9 | 11 | 12 | 13 | 39 | 80

1 8 | PERSONNEL INJURIES | 0 | 0 | 0 | DESCRIPTION | NA

7 3 | 9 | 11 | 12 | 41 | 80

1 9 | LOSS OF OR DAMAGE TO FACILITY | Z | DESCRIPTION | NA

7 3 | 9 | 11 | 12 | 43 | 80

2 0 | PUBLICITY ISSUED | N | DESCRIPTION | NA

7 3 | 9 | 10 | 45 | 80

NAME OF PREPARER: Joseph P. Brannin PHONE: (305) 465-3550 X3427