

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
1750 Chestnut Street Tower II
NRC REGION 1
ATLANTA, GEORGIA

March 31, 1983

83 APR 4 AIO: 43

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 2 - DOCKET
NO. 50-328 - FACILITY OPERATING LICENSE DPR-79 - REPORTABLE OCCURRENCE
REPORT SQRO-50-328/83028

The enclosed report provides details concerning the hydrogen recombiner
being inoperable due to a bad kilowatt meter. This report is submitted
in accordance with Sequoyah unit 2 Technical Specification 6.9.1.13.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



H. J. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

NRC Inspector, Sequoyah

8304070238 830331
PDR ADOCK 05000328
S PDR

OFFICIAL COPY

IE 22

1983-TVA 50TH ANNIVERSARY

An Equal Opportunity Employer