# LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | TNSNP1 (2) | 00-00000-00 (3) | 4111 (4) | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T
01 | REPORT SOURCE: L (6) | 05000327 (7) DOCKET NUMBER | 030283 (8) EVENT DATE | 030384 (9) REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Unit 1 in mode 1 at 100% power. The "B" train auxiliary building gas treatment
03 | system (ABGTS) was declared inoperable at 1640 hours due to failure of the charcoal
04 | test canister to meet the acceptance criteria of 99% methyl iodine removal
05 | efficiency per surveillance instruction (SI) 141 testing. This event required entry
06 | into LCO 3.7.8. There was no effect upon public health or safety. Previous
07 | occurrences - two (SQRO-50-327/81071 and 81083)
08 |

09 | SYSTEM CODE: AA (11) | CAUSE CODE: X (12) | CAUSE SUBCODE: Z (13) | COMPONENT CODE: XXXXXX (14) | COMP. SUBCODE: Z (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 83 | — | SEQUENTIAL REPORT NO. 036 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN: A (18) | FUTURE ACTION: Z (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0000 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: L (25) | COMPONENT MANUFACTURER: X999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The probable cause has been attributed to the exposure of the charcoal to normal
11 | pollutants in flowing air and the charcoal's age. The charcoal was replaced and the
12 | "B" train of the ABGTS was satisfactorily tested and returned to service on 03/04/83
13 | at 1545 hours. No further action is required.
14 |

15 | FACILITY STATUS: E (28) | % POWER: 100 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: B (31) | DISCOVERY DESCRIPTION (32): Surveillance test

16 | ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

17 | PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

18 | PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41): NA

19 | LOSS OF OR DAMAGE TO FACILITY: TYPE Z (42) | DESCRIPTION: NA

8304070343 830331
PDR ADOCK 05000327
S PDR

20 | PUBLICITY: ISSUED N (44) | DESCRIPTION (45): NA

NRC USE ONLY

Name of Preparer: A. M. Carver /M. R. Harding Phone: (615) 870-6422