LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 — LICENSEE CODE: T N S N P 1 (2) — LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) — LICENSE TYPE: 4 1 1 1 1 (4) — CAT: (5)

CON'T 01 — REPORT SOURCE: L (6) — DOCKET NUMBER: 0 5 0 0 0 3 2 7 (7) — EVENT DATE: 0 3 0 4 8 3 (8) — REPORT DATE: 0 3 3 1 8 3 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With unit 1 in mode 1 (100% Rx power) at 1630 CST on 03/04/83, one feedwater flow
03 channel was declared inoperable due to failing low. This required entry into
04 action statement 7 of LCO 3.3.1.1. There was no effect upon public health and
05 safety. Previous occurrences - two (SQRO-50-327/80057, 81001).
06
07
08

09 SYSTEM CODE	I A (11)
CAUSE CODE	A (12)
CAUSE SUBCODE	C (13)
COMPONENT CODE	Z Z Z Z Z Z (14)
COMP. SUBCODE	Z (15)
VALVE SUBCODE	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 3	—	0 3 5	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 During the installation of test equipment on 1-FT-3-48A, a permanent compression fitting
11 test valve blew off causing the channel to indicate low. The incident was caused by
12 personnel error in that the ferrule was improperly installed during original install-
13 ation of the valve. The valve was replaced using a new ferrule and nut and proper
14 installation verified at 1801 CST on 03/04/83. A memo and sketch showing proper install
ation of an Imperial Eastman ferrule has been routed to appropriate personnel.

15 FACILITY STATUS	E (28)
% POWER	1 0 0 (29)
OTHER STATUS (30)	NA
METHOD OF DISCOVERY	B (31)
DISCOVERY DESCRIPTION (32)	Operator observation
16 ACTIVITY RELEASED	Z (33)
CONTENT OF RELEASE	Z (34)
AMOUNT OF ACTIVITY (35)	NA
LOCATION OF RELEASE (36)	NA
17 PERSONNEL EXPOSURES NUMBER	0 0 0 (37)
TYPE	Z (38)
DESCRIPTION (39)	NA
18 PERSONNEL INJURIES NUMBER	0 0 0 (40)
DESCRIPTION (41)	NA
19 LOSS OF OR DAMAGE TO FACILITY (43) TYPE	Z (42)
DESCRIPTION	NA
20 PUBLICITY ISSUED	N (44)
DESCRIPTION (45)	NA
NRC USE ONLY	

8304070409 830331
PDR ADOCK 05000327
S PDR

Name of Preparer: H. R. Rogers /M. R. Harding Phone: (615) 870-6422