

CRISIS MANAGEMENT PLAN

IMPLEMENTING PROCEDURE

EDA - 2

"Off-Site Dose Projections for
Catawba Nuclear Station"

R. E. Harris

Approved By

4/4/91

Date

Rev. 6
April 1, 1991

DUKE POWER COMPANY
OFF-SITE DOSE PROJECTIONS FOR
CATAWBA NUCLEAR STATION

1.0 PURPOSE

To describe a method for projecting dose commitment from a noble gas and/or iodine release, through the containment, the unit vent and/or the steam relief valves, during an emergency.

2.0 REFERENCES

- 2.1 HP/O/B/1000/10, Determination of Radiation Monitor Setpoints
- 2.2 HP/O/B/1009/06, Alternative Method for Determining Dose Rate Within the Reactor Building
- 2.3 HP/O/B/1009/14, Radiation Protection Actions Following an Uncontrolled Release of Liquid Radioactive Material
- 2.4 HP/O/B/1009/17, Unit 1 Post-Accident Containment Air Sampling System
- 2.5 HP/O/B/1009/21, Abnormal Unit Vent Sampling
- 2.6 CNS Technical Specification 3.6.1.2
- 2.7 Offsite Dose Calculation Manual (ODCM)
- 2.8 Regulatory Guide 1.4, "Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss of Coolant Accident for Pressurized Water Reactors"
- 2.9 Regulatory Guide 1.109, "Calculations of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10CFR Part 50, Appendix I"
- 2.10 NuReg-0396, EPA 520/1-78-016, "Planning Basis for the Development of State and Local Government Radiological Emergency Response Plans in Support of Light Water Nuclear Power Plants"
- 2.11 NuReg-0654, FEMA-REP-1, Rev. 1, "Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants"
- 2.12 Letter from F. G. Hudson, September 30, 1985, re: Release Rate Information for McGuire and Catawba Nuclear Station (File: CN-134.10)
- 2.13 Catawba Nuclear Station Class A Computer Model Validation (File: NUC-0306)
- 2.14 Letter from J. E. Thomas, May 19, 1987, File: CN-1346.05 and personal conversation with Frank Poley
- 2.15 Radioiodine and Particle Transmission Through Plant Vent Sampling Lines at Catawba Nuclear Station, prepared by SAIC, dated July 1989.

- 2.16 Letter from C.D. Ingram, June 7, 1989, re: Guidance for Off-site Protective Actions Containment Design Leak Rate Validation. File No.: CN-134.10

3.0 LIMITS AND PRECAUTIONS

- 3.1 This procedure is an alternative method of dose assessment to the Catawba Class A Atmospheric Dispersion Model computer code.
- 3.2 This procedure applies to releases made from Catawba Nuclear Station only. Many of the values contained in this procedure are site specific.
- 3.3 It is assumed that the whole body dose from an iodine release is very small compared to the thyroid dose; therefore, iodine whole body dose is not considered here.
- 3.4 This procedure considers all releases to be ground level releases and that meteorological data are 15 minute averages.
- 3.5 Once a zone has been added to the list of affected zones, it shall not be removed except under the direction of the Dose Assessment Coordinator.
- 3.6 Once the Crisis Management Center (CMC) has been activated, the doses calculated by the Technical Support Center (TSC) dose assessment group, should be compared with those calculated by the CMC before an evacuation recommendation is made.

4.0 PROCEDURE

4.1 Meteorology Assessment

- 4.1.1 Acquire the following information and record on the Dose Assessment Worksheet (Enclosure 5.1):
- 4.1.1.1 Lower tower wind speed (WS) in miles per hour.
- 4.1.1.1.1 Use upper tower wind speed if lower tower wind speed is not available.
- 4.1.1.2 Upper tower wind direction in degrees from North (North = 0).
- 4.1.1.2.1 Use lower tower wind direction if upper tower wind direction is not available.

4.1.1.2.2 If the wind speed or wind direction cannot be obtained from plant systems, obtain them from the National Weather Service (phone 704-359-8466). If the NWS information is unavailable, then obtain data from McGuire Nuclear Station Control Room (73 or 78, then 875, then ext. 4262, or 4263, or 4264).

4.1.1.3 Temperature gradient (ΔT) in degrees centigrade.

4.1.1.4 Using Enclosure 5.2, record the stability class based on ΔT .

4.1.1.4.1 If the temperature gradient is unknown, the following applies:

If between 1000 - 1600 hours, use stability class D;

If between 1600 - 1000 hours, use stability class G.

4.1.1.5 If necessary, use forecasted meteorological data for calculating doses due to changing meteorological conditions.

4.1.2 Determine the atmospheric dispersion parameter, $\overline{X/Q}$ (sec/m^3), for .5, 2, 5 and 10 miles (record on Enclosure 5.1, page 2):

4.1.2.1 Use ΔT , determine the two hour relative concentration value (C_H) from Enclosure 5.2.

4.1.2.2 Convert the C_H values to $\overline{X/Q}$:

$$\overline{X/Q} = \frac{C_H}{WS}$$

4.2 Source Term Assessment - Steam Relief Valve (Enclosure 5.4)

4.2.1 Determine the Sub-Noble Gas Release Rates, SQ_{NG} (Ci/sec), by the following method:

- 4.2.1.1 For Unit 1-EMF26, EMF27, EMF28 and EMF29 or for Unit 2-EMF10, EMF11, EMF12, EMF13:

$$SQ_{NG} = R/hr \times \frac{1}{VOPEN} \times LBM \times CF \frac{C_1}{lbm R/hr}$$

where:

R/hr = EMF26, EMF27, EMF28, EMF29, EMF10, EMF11, EMF12, EMF13 reading
 VOPEN = time the valve is open in seconds
 LBM = lbm released for the time the valve was open
 CF = correction factor per Enclosure 5.5

- 4.2.2 Determine the Noble Gas Release Rate, Q_{NG} (Ci/sec):

$$Q_{NG} = SQ_{NG}(EMF26) + SQ_{NG}(EMF27) + SQ_{NG}(EMF28) + SQ_{NG}(EMF29)$$

- 4.2.3 Determine the Iodine release rate, Q_I (Ci/sec):

$$Q_I = Q_{NG} \times Irat$$

where:

Irat = ratio of I131 eqv./Xe133 eqv. from Enclosure 5.6.

- 4.2.4 Record Q_{NG} and Q_I on Enclosure 5.1, page 2.

4.3 Source Term Assessment - Containment (Enclosure 5.7)

- 4.3.1 Determine the Noble Gas Release Rate, Q_{NG} (Ci/sec) based on one of the following methods:

- 4.3.1.1 Based on an EMF reading, where;

$$Q_{NG} = EMF \times CF \times LR$$

where;

EMF = 39(L), if EMF39(L) < 1E7 cpm and flowpath not isolated,
 EMF = 39(H), if EMF39(L) is offscale and EMF39(H) > 100 cpm and flowpath not isolated,
 EMF = 53A or 53B, if EMF39(H) is offscale. Use survey meter reading (Reference 2.2) if 53A and 53B are not available.

CF = correction factor per Enclosure 5.8.

LR = Leak Rate x BYPASS,
Leak Rate, (ml/hr), by one
of the following methods:

based on containment pressure:
LR = RLR (from Enclosure 5.9)

based on an opening in containment:
LR = OIC (from Enclosure 5.10)

based on design leak rate:
LR = 4.18E6 (Reference 2.16)

BYPASS = Bypass leakage, default is 7%
or 0.07 (Reference 2.6)

4.3.1.2 Based on PACS sample, where;

$$Q_{NG} = PACS \times CF \times LR$$

where;

PACS = $\mu\text{Ci/ml}$ (Reference 2.4)

$$CF = 2.78E-10 \frac{\text{Ci hr}}{\text{sec } \mu\text{Ci}}$$

LR = Leak rate, as determined in Step 4.3.1.1
above

4.3.2 Determine the Iodine Release Rate, Q_I (Ci/sec) based on one
of the following methods:

4.3.2.1 Based on Q_{NG} ;

$$Q_I = Q_{NG} \times \text{Irat}$$

where:

Q_{NG} = Noble Gas Release Rate as determined
in Step 4.3.1 above

Irat = ratio of I131 eqv./Xe 133 eqv. from
Enclosure 5.6.

4.3.2.2 Based on EMF 40 (if flowpath is not isolated);

$$Q_I = \frac{\Delta\text{CPM}}{\Delta\text{min}} \times 9.82E-20 \frac{\text{Ci hr min}}{\text{sec ml cpm}} \times LR$$

where:

ΔCPM = reading from EMF40 Delta Counts
 Δmin = the time interval for EMF40
observation (normally 15 minutes)

$$9.82\text{E-}20 = 4.0\text{E-}5 \mu\text{Ci}/\text{cpm} \times .25 \text{ min}/\text{ft}^3 \\ (\text{inverse of EMF flow rate}) \times \\ 3.53\text{-}5 \text{ ft}^3/\text{ml} \times 1\text{Ci}/1\text{E}6 \mu\text{Ci} \times \\ 1 \text{ hr}/3600 \text{ sec.}$$

$4.0\text{E-}5$ = correlation factor for EMF40 from
Reference 2.1.

LR = Leak rate, as determined in Step
4.3.1.1 above

4.3.2.3 Based on PACS sample;

$$Q_I = \text{PACS} \times \text{CF} \times \text{LR}$$

where;

PACS = ($\mu\text{Ci}/\text{ml}$) (Reference 2.4)

$$\text{CF} = 2.78\text{E-}10 \frac{\text{Ci hr}}{\text{sec } \mu\text{Ci}}$$

LR = Leak rate as determined in Step
4.3.1.1 above

4.3.3 Record Q_{NG} and Q_I on Enclosure 5.1, page 2.

4.4 Source Term Assessment - Unit Vent (Enclosure 5.11)

4.4.1 Determine the Noble Gas Release Rate, Q_{NG} (Ci/sec) based on
one of the following methods:

4.4.1.1 Based on as EMF reading, where;

$$Q_{\text{NG}} = \text{EMF} \times \text{CF} \times \text{CFM}$$

where:

EMF = 36(L) if EMF36(L) < 1E7 cpm,
EMF = 36(H) if EMF36(L) is offscale and
EMF36(H) > 100 cpm and compressor not
tripped,

EMF = 54 if EMF36(H) is offscale or
compressor tripped.

CF = correction factor per Enclosure 5.12

CFM = unit vent flow rate (ft^3/min)

4.4.1.2 Based on unit vent sample, where;

$$Q_{NG} = \text{Unit Vent Sample} \times CF \times CFM$$

where:

Unit Vent Sample = ($\mu\text{Ci/ml}$) per Reference 2.5

$$CF = 4.72E-4 \frac{\text{Ci min ml}}{\text{sec ft}^3 \mu\text{Ci}}$$

CFM = unit vent flow rate (ft^3/min)

4.4.2 Determine the Iodine Release Rate, Q_I (Ci/sec), based on one of the following methods:

4.4.2.1 Based on Q_{NG} ;

$$Q_I = Q_{NG} \times \text{Irat}$$

where:

Q_{NG} = Noble Gas Release Rate as determined in Step 4.4.1 above

Irat = ratio of I131 eqv./Xe133 eqv. from Enclosure 5.6.

4.4.2.2 Based on EMF 37 (if compressor not tripped);

$$\frac{\Delta\text{CPM}}{\Delta\text{min}} \times 1.33E-13 \frac{\text{Ci min min}}{\text{sec ft}^3 \text{cpm}} \times CFM = Q_I$$

where:

ΔCPM = reading from EMF37 Delta Counts

Δmin = the time interval from EMF37 observation (normally 15 minutes)

$$1.33E-13 = 4.0E-5 \mu\text{Ci/cpm} \times 0.1667 \text{ min/ft}^3 \times (\text{inverse of EMF flow rate}) \times 1\text{Ci}/1E6 \mu\text{Ci} \times 1 \text{ min}/60 \text{ sec.} \times 1.2$$

where:

$4.0E-5$ = correlation factor for EMF37 from Reference 2.1.

1.2 = inverse of iodine transmission factor (see Reference 2.15)

CFM = unit vent flow rate (ft^3/min)

4.4.2.3 Based on unit vent sample:

$$Q_I = \text{Unit vent sample} \times 4.72\text{E-}4 \frac{\text{Ci min ml}}{\text{sec ft}^3 \mu\text{Ci}} \times \text{CFM}$$

where:

Unit vent sample = ($\mu\text{Ci/ml}$) (Reference 2.5)

CFM = unit vent flow rate (ft^3/min)

4.4.3 Record Q_{NG} and Q_I on Enclosure 5.1, page 2.

4.5 Dose Assessment (Enclosure 5.1 or Class A computer printout)

4.5.1 On Item 1, record if this information is for a drill or real emergency.

4.5.2 On Item 2, record which unit is affected.

4.5.3 On Item 9, record the reactor status.

4.5.3.1 If the reactor has not tripped, use the data sheet date/time as the time of reactor trip. On the computer printout, arrow out the shutdown time/date and record the % Power from the data sheet.

4.5.4 On Item 10; determine release status by the following guidance criteria:

4.5.4.1 No Release - no potential release of activity generated by the event.

4.5.4.2 Potential Release - activity generated by the event that can potentially be released, but is not currently being released.

4.5.4.3 Release Within Normal Operating Limits - activity generated by the event currently or previously released within normal operating limits (less than $1.008\text{E-}2$ mrem/hr whole body or less than $1.711\text{E-}1$ mrem/hr child thyroid).

4.5.4.4 Release Above Normal Operating Limits - activity generated by the event currently or previously released above normal operating limits (greater than or equal $1.008\text{E-}2$ mrem/hr whole body or greater than or equal $1.711\text{E-}1$ mrem/hr child thyroid).

4.5.5 On Item 11, record what type of release has occurred.

4.5.6 On Item 12, record the noble gas and iodine release rates (curies per second) from all releases.

- 4.5.4 If whole body dose rates exceed $1.008\text{E}-2$ mrem/hr or thyroid dose rates exceed $1.711\text{E}-1$ mrem/hr, check above normal operating limits; otherwise, check below.
- 4.5.6.2 If available, record the highest iodine/xenon ratio.
- 4.5.7 On Item 13, record the dose rates and the integrated doses.
- 4.5.7.1 If new doses were calculated, check the NEW block.
- 4.5.7.2 The duration is the total time of previous releases plus the time estimated for the projected release.
- 4.5.7.3 The integrated dose (mrem) is the total dose from all releases plus the dose from the projected release.
- 4.5.7.4 If information is available contradicting the calculated doses, change the data to reflect the new values.
- 4.5.7.5 On Enclosure 5.1:
- 4.5.7.5.1 Determine the Projected Whole Body Dose Rate, DRwb (rem/hr), due to the noble gases for .5, 2, 5 and 10 miles:
- $$\text{DRwb} = 33.6 \frac{\text{rem m}^3}{\text{hr Ci}} \times \text{TQ}_{\text{NG}} \times \overline{\text{X/Q}}$$
- where:
- 33.6 is the adult whole body dose conversion factor from Reference 2.9 in $\frac{\text{rem m}^3}{\text{hr Ci}}$
- 4.5.7.5.2 Determine the Projected Whole Body Dose, Dwb(rem), due to noble gases for .5, 2, 5 and 10 miles:
- $$\text{Dwb} = \text{DRwb} \times 2 \text{ hr}$$
- where:
- dose is integrated over 2 hour time period

- 4.5.7.5.3 Determine the Projected Thyroid Dose Rate, DRct (rem/hr), due to iodine for .5, 2, 5 and 10 miles:

$$DRct = \overline{X/Q} \times TQ_I \times 2.26E6 \frac{\text{rem m}^3}{\text{hr Ci}}$$

where:

2.26E6 is the child thyroid dose conversion factor from Reference 2.13 in $\frac{\text{rem m}^3}{\text{hr Ci}}$

- 4.5.7.5.4 Determine the Projected Thyroid Dose, Dct(rem), due to iodine for .5, 2, 5 and 10 miles:

$$Dct = DRct \times 2 \text{ hr}$$

where:

dose is integrated over 2 hour time period

- 4.5.8 List any whole body or child thyroid dose rate less than .0001 mrem/hr as "less than background" (where .0001 is an assumed value based on yearly effluent data).
- 4.5.9 On Item 14, record the meteorological data.
- 4.5.10 On Item 16, this section is for the TSC Dose Assessment Coordinator or the CMC off-Site Dose Assessment Director.
- 4.6 Protective Action Recommendations (Enclosure 5.1 or Class A computer printout):
- 4.6.1 Circle on Enclosure 5.1 the Protective Action Zones (PAZ), based upon 1) the wind speed and wind direction, using Enclosure 5.3; and 2) the projected dose from Enclosure 5.1 compared to the following.
- 4.6.2 If the projected dose in a PAZ is < 1 rem whole body or < 5 rem thyroid, then recommend no protective action (action A).
- 4.6.3 If the projected dose in a PAZ is 1 - 5 rem whole body or 5 - 25 rem thyroid, then recommend to consider evacuating pregnant women and children and shelter all other PAZs (actions OTHER and B).
- 4.6.4 If the projected dose in a PAZ is > 5 rem whole body or > 25 rem thyroid, then recommend evacuate everyone and shelter all other PAZs (actions C and B).

- 4.6.5 Recheck meteorology conditions approximately every 15 minutes to ensure that other sectors have not been affected.

4.7 Emergency Classification (Enclosure 5.1)

- 4.7.1 Check the box indicating the emergency classification based upon the following.
- 4.7.2 If the dose rate at the site boundary is $\geq 5.0E-4$ rem/hr whole body then recommend an Alert.
- 4.7.3 If the dose rate at the site boundary is $\geq .05$ rem/hr whole body or $\geq .25$ rem/hr thyroid, then recommend a Site Area Emergency.
- 4.7.4 If the dose rate at the site boundary is ≥ 1 rem/hr whole body or ≥ 5 rem/hr thyroid, then recommend a General Emergency.

5.0 ENCLOSURES

- 5.1 Sample of Meteorology Source Term and Dose Assessment Worksheet
- 5.2 Two-hour Relative Concentration Factors (C_H)
- 5.3 Protective Action Zones Determination
- 5.4 Sample of Source Term Assessment - Steam Relief Valves
- 5.5 EMF26, EMF27, EMF28, EMF29 or EMF10, EMF11, EMF12, EMF13 Noble Gas Correction Factor
- 5.6 1131 eqv./Xe 133 eqv. Ratio
- 5.7 Sample of Source Term Assessment - Containment
- 5.8 Containment Noble Gas Correction Factor
- 5.9 Containment Leakage Rate versus Pressure
- 5.10 Containment Leakage Rate versus Pressure and Size Opening
- 5.11 Sample of Source Term Assessment - Unit Vent
- 5.12 Unit Vent Noble Gas Correction Factor
- 5.13 Integrated Dose

EMERGENCY NOTIFICATION

EDA-2
ENCLOSURE 5.1
Page 1 of 2

1. ☐ THIS IS A DRILL ☐ ACTUAL EMERGENCY ☐ INITIAL ☐ FOLLOW-UP* MESSAGE NUMBER _____

2. SITE: _____ UNIT: _____ REPORTED BY: _____

3. TRANSMITTAL TIME/DATE: _____ / _____ / _____ (Eastern) mm dd yy CONFIRMATION PHONE NUMBER: _____

4. AUTHENTICATION (If Required): _____ (Number) _____ (Codeword)

5. EMERGENCY CLASSIFICATION:
☐ NOTIFICATION OF UNUSUAL EVENT ☐ ALERT ☐ SITE AREA EMERGENCY ☐ GENERAL EMERGENCY

6. ☐ Emergency Declaration At: ☐ Termination At: TIME/DATE: _____ / _____ / _____ (Eastern) mm dd yy (If B, go to item 16.)

7. EMERGENCY DESCRIPTION/REMARKS: _____

8. PLANT CONDITION: ☐ IMPROVING ☐ STABLE ☐ DEGRADING

9. REACTOR STATUS: ☐ SHUTDOWN: TIME/DATE: _____ / _____ / _____ (Eastern) mm dd yy ☐ _____ % POWER

10. EMERGENCY RELEASE(S):
☐ NONE (Go to item 14.) ☐ POTENTIAL (Go to item 14.) ☐ IS OCCURRING ☐ HAS OCCURRED

**11. TYPE OF RELEASE: ☐ ELEVATED ☐ GROUND LEVEL
☐ AIRBORNE: Started: _____ / _____ / _____ Time (Eastern) Date Stopped: _____ / _____ / _____ Time (Eastern) Date
☐ LIQUID: Started: _____ / _____ / _____ Time (Eastern) Date Stopped: _____ / _____ / _____ Time (Eastern) Date

**12. RELEASE MAGNITUDE: ☐ CURIES PER SEC. ☐ CURIES NORMAL OPERATING LIMITS: ☐ BELOW ☐ ABOVE
☐ NOBLE GASES _____ ☐ IODINES _____
☐ IODINE/NOBLE GAS RATIO (If available) _____ ☐ OTHER _____

**13. ESTIMATE OF PROJECTED OFFSITE DOSE: ☐ NEW ☐ UNCHANGED ESTIMATED DURATION: _____ HRS

	Wholebody DOSE RATE (mrem/hr)	Child Thyroid DOSE RATE (mrem/hr)	Wholebody DOSE (mrem)	Child Thyroid DOSE (mrem)
SITE BOUNDARY	_____	_____	_____	_____
2 MILES	_____	_____	_____	_____
5 MILES	_____	_____	_____	_____
10 MILES	_____	_____	_____	_____

**14. METEOROLOGICAL DATA: ☐ WIND DIRECTION (from) _____ * ☐ SPEED (mph) _____
☐ STABILITY CLASS _____ ☐ PRECIPITATION (type) _____

15. RECOMMENDED PROTECTIVE ACTIONS:
☐ NO RECOMMENDED PROTECTIVE ACTIONS
☐ EVACUATE _____
☐ SHELTER IN-PLACE _____
☐ OTHER _____

16. APPROVED BY: _____ (Name) _____ (Title) TIME/DATE: _____ / _____ / _____ (Eastern) mm dd yy

* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

**Information may not be available on initial notifications.

METEOROLOGY, SOURCE TERM AND DOSE ASSESSMENT

- =====
- NOTES: 1) For all evacuations, recommend that the remainder of the 10 mile emergency planning zone stay indoors.
2) Compare these recommendations with other groups' recommendations that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on ____/____/____ Time since trip ____ hrs.

Miles .5 1 2 4 5 7 8
PAZ A0 B1 E1 A1 C1 D1 F1 B2 A2 C2 D2 E2 F2 F3 A3

Total Source Term Assessment ☐ Current ☐ Hypothetical
Steam Relief Containment Unit Vent
Encl. 5.4 Encl. 5.7 Encl. 5.11
____ Ci/sec + ____ Ci/sec + ____ Ci/Sec = ____ Ci/Sec (TQ_{NG})
____ Ci/sec + ____ Ci/sec + ____ Ci/Sec = ____ Ci/Sec (TQ_I)

Source Term Based on

- | | |
|---------------------------|--------------------------------------|
| 1. LOCA | 5. Tube Rupture |
| 2. LOCA (charcoal) | 6. New Fuel Accident (< 100 hrs old) |
| 3. Melted Core | 7. Old Fuel Accident (> 100 hrs old) |
| 4. Melted Core (charcoal) | 8. Waste Gas Decay Tank |

Dose Assessment $\frac{C}{H} = \frac{X}{Q}$ $\Delta T =$ _____
WS

<-----< Adult whole body <-----< >-----> Child thyroid >----->
2 hr 2 hr
Dose = 2 x DRwb = 33.6 x TQ_{NG} x $\frac{X}{Q}$ x TQ_I x 2.26E6 = DRct x 2 = Dose
(rem) (rem/hr) (Ci/sec) (sec/m³) (Ci/sec) (rem/hr) (rem)

Distance miles		
_____ = 2 x _____	= 33.6 x TQ _{NG}	.5 _____ TQ _I x 2.26E6 = _____ x 2 = _____
_____ = 2 x _____	= 33.6 x TQ _{NG}	2 _____ TQ _I x 2.26E6 = _____ x 2 = _____
_____ = 2 x _____	= 33.6 x TQ _{NG}	5 _____ TQ _I x 2.26E6 = _____ x 2 = _____
_____ = 2 x _____	= 33.6 x TQ _{NG}	10 _____ TQ _I x 2.26E6 = _____ x 2 = _____
_____ = 2 x _____	= 33.6 x TQ _{NG}	1 _____ TQ _I x 2.26E6 = _____ x 2 = _____
_____ = 2 x _____	= 33.6 x TQ _{NG}	4 _____ TQ _I x 2.26E6 = _____ x 2 = _____
_____ = 2 x _____	= 33.6 x TQ _{NG}	7 _____ TQ _I x 2.26E6 = _____ x 2 = _____
_____ = 2 x _____	= 33.6 x TQ _{NG}	8 _____ TQ _I x 2.26E6 = _____ x 2 = _____

Review with Emergency Coordinator the recommended Emergency Classification.

- ☐ Recommend Alert
☐ Recommend Site Area Emergency
☐ Recommend General Emergency

DUMMER COMPANY

ENCLOSURE 5.2

TWO-HOUR RELATIVE CONCENTRATION FACTORS (C_R)

Temperature Gradient (C)	Stability Class	Distance (miles)									
		.5	1	2	3	4	5	6	7	8	10
1) $\Delta T < -0.6$	A	1.4E-5	1.2E-6	5.9E-7	4.1E-7	3.2E-7	2.5E-7	2.0E-7	1.9E-7	1.8E-7	1.5E-7
2) $-0.6 \leq \Delta T < -0.5$	C	1.5E-4	4.5E-5	1.3E-5	6.3E-6	3.9E-6	2.7E-6	1.9E-6	1.4E-6	1.1E-6	8.3E-7
3) $-0.5 \leq \Delta T < -0.2$	D	3.8E-4	1.4E-4	4.9E-5	2.7E-5	1.7E-5	1.2E-5	9.2E-6	7.3E-6	6.0E-6	4.3E-6
4) $-0.2 \leq \Delta T < +0.4$	E	6.9E-4	2.5E-4	9.6E-5	5.5E-5	3.5E-5	2.5E-5	2.0E-5	1.6E-5	1.3E-5	9.7E-6
5) $+0.4 \leq \Delta T < +1.2$	F	1.1E-3	5.1E-4	2.0E-4	1.2E-4	8.2E-5	6.2E-5	5.1E-5	4.3E-5	3.8E-5	3.0E-5
6) $+1.2 \leq \Delta T$	G	1.8E-3	1.1E-3	4.3E-4	2.7E-4	2.0E-4	1.7E-4	1.3E-4	1.2E-4	8.6E-5	7.3E-5

NOTE: If ΔT is unavailable use: 1000-1600 hours Use Stability Class D

1600-1000 hours Use Stability Class G

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
EDA-2
ENCLOSURE 5.3
PROTECTIVE ACTION ZONES DETERMINATION

Determine the affected zones (based on wind direction) from the table below and record on Enclosure 5.1.

NOTE: If wind speed is less than or equal to 5 mph, the affected zones for 0-5 miles shall be A0, A1, B1, C1, D1, E1, F1.

Wind Direction (degrees from North)	PAZ's	
	0-5 miles	5-10 miles
0.0 - 22	A0, C1, D1	C2, D2
22.1 - 73	A0, C1, D1, E1	C2, D2, E2, F2
73.1 - 108	A0, C1, D1, E1, F1	D2, E2, F2, F3
108.1 - 120	A0, D1, E1, F1	D2, E2, F2, F3
120.1 - 159	A0, E1, F1	D2, E2, F2, F3, A2
159.1 - 207	A0, E1, F1, A1	E2, F2, F3, A2, B2
207.1 - 247	A0, F1, A1, B1	F2, F3, A2, B2
247.1 - 265	A0, A1, B1	F3, A2, B2, A3, C2
265.1 - 298	A0, A1, B1, C1	A2, B2, A3, C2
298.1 - 338	A0, B1, C1	B2, A3, C2, D2
338.1 - 359.9	A0, B1, C1, D1	B2, C2, D2

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
EDA-2
ENCLOSURE 5.4
SOURCE TERM ASSESSMENT - STEAM RELIEF VALVES

Reactor Trip _____/_____
(Date/Time) Projection based on data on _____/_____
(Date/Time) Report # _____

Calculations based on _____ Melted Core _____ LOCA

NOBLE GAS

based on EMF26 or EMF10

SG
NG

$$\text{_____ R/hr} \times \left[\frac{\text{_____}}{\text{_____ sec}} \right] \times \text{_____ lbm} \times \frac{\text{_____ Ci}}{\text{lbm R/hr}} = \text{_____ Ci/sec}$$

(Encl. 5.5)

based on EMF27 or EMF11

$$\text{_____ R/hr} \times \left[\frac{\text{_____}}{\text{_____ sec}} \right] \times \text{_____ lbm} \times \frac{\text{_____ Ci}}{\text{lbm R/hr}} = \text{_____ Ci/sec}$$

(Encl. 5.5)

based on EMF28 or EMF12

$$\text{_____ R/hr} \times \left[\frac{\text{_____}}{\text{_____ sec}} \right] \times \text{_____ lbm} \times \frac{\text{_____ Ci}}{\text{lbm R/hr}} = \text{_____ Ci/sec}$$

(Encl. 5.5)

based on EMF29 or EMF13

$$\text{_____ R/hr} \times \left[\frac{\text{_____}}{\text{_____ sec}} \right] \times \text{_____ lbm} \times \frac{\text{_____ Ci}}{\text{lbm R/hr}} = \text{_____ Ci/sec}$$

(Encl. 5.5)

Total from all Steam Relief Valves, $Q_{NG} = \text{_____ Ci/sec}$

IODINE

From all Steam Relief valves

Q_I

$Q_{NG} \times \text{_____} \times 1131 \text{ eqv./Xe } 133 \text{ eqv. ratio} = \text{_____ Ci/sec}$
(Encl. 5.6)

☐ Emergency

☐ Drill

Prepared by: _____

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION

EDA-2

ENCLOSURE 5.5

EMF26, EMF27, EMF28, EMF29 or
EMF10, EMF11, EMF12, EMF13 NOBLE GAS CORRECTION FACTOR

Time Since Trip (hrs)

Correction Factor
based on Melted Core or LOCA

≥ 0	3.622
≥ 2	3.971
≥ 4	4.041
≥ 8	4.029
≥ 24	3.332
≥ 48	2.647
≥ 100	2.438
≥ 250	2.438
≥ 500	2.438
≥ 720	2.438

* units in $\frac{Ci}{lbm R/hr}$

* Enclosure 5.5 is the correlation factor per Reference 2.13 x
 $2.83E4 \frac{ml}{ft^3} \times .41 \frac{ft^3}{lbm} \times \frac{m^3}{1E6 ml}$

.41 = specific gravity of steam per Reference 2.13.

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
EDA-2
ENCLOSURE 5.6
I131 eqv./Xe133 eqv. RATIO

Time Since Trip (hrs)	Ratio based on LOCA (Column 1)	Ratio based on Melted Core (Column 2)
≥0	2.74E-3	2.24E-3
≥2	3.42E-3	9.66E-3
≥4	3.82E-3	1.59E-2
≥8	4.34E-3	2.85E-2
≥24	4.79E-3	7.52E-2
≥48	4.84E-3	1.11E-1
≥100	5.06E-3	1.33E-1
≥250	6.55E-3	1.80E-1
≥500	1.02E-2	2.90E-1
≥720	1.44E-2	4.33E-1

* Enclosure 5.6 is from Reference 2.13.

NOTE: For unit vent releases in which Irat is utilized to determine I-131 equiv. concentration, apply the appropriate correction from the table below:

1. LOCA, use column 1 (based on LOCA).
2. LOCA through charcoal filters, divide column 1 value by 100.
3. Core damage, use column 2 (based on Core Melt).
4. Core damage through charcoal filters, divide column 2 value by 100.
5. Tube rupture, use 1.44E-5
6. New fuel accident, use 2.217E-4
7. Old fuel accident, use 7.217E-4
8. Gas decay tank, assume no radioiodine released, only noble gases are considered to be released from gas tank, use 0.

NOTE: For steam releases in which Irat is utilized to determine I-131 equiv. concentration, apply the appropriate correction from the table below:

1. LOCA divide column 1 value by 100.
2. Core damage, divide column 2 value by 100.

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
EDA-2
ENCLOSURE 5.7
SOURCE TERM ASSESSMENT - CONTAINMENT

Reactor Trip _____/_____
(Date/Time) Projection based on data on _____/_____
(Date/Time) Report # _____

Calculations based on _____ Melted Core _____ LOCA

Containment pressure _____ psig

LR = _____ ml/hr x BYPASS _____ (default = .07)

LR based on _____ Realistic Leak Rate

(check one)

_____ 1" 2" 4" 6" 8" 12" 18" 34" diameter opening

(circle one) Personnel Hatch opening

Equipment Hatch opening

_____ Design Leak Rate (4.18E6)

NOBLE GAS

based on (check one)

☐ EMF39(L) if < 1E7 cpm

☐ EMF39(H) if > 100 cpm

☐ EMF53 if 39(H)
is off scale

EMF

CF

LR

Q_{NG}

_____ cpm
or
R/hr x _____
(Encl. 5.8) x _____ ml/hr = _____ $\frac{Ci}{sec}$

(Note on Encl. 5.9)

based on
PACS sample

_____ $\frac{\mu Ci}{ml}$ x 2.78E-10 $\frac{Ci}{sec}$ x _____ ml/hr = _____ $\frac{Ci}{sec}$

IODINE

based on

Q_{NG}

Q_I

_____ $\frac{Ci}{sec}$ x _____ I131 eqv./Xe133 eqv.
ratio (Encl. 5.6) = _____ $\frac{Ci}{sec}$

based on EMF40

LR

_____ $\frac{\Delta CPM}{\Delta min}$ x 9.82E-20 $\frac{Ci}{sec}$ x _____ ml/hr = _____ $\frac{Ci}{sec}$

based on PACS sample

_____ $\frac{\mu Ci}{ml}$ x 2.78E-10 $\frac{Ci}{sec}$ x _____ ml/hr = _____ $\frac{Ci}{sec}$

☐ Emergency

☐ Drill

Prepared by: _____

DUKE POWER COMPANY
Enclosure 5.8
CATAWBA CONTAINMENT NOBLE GAS CORRECTION FACTOR

Time Since Trip (hours)	EMF 39(L) based on		EMF 39(H) based on		EMF 53 based on	
	LOCA	Melted Core	LOCA	Melted Core Core	LOCA	Melted
≥ 0	6.389E-10	6.672E-17	5.56E-14	1.429E-13	3.781E-10	1.190E-9
≥ 2	6.389E-18	4.448E-17	5.56E-14	1.003E-13	3.114E-10	5.894E-10
≥ 4	6.389E-18	3.058E-17	5.56E-14	1.232E-13	2.780E-10	4.726E-10
≥ 8	6.389E-18	2.113E-17	5.56E-14	1.195E-13	2.446E-10	3.392E-10
≥ 24	6.389E-18	1.112E-17	5.56E-14	7.339E-14	2.335E-10	1.890E-10
≥ 48	6.389E-18	1.056E-17	5.56E-14	6.060E-14	2.335E-10	1.668E-10
≥ 100	6.389E-18	1.390E-17	5.56E-14	5.699E-14	2.335E-10	1.612E-10
≥ 250	6.389E-18	1.446E-17	5.56E-14	5.588E-14	2.335E-10	1.557E-10
≥ 500	6.389E-18	9.730E-18	5.56E-14	5.560E-14	2.335E-10	1.251E-10
≥ 720	6.389E-18	6.394E-18	5.56E-14	5.560E-14	2.335E-10	1.056E-10
Units in $\frac{\text{Ci hr}}{\text{sec ml cpm}}$ units in $\frac{\text{Ci hr}}{\text{sec ml cpm}}$ units in $\frac{\text{Ci hr}}{\text{sec ml R/hr}}$						

Enclosure 5.8 is the correlation factor per Reference 2.13 $\times \frac{\text{hr}}{3600 \text{ sec}} \times \frac{\text{Ci}}{1\text{E}6 \text{ pCi}}$

NOTE: Reference 2.14.

If Time Since Trip is > 48 hours and EMF53A or EMF53B is less than or equal to 150 R/hr, add 150 R/hr to reading.

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
EDA-2
ENCLOSURE 5.9
CONTAINMENT LEAKAGE RATE VERSUS PRESSURE

<u>PSIG</u>	<u>ml/hr</u>
≥0	*2.081E5
≥2	4.536E5
≥4	8.316E5
≥8	1.397E6
≥10	1.591E6
≥11	1.663E6
≥12	1.713E6
≥13	1.764E6
≥14	1.800E6
≥15	1.836E6

Enclosure 5.9 is the realistic leakage rate (m^3/sec) per Reference 2.12 x $1\text{E}6 \text{ ml}/\text{m}^3 \times 3600 \text{ sec/hr}$.

* $2.081\text{E}5 \text{ ml/hr}$ is derived as follows:

$$\frac{2.081\text{E}5 \text{ ml}}{\text{hr}} = 0.017 \frac{\%}{\text{day}} \times 3.4\text{E}-3 \frac{\text{m}^3}{\%-\text{sec}} \times 1\text{E}6 \frac{\text{ml}}{\text{m}^3} \times 3600 \frac{\text{sec}}{\text{hr}}$$

where:

0.017 is determined from containment leakage rate vs pressure curve from Reference 2.13 for an assumed 1 psig. $3.4\text{E}-3$ is from Reference 2.12.

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
EDA-2

ENCLOSURE 5.10
CONTAINMENT LEAKAGE RATE VERSUS PRESSURE AND SIZE OPENING

For 1" diameter opening

PSIG	ml/hr	PSIG	ml/hr	PSIG	ml/hr
>1.25	2.209E8	>5.0	3.908E8	>12.5	5.862E8
>2.50	2.889E8	>7.5	4.588E8	>15.0	6.287E8
>3.75	3.483E8	>10.0	5.268E8		

For 2" diameter opening

PSIG	ml/hr	PSIG	ml/hr	PSIG	ml/hr
>1.25	8.496E8	>5.0	1.512E9	>12.5	2.243E9
>2.50	1.121E9	>7.5	1.784E9	>15.0	2.464E9
>3.75	1.342E9	>10.0	2.022E9		

For 4" diameter opening

PSIG	ml/hr	PSIG	ml/hr	PSIG	ml/hr
>1.25	3.144E9	>5.0	5.692E9	>12.5	8.496E9
>2.50	4.248E9	>7.5	6.797E9	>15.0	9.176E9
>3.75	5.098E9	>10.0	7.731E9		

For 6" diameter opening

PSIG	ml/hr	PSIG	ml/hr	PSIG	ml/hr
>1.25	7.137E9	>5.0	1.291E10	>12.5	1.937E10
>2.50	9.516E9	>7.5	1.529E10	>15.0	2.124E10
>3.75	1.138E10	>10.0	1.716E10		

For 8" diameter opening

PSIG	ml/hr	PSIG	ml/hr	PSIG	ml/hr
>1.25	1.257E10	>5.0	2.243E10	>12.5	3.381E10
>2.50	1.648E10	>7.5	2.634E10	>15.0	3.568E10
>3.75	1.971E10	>10.0	3.042E10		

For 12" diameter opening

PSIG	ml/hr	PSIG	ml/hr	PSIG	ml/hr
>1.25	2.719E10	>5.0	5.012E10	>12.5	7.476E10
>2.50	3.738E10	>7.5	5.947E10	>15.0	8.156E10
>3.75	4.452E10	>10.0	6.712E10		

For 18" diameter opening

PSIG	ml/hr	PSIG	ml/hr	PSIG	ml/hr
>1.25	5.522E10	>5.0	1.003E11	>12.5	1.529E11
>2.50	7.476E10	>7.5	1.189E11	>15.0	1.665E11
>3.75	8.836E10	>10.0	1.351E11		

For 34" diameter opening

PSIG	ml/hr	PSIG	ml/hr	PSIG	ml/hr
>1.25	1.869E11	>5.0	3.398E11	>12.5	5.132E11
>2.50	2.583E11	>7.5	4.078E11	>15.0	5.607E11
>3.75	3.093E11	>10.0	4.588E11		

For Personnel Hatch opening

PSIG	ml/hr	PSIG	ml/hr	PSIG	ml/hr
>1.25	2.379E12	>5.0	4.690E12	>12.5	6.967E12
>2.50	3.398E12	>7.5	5.573E12	>15.0	7.646E12
>3.75	4.111E12	>10.0	6.372E12		

For Equipment Hatch opening

PSIG	ml/hr	PSIG	ml/hr	PSIG	ml/hr
>1.25	1.121E13	>5.0	2.022E13	>12.5	3.059E13
>2.50	1.478E13	>7.5	2.379E13	>15.0	3.398E13
>3.75	1.767E13	>10.0	2.719E13		

* Enclosure 5.10 is the containment leakage for an opening size in standard cubic feet per min (scfm) x $2.83E4 \text{ ml/ft}^3$ x 60 min/hr.

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
EDA-2
ENCLOSURE 5.11
SOURCE TERM ASSESSMENT - UNIT VENT

Reactor Trip _____/_____
(Date/Time)

Report # _____
Projection based on data on _____/_____
(Date/Time)

Calculations based on _____ Melted Core _____ LOCA

CFM = _____ ft³/min

NOBLE GAS

based on (check one)

□ EMF36(L) 4f < 1E7 cpm

□ EMF36(H) if > 100 cpm

- EMF54 if 36(H) is offscale

EMF

CF

CFM

 Q_{NG}
$$\frac{\text{cpm or R/hr}}{(\text{Encl. 5.12})} \times \frac{\text{ft}^3}{\text{min}} = \frac{\text{Ci}}{\text{sec}}$$

based on Unit Vent Sample

$$\frac{\mu\text{Ci}}{\text{ml}} \times 4.72\text{E-}4 \frac{\text{Ci min ml}}{\text{sec ft}^3 \mu\text{Ci}} \times \frac{\text{ft}^3}{\text{min}} = \frac{\text{Ci}}{\text{sec}}$$

IODINE

based on

 Q_{NG} Q_1
$$\frac{\text{Ci}}{\text{sec}} \times \frac{1131 \text{ eqv./Xe133 eqv.}}{\text{ratio (Encl. 5.6)}} = \frac{\text{Ci}}{\text{sec}}$$

based on

EMF37

CFM

$$\frac{\Delta \text{CPM}}{\Delta \text{min}} \times 1.33\text{E-13} \frac{\text{Ci min min}}{\text{sec ft}^3 \text{ cpm}} \times \frac{\text{ft}^3}{\text{min}} = \frac{\text{Ci}}{\text{sec}}$$

based on Unit Vent Sample

$$\frac{\mu\text{Ci/ml} \times 4.72\text{E-4} \frac{\text{Ci min ml}}{\text{sec ft}^3 \mu\text{Ci}} \times \frac{\text{ft}^3}{\text{min}}}{\text{min}} = \frac{\text{Ci}}{\text{sec}}$$
☐ Emergency

□ Drill

Prepared by: _____

DUKE POWER COMPANY
ENCLOSURE 5.12
CATAWBA UNIT VENT NOBLE GAS CORRECTION FACTOR

Time Since Trip (hours)	EMF36(L) based on	EMF36(H) based on	EMF54 based on
	Melted Core	Melted Core	Melted Core
≥ 0	1.133E-10	2.426E-7	1.887E-3
≥ 2	7.552E-11	1.704E-7	1.179E-3
≥ 4	5.192E-11	2.091E-7	9.905E-4
≥ 8	3.587E-11	2.030E-7	6.367E-4
≥ 24	1.888E-11	1.246E-7	2.931E-4
≥ 48	1.794E-11	1.029E-7	2.405E-4
≥ 100	2.360E-11	9.676E-8	2.358E-4
≥ 250	2.454E-11	9.487E-8	2.358E-4
≥ 500	1.652E-11	9.440E-8	2.358E-4
≥ 720	1.086E-11	9.440E-8	2.358E-4

If accident is:

1. Melted core use table.
2. Melted core through charcoal use table.
3. New fuel Accident (less than 100 days old) use 2.358E-11 for EMF36(L), use 9.67E-8 for EMF36(H), use 2.358E-4 for EMF54.
4. All other accidents use 1.086E-11 for EMF36(L), use 9.44E-8 for EMF36(H), use 2.358E-4 for EMF54.

Units in $\frac{\text{Ci min}}{\text{sec ft}^3 \text{ cpm}}$

units in $\frac{\text{Ci min}}{\text{sec ft}^3 \text{ cpm}}$

units in $\frac{\text{Ci min}}{\text{sec ft}^3 \text{ R/hr}}$

Enclosure 5.12 is the correlation factor per Reference 2.13 x 2.83E4 $\frac{\text{ml}}{\text{ft}^3} \times \frac{\text{min}}{60 \text{ sec}} \times \frac{\text{Ci}}{1\text{E6 } \mu\text{Ci}}$

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
EDA-2
ENCLOSURE 5.13
INTEGRATED DOSE

Duration (hrs)	_____	_____	_____	_____	_____	_____	_____	_____	_____
A0	_____	_____	_____	_____	_____	_____	_____	_____	_____
B1	_____	_____	_____	_____	_____	_____	_____	_____	_____
E1	_____	_____	_____	_____	_____	_____	_____	_____	_____
A1	_____	_____	_____	_____	_____	_____	_____	_____	_____
C1	_____	_____	_____	_____	_____	_____	_____	_____	_____
D1	_____	_____	_____	_____	_____	_____	_____	_____	_____
F1	_____	_____	_____	_____	_____	_____	_____	_____	_____
B2	_____	_____	_____	_____	_____	_____	_____	_____	_____
A2	_____	_____	_____	_____	_____	_____	_____	_____	_____
C2	_____	_____	_____	_____	_____	_____	_____	_____	_____
D2	_____	_____	_____	_____	_____	_____	_____	_____	_____
E2	_____	_____	_____	_____	_____	_____	_____	_____	_____
F2	_____	_____	_____	_____	_____	_____	_____	_____	_____
F3	_____	_____	_____	_____	_____	_____	_____	_____	_____
A3	_____	_____	_____	_____	_____	_____	_____	_____	_____

Instructions:

- 1) Add the doses from previous releases to the projected release.
- 2) Add the times of releases to the time of the projected release.