

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY
STATION MANAGER

RECEIVED
NRC

83 MAR 28 PM 12:33

SCE

REGIONAL FILE

TELEPHONE
(714) 492-7700

March 24, 1983

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
14-Day Follow-Up Report
Licensee Event Report No. 83-019 (Docket 50-361)
Licensee Event Report No. 83-023 (Docket 50-362)
San Onofre Nuclear Generating Station, Units 2 & 3

Reference: Letter, H.B. Ray (SCE) to R. H. Engelken (NRC),
dated March 11, 1983

The referenced letter provided you with confirmation of our prompt notification, pursuant to Sections 6.9.1.12.i of Appendix A, Technical Specifications to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, involving the Reactor Protection System (RPS).

Pursuant to Section 6.9.1.12, this submittal provides the required 14-day follow-up report and copies of Licensee Event Reports (LER's). Enclosed LER 83-019 (Docket 50-361) and LER 83-023 (Docket 50-362) address these events.

The referenced letter indicated that the failure in Unit 3 was on March 3, 1983, whereas it was on March 1, 1983. Also, the total number of Reactor Trip Breakers is nine (9) per unit instead of the eight (8) previously stated.

8304110194 830324
PDR ADOCK 05000361
S PDR

IE-22
83-140

March 24, 1983

If there are any questions regarding the above, please contact me.

Sincerely,



Enclosure: LER 83-019 (Docket 50-361)
LER 83-023 (Docket 50-362)

cc: A.E. Chaffee (USNRC Resident Inspector, Units 2 and 3)
R.J. Pate (USNRC Resident Inspector, Units 2 and 3)

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U.S. Nuclear Regulatory Commission
Office of Management Information and Program Control (MIPC)

Institute of Nuclear Power Operations (INPO)