



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

March 24, 1983

Mr. R.C. Haynes
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-039/03L-0
ER 100450 FILE 841-23
PLA-1594

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 83-039/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.c, in that two channel functional tests required to be performed prior to each startup, if not performed within the last seven days, were omitted from the plant startup procedure and consequently not performed prior to several startups.

H.W. Keiser
Superintendent of Plant-Susquehanna

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

JTT/cg

8304110312 830324
PDR ADOCK 05000387
S PDR

Ier