NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	Licensee Code (2)	CTHNP1
01	License Number (3)	00-00000-00
01	License Type (4)	4 1111
01	CAT (5)	
CON'T 01	Report Source (6)	L
	Docket Number (7)	050-0213
	Event Date (8)	030983
	Report Date (9)	033183

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 In the course of system inspections and tests during a scheduled shutdown for
03 refueling, mechanical linkages on two containment air recirculation (CAR) fan
04 dampers were found broken. No hazard to the public existed because design accident
05 air flow would have been maintained had this failure occurred during plant operations.

Line 09	Value
System Code (11)	SC
Cause Code (12)	E
Cause Subcode (13)	B
Component Code (14)	VALVEX
Comp. Subcode (15)	N
Valve Subcode (16)	X

LER/RO Report Number (17)	Value
Event Year	83
	—
Sequential Report No.	005
	/
Occurrence Code	03
Report Type	L
	—
Revision No.	0

Field	Value
Action Taken (18)	A
Future Action (19)	X
Effect on Plant (20)	Z
Shutdown Method (21)	Z
Hours (22)	0000
Attachment Submitted (23)	N
NPRD-4 Form Sub. (24)	N
Prime Comp. Supplier (25)	A
Component Manufacturer (26)	X999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 At about the time of this failure it had been determined through engineering review
11 of another recent failure that a regular maintenance program is needed. The
12 program is being accomplished now and will be written into station procedures by
13 May 31, 1983.

Line	Field	Value
15	Facility Status (28)	H
15	% Power (29)	000
15	Other Status (30)	N/A
15	Method of Discovery (31)	B
15	Discovery Description (32)	Outage inspection/test program
16	Activity Released (33)	Z
16	Content of Release (34)	Z
16	Amount of Activity (35)	N/A
16	Location of Release (36)	N/A
17	Personnel Exposures Number (37)	000
17	Type (38)	Z
17	Description (39)	N/A
18	Personnel Injuries Number (40)	000
18	Description (41)	N/A
19	Loss of or Damage to Facility Type (42)	Z
19	Description (43)	N/A
20	Publicity Issued (44)	N
20	Description (45)	N/A

8304110460 830331
PDR ADOCK 05000213
S PDR

NRC USE ONLY

NAME OF PREPARER: R. Z. Test

PHONE: (203) 267-2556

GPO 917-926