



**Duquesne Light**

Nuclear Group  
P.O. Box 4  
Shippingport, PA 15077-0004

Telephone (412) 393-6000

April 19, 1991

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Proposed Operating License Change Request  
No. 176 Revision 1 (TAC No. 76889)

Enclosed are the following:

1. An application for amendment to the above license to revise our previous submittal which proposed to incorporate an overpressure protection system (OPPS) setpoint curve based on temperature. This revision replaces the current OPPS setpoint with a new single setpoint and replaces the current OPPS enable temperature.
2. Documents designated Attachment A, B and C which set forth respectively, the change in the Technical Specifications, the safety analysis (including the no significant hazards evaluation), and the typed replacement Technical Specification pages. Two typed pages in Attachment C (B 3/4 4-11 and B 3/4 5-2) are provided in addition to the changes marked-up in Attachment A due to shifting one or more paragraphs to the next page during typing.

This change has been reviewed by the Onsite Safety Committee and Offsite Review Committee and was determined to be safe based on the attached safety analysis.

We request approval of this amendment by June 1, 1991 to support plant restart from the current outage.

Sincerely,

J. J. Carey  
Executive Vice President  
Operations

cc: Mr. J. Beall, Sr. Resident Inspector  
Mr. T. T. Martin, NRC Region I Administrator  
Mr. A. W. DeAgazio, Project Manager  
Mr. T. M. Gerusky, Director BRP/DER  
Mr. R. Janati, BRP/DER  
Mr. R. Saunders (VEPCO)

240064

9104250081 910419  
PDR ADOCK 05000334  
P PDR

A001  
11