

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | C | A | R | S | I | S | 1 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 4 | 1 | 1 | 1 | 1 | 4 | 5  
9 3 14 15 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39

CON'T  
0 1 | R | E | P | O | R | T | S | O | U | R | C | E | L | 5 | 0 | 5 | 0 | 0 | 0 | 3 | 1 | 2 | 7 | 0 | 3 | 1 | 4 | 8 | 3 | 3 | 0 | 4 | 0 | 6 | 8 | 3 | 9  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
0 2 | On March 14, 1983, it was determined that Snubber Surveillance test  
0 3 | SP 201.10A was not performed in the required interval. Since the plant  
0 4 | was shutdown and defueled at the time, there was no safety significance.  
0 5 |  
0 6 |  
0 7 |  
0 8 |

0 9 | SYSTEM CODE: X X (11) CAUSE CODE: A (12) CAUSE SUBCODE: A (13) COMPONENT CODE: S U P P O R T (14) COMP SUBCODE: D (15) VALVE SUBCODE: Z (16)  
17 | LER/RO REPORT NUMBER: 8 3 (21) EVENT YEAR: 8 3 (22) SEQUENTIAL REPORT NO.: 0 1 2 (23) OCCURRENCE CODE: 0 3 (24) REPORT TYPE: L (25) REVISION NO.: 0 (26)  
18 | ACTION TAKEN: H (33) FUTURE ACTION: X (34) EFFECT ON PLANT: Z (35) SHUTDOWN METHOD: Z (36) HOURS: 0 0 0 (37) ATTACHMENT SUBMITTED: Y (38) NPRO-4 FORM SUB: N (39) PRIME COMP SUPPLIER: Z (40) COMPONENT MANUFACTURER: Z 0 0 9 (41)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
1 0 | Plant personnel mis-interpreted the Technical Specifications because no  
1 1 | explicit provisions were made in them to cover the plant in this configuration.  
1 2 | All required inspections will be performed prior to startup from this outage.  
1 3 | Personnel were re-instructed concerning requirements.  
1 4 |

1 5 | FACILITY STATUS: H (28) % POWER: 0 0 0 (29) OTHER STATUS: N/A (30) METHOD OF DISCOVERY: A (31) DISCOVERY DESCRIPTION: Review of Surveillance Schedule (32)

1 6 | ACTIVITY CONTENT RELEASED OF RELEASE: Z (33) AMOUNT OF ACTIVITY: N/A (35) LOCATION OF RELEASE: N/A (36)

1 7 | PERSONNEL EXPOSURES NUMBER: 0 0 0 (37) TYPE: Z (38) DESCRIPTION: N/A (39)

1 8 | PERSONNEL INJURIES NUMBER: 0 0 0 (40) DESCRIPTION: N/A (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z (42) DESCRIPTION: N/A (43)

2 0 | PUBLICITY ISSUED DESCRIPTION: Y (44) Local newspapers and wire services. (45)

NAME OF PREPARER: R. W. Colombo PHONE: (916) 452-3211