

OPERATING DATA REPORT

DOCKET NO. 50-275
 DATE 3/3/83
 COMPLETED BY W.J. Kelly
 TELEPHONE (805) 595-7351

OPERATING STATUS

1. Unit Name: Diablo Canyon Unit 1
2. Reporting Period: February 1983
3. Licensed Thermal Power (MWt): 166.9
4. Nameplate Rating (Gross MWe): 1170
5. Design Electrical Rating (Net MWe): 1084
6. Maximum Dependable Capacity (Gross MWe): 1134
7. Maximum Dependable Capacity (Net MWe): 1084
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): -0-
10. Reasons For Restrictions, If Any: Suspended Low Power Test License

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>0</u>	<u>0</u>	<u>0</u>
12. Number Of Hours Reactor Was Critical	<u>0</u>	<u>0</u>	<u>0</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>0</u>	<u>0</u>	<u>0</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>0</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>0</u>
18. Net Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>0</u>
19. Unit Service Factor	<u>N/A</u>		
20. Unit Availability Factor	<u>N/A</u>		
21. Unit Capacity Factor (Using MDC Net)	<u>N/A</u>		
22. Unit Capacity Factor (Using DER Net)	<u>N/A</u>		
23. Unit Forced Outage Rate	<u>N/A</u>		
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: March, 1983 (fuel load)
26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

MAY 1983
 MAY 1983
 AUGUST 1983

Forecast
 Achieved

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-275

UNIT Diablo Canyon Unit 1

DATE 3/3/83

COMPLETED BY W.J. Kelly

TELEPHONE (805) 595-7351

MONTH February 1983

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u> </u>
30	<u> </u>
31	<u> </u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH February 1983

DOCKET NO. 50-275
 UNIT NAME Diablo Canyon Unit 1
 DATE 3/3/83
 COMPLETED BY W.J. Kelly
 TELEPHONE (805) 595-7351

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
	810928	F	0	H	4	81-002/01T	ZZ	ZZZZZZ	Halted fuel loading preparations upon discovery of seismic calculation errors. Reanalysis and reviews are being conducted in accordance with Commission's instructions

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

⁵
 Exhibit I - Same Source