



Wisconsin Electric POWER COMPANY
231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

April 12, 1983

STATE OF WISCONSIN
Department of Natural Resources
WPDES Permit Section
P.O. Box 7921
Madison, WI 53707

Gentlemen:

WPDES Permit No. WI-0000957-2
POINT BEACH NUCLEAR PLANT

This will notify the Department that the daily maximum pH effluent limitation was exceeded at the Point Beach Nuclear Plant. The pH of the retention pond discharge (sample point 501) was 9.2 (s.u.) on April 6, 1983.

The Company has commenced an investigation into this incident which will include a review of the sampling and analysis techniques to determine the validity of the results, an inspection of any treatment equipment, and a review of operators' logs to determine any unusual activities which might have caused the incident. When the investigation is completed, a letter will be sent to the Department outlining the results of the investigation and corrective action, if any, which has been or will be taken.

Very truly yours,

C. W. Fay
Vice President - Nuclear Power

C. W. Fay

cc: DNR Lake Michigan District
NRC - Washington, D. C. ✓
NRC - Region III

IE23

8304180286 830412
PDR ADOCK 05000266
S PDR