

Duquesne Light Company

Beaver Valley Power Station
PO Box 4
Shippensburg, PA 17077-0004

JOHN D. SIEBER
Vice President - Nuclear Group

May 6, 1991

(412) 283-6265

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Beaver Valley Power Station, Units No. 1 and 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Proposed Operating License Change 190/54
(Tac. Nos. 80094/80095).


Enclosed are the following:

1. An application for amendment to the above licenses to add a surveillance requirement to provide for the removal and examination of the reactor vessel material irradiation surveillance specimens in accordance with 10CFR50, Appendix H.
2. Documents designated Attachments A, B and C, which set forth, respectively, the changes in the Technical Specifications, the safety analysis (including the no significant hazards evaluation), and the typed replacement Technical Specification pages.

This change has been reviewed by the Onsite Safety Committee and the Offsite Review Committee and was determined to be safe based on the attached safety analysis.

The requested target date for approval of this proposed change is December 2, 1991.

Sincerely,


J. D. Sieber
Vice President
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. A. W. DeAgazio, Project Manager
Mr. T. M. Gerusky, Director BRP/DER
Mr. R. Janati, BRP/DER
Mr. R. Saunders (VEPCO)

9105130123 910506
PDR ADOCK 05000334
PDR

A001
11

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of	)	UNIT NO. 1	UNIT NO. 2
	)	Docket No. 50-334	Docket No. 50-412
Duquesne Light Company	)	License No. DPR-66	License No. NPF-73
Beaver Valley Power Station)			

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the Technical Specifications be amended to modify Technical Specification 3.4.9.1 to add Surveillance Requirement 4.4.9.1.c to provide for the removal and examination of the reactor vessel material irradiation surveillance specimens in accordance with 10CFR50 Appendix H. 4.4.9.1.c would also state that the results of the examinations shall be used to update Figures 3.4-2 and 3.4-3 (Reactor Coolant System Heatup and Cooldown Curves).

The proposed technical specification changes are set forth in Attachment A to this application. A safety analysis and no significant hazard evaluation are set forth in Attachment B. Typed replacement pages for the Technical Specifications are included in Attachment C. Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.

WHEREFORE, applicant respectfully requests that Appendix A to these operating licenses be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By J. D. Sieber
J. D. Sieber
Vice President, Nuclear

Subscribed and sworn to before me

on this 3rd day of May, 1991

Sheila M. Fattore

