

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK: 1 2 3 4 5 6 ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

② 0 0 - 0 0 0 0 0 - 0 0 ③ 4 1 1 1 1 ④ ⑤

7 8 9 14 15 25 26 30 57 CAT 58

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

REPORT
SOURCE

0 1
7 8

REPORT SOURCE L 6 0 5 0 0 0 3 6 4 7 0 3 1 8 8 3 8 0 4 1 4 8 3 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 2300 on 3/18/83, the instrumentation channel associated with service water discharge

0 3 | flow transmitter FT-571 was declared inoperable when the main control board recorder

0 4 | indicated low. Tech. Spec. 3.3.3.10, in part, requires this channel to be operable.

0 5 | Tech. Spec. 3.3.3.10 action statement requirements were met. Health/safety of the

0 6 | public was not affected.

0 7 |

0 8 |

7 8 9

SYSTEM CODE W A 11		CAUSE CODE E 12		CAUSE SUBCODE X 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE T 15		VALVE SUBCODE Z 16							
EVENT YEAR 8 3 21 22		SEQUENTIAL REPORT NO. 0 1 6 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32									
ACTION TAKEN D 18		FUTURE ACTION X 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. N 24		PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER F 1 8 0 26	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This event was caused by water damage to the flow transmitter which is located in a
1 1 service water valve box. Following the repair of the transmitter, the FT-571 instru-
1 2 mentation channel was declared operable at 1640 on 3/19/83. An engineering review will
1 3 be made to determine means for improving reliability.
1 4

FACILITY STATUS										% POWER										OTHER STATUS										METHOD OF DISCOVERY										DISCOVERY DESCRIPTION									
1	5	E	28	1	0	0	29	NA										30	A	31	Operational Event										32																		
ACTIVITY CONTENT										RELEASED OF RELEASE										AMOUNT OF ACTIVITY										LOCATION OF RELEASE																			
1	6	Z	33	Z	34	NA										35	NA										36																						
PERSONNEL EXPOSURES										PERSONNEL INJURIES										LOSS OF OR DAMAGE TO FACILITY										PUBLICITY																			
NUMBER										NUMBER										TYPE										DESCRIPTION																			
1	7	0	0	0	37	0	0	0	40	Z	38	NA										39	NA										41																
TYPE										DESCRIPTION										NA										43	NA										45								
1	8	0	0	0	40	NA										41	NA										43	NA										45											
ISSUED										DESCRIPTION										NRC USE ONLY																													
2	0	N	44	NA										45	NA										47																								

NAME OF PREPARER W. G. Hairston, III

PHONE: (205) 899-5156