

Analysis of Flow Stratification in the Surge Line of the Comanche Peak Reactor

Prepared by
J. G. Sun, Y. H. Shen, W. T. Sha

Argonne National Laboratory

Prepared for
U.S. Nuclear Regulatory Commission

AVAILABILITY NOTICE

Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 2120 L Street, NW, Lower Level, Washington, DC 20555
2. The Superintendent of Documents, U.S. Government Printing Office, P.O. Box 37082, Washington, DC 20013-7082
3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC Office of Inspection and Enforcement bulletins, circulars, information notices, inspection and investigation notices; Licensee Event Reports; vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the GPO Sales Program: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, and NRC booklets and brochures. Also available are Regulatory Guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG series reports and technical reports prepared by other federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal and periodical articles, and transactions. *Federal Register* notices, federal and state legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Office of Information Resources Management, Distribution Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7920 Norfolk Avenue, Bethesda, Maryland, and are available there for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

DISCLAIMER NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Analysis of Flow Stratification in the Surge Line of the Comanche Peak Reactor

Manuscript Completed: January 1991
Date Published: April 1991

Prepared by
J. G. Sun, Y. H. Shen, W. T. Sha

Argonne National Laboratory
9700 South Cass Avenue
Argonne, IL 60439

Prepared for
Division of Safety Programs
Office for Analysis and Evaluation of Operational Data
U.S. Nuclear Regulatory Commission
Washington, DC 20555
NRC FIN D2195

Analysis of Flow Stratification in the Surge Line of the Comanche Peak Reactor

J. G. Sun, Y. H. Shen, and W. T. Sha

Abstract

A number of nuclear power plants have reported failure of reactor components due to flow stratification. Therefore, a fundamental understanding of, and a capability to predict, flow stratification in a reactor system is critically important to reactor performance and safety. The work presented here is the first step in this direction and will contribute to the resolution of the issue of flow stratification.

An analysis is performed using the COMMIX-1C computer program for the surge line of the Comanche Peak reactor. A comparison is made between the calculated results from the COMMIX code and the plant-measured data, and the agreement is good.

Contents

Executive Summary.....	1
1 Introduction.....	1
2 Objectives.....	2
3 Brief Description of the COMMIX Code.....	2
3.1 Background.....	2
3.2 Equations Solved.....	3
3.3 Unique Features.....	3
3.3.1 COMMIX Porous-Medium Formulation.....	3
3.3.2 Two Solution Algorithms.....	3
3.3.3 The Geometry Package.....	4
3.4 Other Features.....	4
4 Flow Stratification in a Surge Line.....	5
4.1 Surge Line Layout of Comanche Peak Reactor.....	6
4.2 Experimental Measurements.....	6
4.3 Numerical Simulation Model Used in COMMIX Code.....	6
4.4 Initial and Boundary Conditions.....	6
4.4.1 Initial Conditions.....	7
4.4.2 Boundary Conditions.....	7
4.5 COMMIX Results.....	8
4.6 Comparison of COMMIX Results with Measurements.....	8
5 Discussion and Conclusions.....	9
Acknowledgments.....	49
References.....	49

Figures

1 Pressurizer Surge Line Layout and Monitoring Locations for the Comanche Peak Reactor.....	12
2 T1 Temperature Readings.....	13
3 T2 Temperature Readings.....	14
4 T3 Temperature Readings.....	15
5 T4 Temperature Readings.....	16
6 Hot-Leg Temperature Readings.....	17
7 Pressurizer Water Level Readings.....	18

7a	Enlarged View of a Portion of Fig. 7 for 17 to 18 h	19
8	Surge Line Layout Used in COMMIX Code	20
9	Typical Cross Section of Surge Line	21
10	Typical Elbow	22
11	Inlet Velocity of Surge Line	23
12	Inlet Temperature of Surge Line	24
13	Velocity Profile at 10 min into Transient, Pipes L1 and L2	25
14	Velocity Profile at 10 min into Transient, Pipe L2	26
15	Velocity Profile at 10 min into Transient, Pipe L3	27
16	Velocity Profile at 10 min into Transient, Pipe L3	28
17	Velocity Profile at 10 min into Transient, Pipe L3	29
18	Velocity Profile at 10 min into Transient, Pipes L3 and L4	30
19	Velocity Profile at 10 min into Transient, Pipe L4	31
20	Velocity Profile at 10 min into Transient, Pipe L4	32
21	Temperature Distributions at 10 min into Transient, Pipes L1 and L2	33
22	Temperature Distributions at 10 min into Transient, Pipe L2	34
23	Temperature Distributions at 10 min into Transient, Pipe L3	35
24	Temperature Distributions at 10 min into Transient, Pipe L3	36
25	Temperature Distributions at 10 min into Transient, Pipe L3	37
26	Temperature Distributions at 10 min into Transient, Pipes L3 and L4	38
27	Temperature Distributions at 10 min into Transient, Pipe L4	39
28	Temperature Distributions at 10 min into Transient, Pipe L4	40
29	Temperature Profile at T1	41
30	Temperature Profile at T2	42
31	Temperature Profile at T3	43

32	Temperature Profile at T4	44
33	COMMIX Results vs. Experimental Data, T1.....	45
34	COMMIX Results vs. Experimental Data, T2.....	46
35	COMMIX Results vs. Experimental Data, T3.....	47
36	COMMIX Results vs. Experimental Data, T4.....	48

Table

1	Pressurizer Water Level vs. Volume.....	11
---	---	----

Executive Summary

Flow stratification is known to occur in various reactor components during normal and off-normal operating conditions of both pressurized water reactors and boiling water reactors. A large temperature difference is normally associated with flow stratification. Thus, when flow stratification occurs in a reactor component, it will be subject to an additional thermal stress resulting from the local temperature difference. A number of nuclear power plants have reported failure of reactor components due to flow stratification. Flow stratification can not only cause reactor shutdown due to an unisolable leak resulting from failure of a reactor component, but also has significant implications to reactor safety and can alter both the sequence and consequence of a reactor accident. Therefore, it is imperative to understand the causes of flow stratification and, more important, we should be able to predict when and where flow stratification will occur and the magnitude of the temperature difference associated with the flow stratification. The work reported here represents the first step in this direction and will contribute to the resolution of the issue of flow stratification.

An analysis is performed using the COMMIX-1C computer program for the surge line of the Comanche Peak reactor. The COMMIX-1C computer code, which is being developed and sponsored by the Office of Nuclear Regulatory Research in the U.S. Nuclear Regulatory Commission, is a three-dimensional transient single-phase computer program for thermal-hydraulic analysis of single- and multicomponent engineering systems. It solves equations of conservation of mass, momentum, and energy as a boundary value problem in space and as an initial value problem in a time domain and has been applied to flow stratification and natural circulation during postulated reactor accidents. The major objective of this work is to demonstrate that the COMMIX code is capable of predicting flow stratification. The numerical results obtained from the COMMIX code for the surge line of the Comanche Peak reactor presented here have been compared with the measurements provided by the Westinghouse Electric Corporation and the agreement is good.

1 Introduction

Flow stratification is due to the density difference of two streams of a fluid or different fluids flowing at relatively low velocities with very little mixing. The density difference is attributed either to the temperature difference of two streams of a given fluid or to different fluids with different intrinsic densities. The scope of this study is limited to flow stratification caused by the temperature difference of two streams of a given fluid. These two streams flow at low velocity with very little turbulent mixing between them. The lighter hot fluid stays above and the heavier cold fluid stays below in the flow domain.

A number of nuclear power plants have reported failure of reactor components due to flow stratification.¹ The most common cases of flow stratification in reactor components during normal operating conditions (including transients) and off-normal conditions occur in the surge line, hot leg, residual heat removal system, feed water line, steam generator feed water ring, etc. Flow stratification can not only cause reactor shutdown due to unisolable leaks caused by failure of reactor components, but also has serious implications

for reactor safety. It has been shown that flow stratification can occur in a hot leg and most likely in a surge line* during a postulated TLMB* accident (station blackout).² One possibility is failure of the pressure boundary due to flow stratification prior to breach of the reactor vessel by the molten core; should this failure occur early enough, the reactor system may depressurize sufficiently to avoid direct containment heating when the core debris is ejected after vessel failure. Thus, flow stratification can alter both the sequence and consequence of a severe accident. For these reasons, a fundamental understanding of flow stratification is essential to avoid a possible reactor shutdown or accident. The present work represents the first step in that direction and will provide a reliable predictive capability of flow stratification in terms of when and where, as well as the magnitude of the temperature difference. It is to be noted that flow stratification was not accounted for in the original design of all light water reactors (LWR) and it certainly has significant impact on life extension of all existing LWRs.

2 Objectives

The two principal objectives of this study are:

1. To demonstrate the capability of the COMMIX computer code in predicting flow stratification in various reactor components.
2. To present results obtained from the COMMIX code for the surge line of Comanche Peak reactor and to compare these results with plant-measured data.

3 Brief Description of the COMMIX Code

COMMIX is a generalized computer code for heat transfer and fluid flow analysis.³⁻⁵ Its capabilities include steady-state/transient, three-dimensional, and single-phase analysis of nuclear reactor systems under normal and off-normal operating conditions. Recently, the COMMIX code has been and continues to be extended and modified to multiphase applications of various engineering systems.

COMMIX is a well-refined and -tested code. Already, a large number of computations have been performed for complex situations, and many organizations, both in the U.S. and abroad, are using the code to simulate industrial problems. The structure of the code is modular. Its many unique features are described below.

3.1 Background

Development of the COMMIX code began in the summer of 1976. The initial version, COMMIX-1,³ was documented and made available to the public (through the U.S. Nuclear

*In this analysis, the surge line was not explicitly included.

Regulatory Commission) in January 1978. The advanced version, COMMIX-1A,⁴ with more capability and flexibility, was released in 1983. Developmental work continued to add improved models and to expand applications to nonnuclear systems. The extended version, COMMIX-1B, was released in December 1985. The latest version is COMMIX-1C,⁵ which was released very recently (September 1990). Many additional improvements over COMMIX-1B have been incorporated into COMMIX-1C.

3.2 Equations Solved

Three-dimensional, time-dependent conservation equations of mass, momentum, and energy and transport equations of turbulence parameters, along with the equation of state, are solved as a boundary value problem in space and an initial value problem in time.

The solution provides detailed three-dimensional descriptions of

- velocity,
- temperature, and
- pressure,

along with ancillary information such as heat transfer and resistance correlations. For easy interpretation, the numerical results can be transformed into graphic forms (e.g., vector plots, isotherm plots, and video or film showing fluid motion).

3.3 Unique Features

3.3.1 COMMIX Porous-Medium Formulation

COMMIX employs a new porous-medium formulation⁶ based on local volume-averaging. This formulation uses four parameters—volume porosity, directional surface porosity, distributed resistance, and distributed heat source (sink)—to model the effects of internal solid structures. In the conventional porous-medium formulation, only three parameters (volume porosity, distributed resistance, and distributed heat source) are used. The addition of a fourth parameter, directional surface porosity, is a new concept that greatly facilitates modeling of velocity and temperature fields in anisotropic media and, in general, improves resolution and accuracy.

3.3.2 Two Solution Algorithms

COMMIX has two solution algorithms for single-phase systems; both algorithms are provided as user options:

- A semi-implicit algorithm derived from the Los Alamos ICE Technique.⁷⁻⁹ This algorithm is ideally suited for analyzing fast transients, where one is

interested in details at small time intervals (on the order of Courant time-step).

- A fully implicit algorithm named SIMPLEST-ANL.⁴ This algorithm is a modification of the Patankar-Spalding numerical procedure¹⁰ known as SIMPLE/SIMPLER. It is particularly suitable for analyzing slow and normal transients.

These two solution procedures are combined into one formulation, but are implemented so that a user can switch from one solution scheme to another at any time during the transient simulation of a problem.

3.3.3 The Geometry Package

The geometry package developed and implemented in COMMIX can approximate any irregular geometry. It uses basic computational cells as building blocks to model the geometry under consideration. Then, both volume porosity and directional surface porosity are used to account for the differences between the approximated and actual configurations.

To reduce computer storage, a computational cell is defined by a number rather than by its conventional (i, j, k) location, where i, j, and k are the computational cell indices in the three principal axes (e.g., x, y, and z in the Cartesian coordinate system). With this approach, the storage requirement depends only on the total number of computational cells and not on the dimensional values of (IMAX * JMAX * KMAX), where IMAX, JMAX, and KMAX denote the maximum values of computational cell indices in the three corresponding principal axes.

A normal three-dimensional computational cell has six surfaces. But to facilitate true and proper modeling of a complex irregular geometry (and most geometries in engineering systems are complex and irregular), we have provided flexibility so that a user can specify an additional seventh surface, called an irregular surface, to a computational cell.

3.4 Other Features

- For single-phase applications, two turbulence model options are provided:
 - Constant turbulent diffusivity model.
 - Two-equation (k- ϵ) model, where k is the turbulent kinetic energy and ϵ is the dissipation rate of k.
- A flow-modulated skew-upwind difference scheme⁵ has been developed and implemented to reduce numerical diffusion, specifically for the case of flow inclined to grid lines.
- The final form of all of the sets of discretization equations is

$$a_0^* \phi_0 - \sum_{l=1}^6 a_l^* \phi_l - b_0^* = 0,$$

where ϕ is a dependent variable and the subscript 1 stands for neighboring points. This general form of the discretization equation lends itself to various solution schemes, e.g., SOR, Preconditioned Conjugate Gradient Method, and direct matrix inversion.

- The solution has a decoupled-transient-simulation option that permits solution of
 - mass-momentum equations only, or
 - energy equation only, or
 - coupled mass-momentum and energy equations, at any given time-step.
- The code has an option that allows use of either Cartesian or cylindrical coordinates.
- COMMIX has built-in properties for liquid sodium and water, with an option permitting use of simplified property correlations for any fluid.
- The code also contains:
 - A generalized resistance model to permit specification of resistance due to internal structures (fuel rods, wire wrap, baffles, grid spacers, etc.).
 - A generalized thermal structure formulation to model thermal interaction between structures (fuel rods, wire wrap, duct wall, baffles, etc.) and surrounding fluid.
- The heat source/sink and boundary conditions can be functions of time.
- The COMMIX code is structured to permit solution of one-, two-, or three-dimensional calculations.

4 Flow Stratification in a Surge Line

A detailed three-dimensional and time-dependent analysis is performed using the COMMIX-1C code for the surge line of the Comanche Peak reactor. Temperature distributions of both fluid and surge line wall are calculated. The surge line layout of the reactor is described, the experimental measurements provided by Westinghouse¹¹ are presented, the numerical model used in the COMMIX calculation is outlined, and both initial and boundary conditions based on the limited measurements used in the COMMIX code are followed. Finally, the detailed velocity profiles and temperature distributions of the surge line obtained from the COMMIX code are presented and compared with the experimental measurements.

4.1 Surge Line Layout of Comanche Peak Reactor

Figure 1 presents the layout of the surge line of the Comanche Peak reactor. All pipe dimensions are shown. The temperature monitoring locations, namely T1, T2, T3, and T4, are also shown in the figure; the temperature monitors record the outside pipe-wall temperature at various circumferential locations.

4.2 Experimental Measurements

Figures 2-5 are temperature measurements as a function of time at T1, T2, T3, and T4, respectively, at the various circumferential locations. Temperatures, as a function of time, of the four hot legs are shown in Fig. 6; the hot leg marked 4 in Fig. 6 is the hot leg with the pressurizer. The water level of the pressurizer as a function of time is marked 7 in Fig. 7. Figure 7a is an enlarged view of a portion of Fig. 7 from 17 to 18 h. The relationship between water level height of the pressurizer and volume is presented in Table 1.

4.3 Numerical Simulation Model Used in COMMIX Code

The numerical models that simulate the surge line of the Comanche Peak reactor are shown in Figs. 8-10. The computational mesh setup along the pipe line is shown in Fig. 8. Figure 9 presents a typical cross section of the surge line, and a typical elbow is modeled as shown in Fig. 10. To avoid modeling complications, the pipe marked L1 in Fig. 1 is modeled as a vertical run, as shown in Fig. 8. This simplification will not affect the results and is discussed in Sec. 5.

The heat-capacity effect of the surge line is explicitly accounted for in the numerical calculation. Wall thickness is equally divided into two computational grids in the numerical model, and the thermal physical properties of the pipe wall used in the COMMIX calculations are

$$\rho \text{ (density)} = 7977 - 0.4167 T \text{ (kg/m}^3\text{)},$$

$$k \text{ (thermal conductivity)} = 14.16 + 0.0131 T \text{ (W/m-}^\circ\text{C)},$$

$$C_p \text{ (specific heat)} = 508.67 \text{ (J/kg-}^\circ\text{C)},$$

$$T \text{ (temperature) in } ^\circ\text{C}.$$

4.4 Initial and Boundary Conditions

A close examination of the experimental measurements shown in Figs. 2-5 reveals that flow stratification with a large temperature difference occurred at approximately 17-1/2 to 21-1/2 h in the transient. One objective of this work is to demonstrate the capability of the COMMIX code to analyze flow stratification. Consideration is also given to the saving of computer running time. We thus decided to start our calculation at 17 h, 31 min, 10 s into the transient. Because we do not start our calculation at the very beginning of the transient, the initial condition corresponding to the beginning of our calculation must be constructed. Also, the boundary conditions as a function of time at the inlet of the surge line (from the

hot leg to the surge line) must be provided. Both initial and boundary conditions used in the COMMIX calculation are described below.

4.4.1 Initial Conditions

- Velocity distribution based on isothermal steady-state solution with inlet velocity of 0.002 m/s at the inlet of the surge line (from hot leg to surge line).
- The outside pipe-wall temperature distribution of all horizontal pipes (L2 and L3) based on T2 and T3 readings and linearly interpreted and extrapolated both axially (along the pipe length) and circumferentially. The outside pipe-wall temperatures in L1 and L4 are assumed to be uniformly distributed according to T1 and T4 readings, respectively. All fluid temperatures next to the pipe wall of L2 and L3 are assumed to be the same and to be stratified. Temperatures in L1 and L4 are assumed to be uniform at 152.6°F (see Fig. 6) and 440°F (same as surge line wall temperature, Fig. 5), respectively. The assumption of uniform fluid temperature in L1 and L4 is reasonable because both T1 and T4 readings after we started the calculation appear to support the assumption.

4.4.2 Boundary Conditions

- At inlet of surge line (from hot leg to surge line):

-Inlet velocity based on water level of pressurizer (Fig.7), as shown in Fig. 11. Figure 11 is obtained in the following manner:

Because water is an incompressible fluid, its level change in the pressurizer is directly related to the water flow rate from the surge line to the pressurizer, which in turn, is related to the flow rate from the hot leg to the surge line. Therefore, the instantaneous mean inlet water velocity v_{in} is evaluated from

$$v_{in} = \frac{QdH}{A dt}$$

where H is the water level in the pressurizer (in percent) as shown in Fig. 7, Q is the volume of the water (in gallons) in each percent change of the pressurizer level, as shown in Table 1, A is the cross-sectional area of the surge line pipe, and t is the time. It is seen from the above equation that the inlet velocity is proportional to the slope of the water level change in the pressurizer as a function of time. When the experimental data of Fig. 7 for the water level (in percent) is enlarged by many times (see Fig. 7a), it can be seen that the slope becomes positive from about 17 h 31 min and increases to a maximum after about 17 h 36 min. Then the slope decreases, attains

another maximum, and gradually declines, eventually reaching very small value. The inlet velocity follows the same pattern, as shown in Fig. 11.

-Inlet temperature based on the outside pipe-wall temperature reading of the hot leg (near the surge line) with pressurizer (Fig. 6), as shown in Fig. 12.

- At the outlet of surge line (from surge line to pressurizer):

$$\frac{\partial v}{\partial x} = \frac{\partial T}{\partial x} = 0.$$

4.5 COMMIX Results

A number of assumptions were used in the calculation:

- No heat loss through the pipe wall of the surge line.
- No pitch (slope) for horizontal pipe.
- Calculation started at 17 h, 31 min, 10 s in the transient.
- Using "best estimate" initial and boundary conditions based on very limited experimental measurements. These measurements are in graphic plot (see Figs. 2-7), but not in digital form.
- Approximating L1 pipe as a vertical run.
- Pipe-wall conduction limited to one dimension (radial direction only).

The typical velocity profiles and temperature distributions at 10 min after starting the calculation will be presented. Velocity profiles and temperature distributions at the center-line of the surge line in the vertical planes of L2 and L3 are shown in Figs. 13-20 and Figs. 21-28, respectively. The temperature profiles of the surge line cross sections at the locations of T1, T2, T3, and T4 are presented in Figs. 29-32, respectively, and both inside and outside temperatures of the surge line wall corresponding to the measured locations are also shown in these figures.

4.6 Comparison of COMMIX Results with Measurements

A comparison of the outside surge line wall temperatures calculated by the COMMIX code with the measured data provided by the Westinghouse Electric Corp.¹¹ namely T1, T2, T3, and T4, are shown in Figs. 29-32, respectively. The calculated results and the experimental measurements are in reasonable agreement.

5 Discussion and Conclusions

Despite large uncertainties in constructing the "best estimate" initial and boundary conditions on the basis of limited available measurements, it is gratifying that the agreement between the calculated results obtained from the COMMIX code and the experimental data is reasonably good. In our opinion, the agreement can be further improved if both initial and boundary conditions can be more accurately quantified.

The wall temperatures of the surge line were calculated by one-dimensional (radial direction only) approximation. The calculated results can be improved if the additional conductions from both circumferential and axial directions are incorporated into the COMMIX code. We recommend that this additional capability be implemented into the COMMIX code.

Based on T1 and T4 readings, there appears to be no flow stratification in either inclined pipe L1 or vertical run L4 very soon after the calculation is begun, as shown in Figs. 2 and 5, respectively. Thus, it seems justifiable to model the inclined pipe L1 as a vertical run.

As stated earlier, the major thrust of this work is to demonstrate the capability of the COMMIX code, which can be used to predict the time, location, and magnitude of a local temperature difference in a flow-stratified pipe. Based on the comparison between the calculated results from COMMIX code and the experimental measurements (Figs. 33-36), it seems reasonable to conclude that the COMMIX code has demonstrated its capability for predicting the flow stratification in the surge line. Nevertheless, it is desirable to conduct more assessments and validations. In particular, validation must be carried out to compare the COMMIX results with the well-instrumented experiments, which are not limited to temperature measurements but also include velocity data.

Based on the calculated velocity profiles and temperature distributions (Figs. 13-20 and Figs. 21-28, respectively) 10 min after starting the calculation, the following important observations may be summarized below.

- The maximum flow stratification or maximum local temperature difference between the top and bottom of the surge line is located at L2 immediately after the flow passes through the elbow from L1. This location is different from the T1, T2, T3, and T4 locations. From an instrumentation standpoint, it is very desirable to take measurements at or near the point of maximum flow stratification.
- The calculated velocity profiles after 10 min of the transient calculation are similar to those shown in Figs. 13-20. The calculated velocity profile in the surge line is very complicated. In a large portion of horizontal pipes L2 and L3, the fluid in both the top and bottom of these pipes flows in the same direction, while in the middle portion, the fluid flows in the opposite direction. It is our belief that the flow pattern is highly sensitive to the geometrical arrangement of a surge line as well as to operating conditions.

Thus, it is very difficult to pregeneralize both the flow pattern and the temperature distribution in a stratified pipe.

- The calculated temperature at the top of the surge line (0° curve) is slightly higher than the temperature at 60° , as shown in Fig. 35 approximately 10 min into the transient. This is because the local velocity at 0° is higher than that at the 60° location; thus, the corresponding heat transfer coefficient is higher. As mentioned earlier, the pipe-wall conduction model used in the COMMIX code is limited to one dimension (radial direction only, in this case); therefore, the spread of the calculated temperatures between the 0° and 90° locations of T3 could be larger if the circumferential conduction of the pipe wall is included. Furthermore, the validity of the assumption of no heat loss through the surge line wall must be examined for future calculations.

Finally, it is to be noted that the COMMIX code is a general-purpose, multidimensional computer program that is not limited to flow stratification in a surge line. In fact, the COMMIX code can be applied to flow stratification problems in any reactor component, including the high-pressure injection system, steam generator feedwater ring, etc., under various reactor operating conditions. The code has also been used extensively for analyzing natural circulation under severe accident conditions. Recently, the Office of Nuclear Reactor Regulatory in the U.S. Nuclear Regulatory Commission expressed some concern about the thermal stripping problem. It is our belief that with some modification of the COMMIX code, we will be in a position to tackle this problem.

Table 1. Pressurizer water level vs. volume
(reproduced from best available
source)

INSIDE DIAMETER: 84.000 INCHES

TOTAL INSIDE LENGTH OF TANK: 595.500 INCHES

HEIGHT OF TANK CYLINDER: 530.900 INCHES

DEPTH OF ELLIPTICAL HEADS: 32.300 INCHES

LEVEL INDICATION BEGINS AT 39.800 INCHES

LEVEL INDICATION ENDS AT 561.500 INCHES

LIQUID HEIGHT (INCHES)	VOLUME (GALLONS)	LEVEL IND. (%)	LIQUID HEIGHT (INCHES)	VOLUME (GALLONS)	LEVEL IND. (%)	LIQUID HEIGHT (INCHES)	VOLUME (GALLONS)	LEVEL IND. (%)
39.80	694.5	0.00	45.82	899.7	1.00	50.23	934.8	2.00
55.45	1060.0	3.00	60.67	1185.2	4.00	65.89	1310.3	5.00
71.10	1435.5	6.00	76.32	1560.6	7.00	81.54	1685.8	8.00
86.75	1810.9	9.00	91.97	1936.1	10.00	97.19	2061.3	11.00
102.40	2186.4	12.00	107.62	2311.6	13.00	112.84	2436.7	14.00
118.05	2561.9	15.00	123.27	2687.1	16.00	128.47	2812.2	17.00
133.71	2937.4	18.00	138.92	3062.5	19.00	144.14	3187.7	20.00
149.36	3312.8	21.00	154.57	3438.0	22.00	159.79	3563.1	23.00
165.01	3688.3	24.00	170.23	3813.5	25.00	175.44	3938.6	26.00
180.66	4063.8	27.00	185.88	4189.0	28.00	191.09	4314.1	29.00
196.31	4439.3	30.00	201.53	4564.4	31.00	206.74	4689.6	32.00
211.96	4814.7	33.00	217.18	4939.9	34.00	222.40	5065.1	35.00
227.61	5190.2	36.00	232.83	5315.4	37.00	238.05	5440.5	38.00
243.26	5565.7	39.00	248.48	5690.8	40.00	253.70	5816.0	41.00
258.91	5941.1	42.00	264.13	6066.3	43.00	269.35	6191.5	44.00
274.57	6316.6	45.00	279.78	6441.8	46.00	285.00	6566.9	47.00
290.22	6692.1	48.00	295.43	6817.2	49.00	300.65	6942.4	50.00
305.87	7067.6	51.00	311.08	7192.7	52.00	316.30	7317.9	53.00
321.52	7443.0	54.00	326.74	7568.2	55.00	331.95	7693.4	56.00
337.17	7818.5	57.00	342.39	7943.7	58.00	347.60	8068.8	59.00
352.82	8194.0	60.00	358.04	8319.1	61.00	363.25	8444.3	62.00
368.47	8569.5	63.00	373.69	8694.6	64.00	378.91	8819.8	65.00
384.12	8944.9	66.00	389.34	9070.1	67.00	394.56	9195.2	68.00
399.77	9320.4	69.00	404.99	9445.6	70.00	410.21	9570.7	71.00
415.42	9695.9	72.00	420.64	9821.1	73.00	425.86	9946.2	74.00
431.07	10071.3	75.00	436.29	10196.5	76.00	441.51	10321.7	77.00
446.73	10446.8	78.00	451.94	10572.0	79.00	457.16	10697.1	80.00
462.38	10822.3	81.00	467.59	10947.4	82.00	472.81	11072.6	83.00
478.03	11197.8	84.00	483.25	11322.9	85.00	488.46	11448.1	86.00
493.68	11573.2	87.00	498.90	11698.4	88.00	504.11	11823.6	89.00
509.33	11948.7	90.00	514.55	12073.9	91.00	519.76	12199.1	92.00
524.98	12324.2	93.00	530.20	12449.3	94.00	535.42	12574.5	95.00
540.63	12699.7	96.00	545.85	12824.8	97.00	551.07	12950.0	98.00
556.28	13075.1	99.00	561.51	13200.3	100.00			

TITLE: PRESSURIZER

PREPARED BY:

AW Smith 2/2/90

SOURCE: TECHNICAL SUPPORT

REVIEWED BY:

2/2/90




Fig. 1. Pressurizer surge line layout and monitoring locations for the Comanche Peak Reactor

COMANCHE PEAK STEAM ELECTRIC STATION - UNIT 1 STRATIFICATION AND THERMAL CYCLING

STRATIFY
Revision B
3 Mar 1990

CH-568				CH-561			
PZR SCL	PT	00T-1-000	TEMP	PZR SCL	PT	00T-1-100	TEMP
Minimum	-	151.833	DEGF	Minimum	-	151.198	DEGF
Maximum	-	350.543	DEGF	Maximum	-	208.737	DEGF
Average	-	193.862	DEGF	Average	-	185.979	DEGF
SD	-	18.595	DEGF	SD	-	12.812	DEGF

Top Curve

Bottom Curve




Fig. 2. T1 temperature readings

COMANCHE PEAK STEAM ELECTRIC STATION - UNIT 1 STRATIFICATION AND THERMAL CYCLING

STABILITY
Revision 0
3 Mar 1988

CH-562				CH-563				CH-564			
PZR	SGL	PT	001-2-000 TEMP	PZR	SGL	PT	001-2-000 TEMP	PZR	SGL	PT	001-2-000 TEMP
Minimum	-	-	253.304 DEGF	Minimum	-	-	239.289 DEGF	Minimum	-	-	216.135 DEGF
Maximum	-	-	408.107 DEGF	Maximum	-	-	403.230 DEGF	Maximum	-	-	410.073 DEGF
Average	-	-	393.373 DEGF	Average	-	-	390.933 DEGF	Average	-	-	386.993 DEGF
SD	-	-	36.158 DEGF	SD	-	-	44.688 DEGF	SD	-	-	57.365 DEGF
CH-565				CH-566							
PZR	SGL	PT	001-2-120 TEMP	PZR	SGL	PT	001-2-180 TEMP				
Minimum	-	-	125.424 DEGF	Minimum	-	-	159.031 DEGF				
Maximum	-	-	487.428 DEGF	Maximum	-	-	382.923 DEGF				
Average	-	-	379.029 DEGF	Average	-	-	351.704 DEGF				
SD	-	-	68.469 DEGF	SD	-	-	72.373 DEGF				




Fig. 3. T2 temperature readings

COMANCHE PEAK STEAM ELECTRIC STATION - UNIT 1 STRATIFICATION AND THERMAL CYCLING

CH-567				CH-568				CH-569			
PZR	SGL	PT	TEMP	PZR	SGL	PT	TEMP	PZR	SGL	PT	TEMP
Minimum	272.462	DEGF		Minimum	240.304	DEGF		Minimum	221.353	DEGF	
Maximum	438.097	DEGF		Maximum	427.787	DEGF		Maximum	429.189	DEGF	
Average	416.832	DEGF		Average	409.749	DEGF		Average	339.561	DEGF	
SD	34.997	DEGF		SD	45.318	DEGF		SD	57.818	DEGF	
CH-570				CH-571							
PZR	SGL	PT	TEMP	PZR	SGL	PT	TEMP				
Minimum	189.126	DEGF		Minimum	150.454	DEGF					
Maximum	409.338	DEGF		Maximum	366.523	DEGF					
Average	382.633	DEGF		Average	339.841	DEGF					
SD	65.346	DEGF		SD	65.304	DEGF					




Fig. 4. T3 temperature readings

COMANCHE PEAK STEAM ELECTRIC STATION - UNIT 1 STRATIFICATION AND THERMAL CYCLING

CH-572				CH-573			
PZR	SGL	PT	00T-4-000 TEMP	PZR	SGL	PT	00T-4-100 TEMP
Minimum	-	-	410.106 DEGF	Minimum	-	-	410.106 DEGF
Maximum	-	-	439.733 DEGF	Maximum	-	-	440.001 DEGF
Average	-	-	431.017 DEGF	Average	-	-	432.860 DEGF
SD	-	-	5.217 DEGF	SD	-	-	5.406 DEGF




Fig. 5. T4 temperature readings

COMANCHE PEAK STEAM ELECTRIC STATION - UNIT 1
STRATIFICATION AND THERMAL CYCLING

STRATIFY
Revision 8
9 Mar 1988

CH-854		CH-855		CH-856		CH-857	
RCS LP1 HL TEMP (WR)		RCS LP2 HL TEMP (WR)		RCS LP3 HL TEMP (WR)		RCS LP4 HL TEMP (WR)	
Minimum -	154.800 DEGF	Minimum -	154.175 DEGF	Minimum -	154.800 DEGF	Minimum -	152.600 DEGF
Maximum -	162.925 DEGF	Maximum -	163.100 DEGF	Maximum -	160.825 DEGF	Maximum -	163.625 DEGF
Average -	157.582 DEGF	Average -	157.909 DEGF	Average -	157.196 DEGF	Average -	158.214 DEGF
SD -	2.488 DEGF	SD -	2.332 DEGF	SD -	1.600 DEGF	SD -	2.768 DEGF





Fig. 6. Hot-leg temperature readings

MANCHE PEAK STEAM ELECTRIC STATION - UNIT 1 STRATIFICATION AND THERMAL CYCLING

STRATIFY
Revision 2
5 Mar 1988



Vol
= 1800 ft³




Fig. 7. Pressurizer water level readings




Fig. 7a. Enlarged view of a portion of Fig. 7 for 17 to 18 h




Fig. 8. Surge line layout used in COMMLX code




Fig. 9. Typical cross section of surge line




Fig. 10. Typical elbow




Fig. 11. Inlet velocity of surge line





Fig. 12. Inlet temperature of surge line



Fig. 13. Velocity profile at 10 min into transient, Pipes L1 and L2




$J = 4$

$\overrightarrow{0.10 \text{ m/s}}$

Pipe L2 ($i = 10, 22$)

Fig. 14. Velocity profile at 10 min into transient, Pipe L2



$$I = 4 \frac{\text{m/s}}{0.10}$$

Fig. 15. Velocity profile at 10 min into transient, Pipe L3





Fig. 16. Velocity profile at 10 min into transient, Pipe L3



$I = 4$

0.10 m/s

Pipe L3 ($j = 32, 41$)

Fig. 17. Velocity profile at 10 min into transient, Pipe L3





Fig. 18. Velocity profile at 10 min into transient, pipes L3 and L4

0.10 m/s


$I = 4$




Pipe L4 ($k = 33, 41$)

Fig. 19. Velocity profile at 10 min into transient, pipe L4

Fig. 20. Velocity profile at 10 min into transient, pipe L4





Pipe L2 ($i = 23, 39$), B1
and L1 ($k = 1, 19$)

$$J = 4$$

Fig. 21. Temperature distributions at 10 min into transient, pipes L1 and L2



$J = 4$

Pipe L2 ($i = 10, 22$)


Fig. 22. Temperature distributions at 10 min into transient, Pipe L2



$I = 4$

$Pi, j = 10, 21) \& B2$

Fig. 23. Temperature distributions at 10 min into transient, Pipe L3



$I = 4$

Fig. 26. Temperature distributions at 10 min into transient, pipes L3 and L4

Pipe L4 ($k = 33, 41$)



$I = 4$


Fig. 27. Temperature distributions at 10 min into transient, pipe L4

Pipe L4 ($k = 42, 50$)



Fig. 28. Temperature distributions at 10 min into transient, pipe L4

Surge Line Wall Temperature ()



K = 5

Fig. 29. Temperature profile at T1




Fig. 30. Temperature profile at T2




Fig. 31. Temperature profile at T3




Fig. 32. Temperature profile at T4




Fig. 33. COMMIX results vs. experimental data, T1




Fig. 34. COMMIX results vs. experimental data, T2




Fig. 35. COMMIX results vs. experimental data, T3




Fig. 36. COMMIX results vs. experimental data, T4

Acknowledgments

The authors gratefully acknowledge the encouragement and support of Drs. Barry Koufer, George Lanik, Jack Rosenthal, and Nelson Su of the Office for Analysis and Evaluation of Operational Data, U.S. Nuclear Regulatory Commission. Stimulating discussions with our coworkers Drs. Maurizio Bottoni, Tai Chien, and Hank Domanus, and the excellent typing of Sally Moll, are also acknowledged.

References

1. Su, N. T., *Special Study Report Review of Thermal Stratification Operating Experience*, AEOD/S902 (March 1990).
2. Domanus, H. M., and W. T. Sha, *Analysis of Natural Convection Phenomena in a Three-Loop PWR During a TMLB Transient Using the COMMIX Code*, NUREG/CR-5070, ANL-87-54 (Dec. 1987).
3. Sha, W. T., et al., *COMMIX-1: A Computer Program for Three-Dimensional, Transient, Single-Phase Thermal Hydraulic Analysis*, NUREG/CR-0483, ANL-77-96 (Sept. 1978).
4. Sha, W. T., et al., *COMMIX-1B: A Three-Dimensional Transient Single-Phase Computer Program for Thermal Hydraulic Analysis of Single and Multicomponent Systems*, NUREG/CR-4348, ANL-85-42 (Sept. 1985).
5. Domanus, H. M., et al., *COMMIX-1C: A Three-Dimensional Transient Single-Phase Computer Program for Thermal Hydraulic Analysis of Single- and Multicomponent Engineering Systems*, NUREG/CR-5649, ANL-90/33 (Sept. 1990).
6. Sha, W. T., B. T. Chao, and S. L. Soo, *Conservation Equations for Finite Control Volume Containing Single Phase Fluid with Fixed, Dispersed Heat Generating (or Absorbing) Solids*, NUREG/CR-0945, ANL-CT-79-42 (July 1979).
7. Harlow, F. H., and A. A. Amsden, *A Numerical Fluid Dynamics Calculation Method for All Flow Speeds*, *J. Computational Phys.*, 8, p. 197 (1971).
8. Harlow, F. H., and A. A. Amsden, *Numerical Calculation of Multiphase Fluid Flow*, *J. Computational Phys.*, 17, pp. 19-52 (1975).
9. Harlow, F. H., and A. A. Amsden, *Flow of Interpenetrating Material Phases*, *J. Computational Phys.*, 18, pp. 440-464 (1975).
10. Patankar, S. V., *Numerical Heat Transfer and Fluid Flow*, in *Numerical Heat Transfer*, 2, McGraw-Hill, New York (1979).
11. Coslow, W., Westinghouse Power Systems Division, personal communication, 1990.

Distribution for NUREG/CR- 5456 (ANL-91/6)Internal:

M. Bottoni
H. M. Domanus
C. A. Malefy
W. T. Sha (28)

J. G. Sun
R. A. Valentin
R. W. Weeks

ANL Contract File
TIS Files (3)
ANL Patent Dept.

External:

NRC, Washington, for distribution per P 4

ANL Libraries (2)

Manager, Chicago Operations Office, DOE

Materials and Components Technology Division Review Committee:

H. Berger, Industrial Quality, Inc., Gaithersburg, MD

M. S. Dresselhaus, Massachusetts Institute of Technology, Cambridge, MA

S. J. Green, Electric Power Research Institute, Palo Alto, CA

R. A. Greenkorn, Purdue University, West Lafayette, IN

C.-Y. Li, Cornell University, Ithaca, NY

P. G. Shewmon, Ohio State University, Columbus

R. E. Smith, Electric Power Research Institute, NDE Ctr., Charlotte, NC

S. Fabric, U.S. Nuclear Regulatory Commission, Washington, DC

B. Kaufer, U.S. Nuclear Regulatory Commission, Washington, DC

G. Lanik, U.S. Nuclear Regulatory Commission, Washington, DC

T. Novak, U.S. Nuclear Regulatory Commission, Washington, DC

J. Rosenthal, U.S. Nuclear Regulatory Commission, Washington, DC

Y. H. Shen, Sunnyvale, CA

N. Su, U.S. Nuclear Regulatory Commission, Washington, DC

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER
(Assigned by NRC. Add Vol., Supp., Rev.,
and Addendum Numbers, if any.)

NUREG/CR-5456
ANL-91/6

2. TITLE AND SUBTITLE

Analysis of Flow Stratification in the Surge Line of the Comanche Peak
Reactor

3. DATE REPORT PUBLISHED

MONTH | YEAR
April | 1991

4. FUNDING NUMBER

D2195

5. AUTHOR(S)

J. G. Sun, Y. H. Shen, and W. T. Sha

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

Sept. 1990 - Feb. 1991

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Argonne National Laboratory
9700 South Cass Avenue
Argonne, IL 60439

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above" if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Division of Safety Programs
Office for Analysis and Evaluation of Operational Data
U. S. Nuclear Regulatory Commission
Washington, DC 20555

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

A number of nuclear power plants have reported failure of reactor components due to flow stratification. Therefore, a fundamental understanding of, and a capability to predict, flow stratification in a reactor system is critically important to reactor performance and safety. The work presented here is the first step in this direction and will contribute to the resolution of the issue of flow stratification.

An analysis is performed using the COMMIX-1C computer program for the surge line of the Comanche Peak reactor. A comparison is made between the calculated results from the COMMIX code and the plant-measured data, and the agreement is good.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating this report.)

Flow stratification
Solution of Navier Stokes and energy equations

13. AVAILABILITY STATEMENT

Unlimited

14. SECURITY CLASSIFICATION

(This Page)

Unclassified

(This Report)

Unclassified

15. NUMBER OF PAGES

16. PRICE

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

SPECIAL FOURTH-CLASS RATE
POSTAGE & FEES PAID
USNRC
PERMIT NO. 0-07

120555134531 1 1AN1P4
US NRC-3ADM
DIV. 14-2 PUBLICATIONS SVCS
1P2-PDR-NUREG
0-021
WASHINGTON DC 20555

ANALYSIS OF FLOW STRATIFICATION IN THE SURGE LINE OF THE
COMANCHE PEAK REACTOR

APRIL 1991

NUREG/CR-5456