

Test Report No. 14950

No. of Pages 47

Report of Test on

SEISMIC VIBRATION TESTING OF
ONE (1) HYDROGEN ANALYZER ASSEMBLY
GENERAL ELECTRIC SPACE SYSTEMS
VALLEY FORGE SPACE CENTER
UNDER PURCHASE ORDER NO. A28000A10155



Date October 17, 1979

	Prepared	Checked	Approved
By	B. Esposito	R. Gilfoy	M. L. Tolf
Signed	<i>B. Esposito</i>	<i>R. Gilfoy</i>	<i>M. L. Tolf</i>
Date	<i>October 18, 1979</i>	<i>18 Oct 79</i>	<i>10/18/79</i>

BE/hmf

S023-508-17-18-0

8304220592 830420
PDR ADCK 05000361
P PDR

F-37

Administrative Data

- 1.0 Purpose of Test: To subject one hydrogen analyzer assembly to seismic vibration testing.
- 2.0 Manufacturer: General Electric
Valley Forge Space Center
Space Division
- 3.0 Manufacturer's Type or Model No: P/N 47E240609
- 4.0 Drawing, Specification or Exhibit: AETC Test Procedure No. 14950 Rev 0
dated July 3, 1979.
- 5.0 Quantity of Items Tested:
Refer to section 1.0 below.
- 6.0 Security Classification of Items: Unclassified
- 7.0 Date Test Completed: October 3, 1979
- 8.0 Test Conducted By: C. Pilotte
P. McDermott
- 9.0 Disposition of Specimens: Returned to General Electric.
- 10.0 Abstract:
Refer to the results section below.

Report No. 14950

Page 1

1.0 TEST ITEM

One (1) Hydrogen Analyzer Assembly P/N 47E240609 consisting of one (1) free standing enclosure approximately 72-1/16" X 25-1/6" X 31-9/16" containing signal conditioning for hydrogen analyzers, one (1) hydrogen sensor and one (1) pressure transducer with a total weight of approximately 660 lbs was submitted by General Electric Space Systems, Valley Forge Space Center, for seismic vibration testing at Acton Environmental Testing Corporation (AETC).

Report No. 14950



S023-50E-17-1E-0

Page 2

2.0 TEST REQUIREMENTS

The purpose of this test was to subject the assembly specified in section 1.0 above to the seismic vibration test specified in section 3.0 below to determine its ability to withstand such vibration without evidence of mechanical damage, deterioration, or loss of its ability to operate properly during or after the simulated seismic event.

Report No. 14950



Page 3

3.0 TEST PROCEDURES

3.1 Test Mounting

The enclosure specified in section 1.0 above was bolted to a 1-1/2" thick steel plate test fixture. The sensor and the transmitter were mounted to brackets supplied by General Electric. The brackets were bolted to the steel plate test fixture. The test fixture was then securely attached to the small 45° biaxial table of the AETC seismic test facility. The use of the 45° biaxial table results in equal horizontal and vertical components.

3.2 Test Monitoring

The hydrogen analyzer assembly was monitored with accelerometers to determine its mechanical response during the resonance survey and multiple frequency tests specified in sections 3.4 and 3.5 below. The eleven (11) monitoring accelerometers and one (1) control accelerometer were located as follows:

ACCELEROMETER NO.	AXIS SENSING ORIENTATION	LOCATION*
1	Vertical	On upper right front corner of cabinet
2	In-axis Horizontal	On lower right intermediate panel above ATB1 & ATB2
3	Vertical	On backside of train B
4	In-axis Horizontal	Gas calibration panel
5	Vertical	On backside of train A
6**	In-axis Horizontal	Gas calibration switch panel
7	Vertical	On lower right front corner of cabinet
8***	In-axis Horizontal	On test table
9	Vertical	Control is #12
10	In-axis Horizontal	
11	In-axis Horizontal	
12	Vertical	

During the resonance survey, data from all twelve (12) accelerometers through appropriate signal conditioning was recorded onto visicorder recording paper included with this test report and onto magnetic tape.

- * Refer to the included photographs
- ** 6A for tests 2, 3 & 5
- *** 8A for tests 2, 3 & 5

Report No. 14950



S023-508-17-18-0

Page 4

F-41

During the multiple frequency test specified in section 3.5 below, data from all twelve (12) accelerometers, through appropriate signal conditioning was recorded onto magnetic tape. Data from the control accelerometer was also analyzed on line by a Spectral Dynamics SD321 Shock Spectrum Analyzer and the X-Y plots of the Test Response Spectra (TRS) of the control accelerometer are included as part of this test report.

The hydrogen analyzer assembly was visually monitored for any evidence of mechanical damage or deterioration.

General Electric personnel monitored the hydrogen analyzer assembly performance. General Electric supplied the required performance monitoring equipment including gas. AETC supplied two (2) channels of brush recording for the following:

CHANNEL NO.	CHANNEL DESCRIPTION
1	Analyzer output A
2	Analyzer output B

The Brush Recordings were retained by General Electric personnel at the completion of testing.

3.3 Test Conditions

The hydrogen analyzer assembly was tested at room temperature.

During the resonance survey specified in section 3.4, the hydrogen analyzer assembly was not operational.

During the multiple frequency test specified in section 3.5 below, the hydrogen analyzer assembly was operational. All electrical and operating test conditions were set and controlled by General Electric personnel.

3.4 Resonance Survey

The resonance survey consisted of a biaxial sinusoidal input with peak horizontal and vertical accelerations of 0.25's at frequencies from 1.0 through 35.0 Hz. The resonance survey was performed at a sweep rate of 1/2 octave/minute. The input was applied in two (2) biaxial directions of excitation as follows:

TEST	BIAXIAL DIRECTION OF EXCITATION*
1, 1A, 1B, 1C	Front-to-back & Vertical
2	Right-to-left & Vertical

*Refer to the included photographs.

Report No. 14950



3.5 Multiple Frequency Test

A biaxial multiple frequency excitation was applied. The test input had been recorded on a 14-channel tape recorder, each track having discrete frequency sine beats recorded at a different frequency and delay between beats. All frequencies were recorded at maximum levels.

The input was played back through a 14-channel tape recorder. The outputs of the 14 channels were then combined in a 14-channel mixer which resulted in a multiple frequency output.

The individual mixer channels had gain controls so that the level of each output tape channel passing through the mixer could be controlled. In this manner, the required test spectrum could be shaped by controlling the level of individual frequencies.

Qualification tests, consisting of biaxial periodic pseudo-random excitation, were performed. The level of the periodic pseudo-random excitation was such that the Test Response Spectra (TRS), from the control accelerometer would envelop the appropriate Required Response Spectra (RRS) shown in Figure 1, except where limited by AETC shaker table capabilities.

The input was applied six (6) times in each of four (4) biaxial directions of excitations as follows:

TEST NO.	BIAXIAL DIRECTION OF EXCITATION*
3	Right-to-left & Vertical
4	Front-to-back & Vertical
5	Left-to-right & Vertical
6	Back-to-front & Vertical

The test duration for each input was thirty (30) seconds.

The level of the first five (5) inputs in each biaxial direction was such that the TRS from the control accelerometer computed at $Q=10$ (5% damping) would envelop the OBE RRS shown in Figure 1, except where limited by AETC shaker table capabilities. The level of the sixth input in each biaxial direction was such that the TRS computed at $Q=10$ (5% damping) would envelop the SSE RRS shown in Figure 1, except where limited by AETC shaker table capabilities.

**Refer to the included photographs.*

Report No. 14950



S023-506-17-12-0

Page 6

F-43

Figure 1 is a composite curve of Revisions A of Sketches S023-SK-S-655, S023-SK-S-656, S023-SK-S-633, S023-SK-S-634, S023-SK-S-739, S023-SK-S-725, S023-SK-737 and S023-SK-S-701 of Revision 1 of Appendix 4F "Criteria for Seismic Qualification of Seismic Class 1 Equipment", dated July 20, 1973.

Report No. 14950



4.0 TEST RESULTS

4.1 Resonance Survey Test Results

During test 1, resonances were detected at 23.0, 30.75 and 33.75 Hz. Accelerometers 7 and 8 fell off during the test at the 30.75 Hz resonance. Because the readout of accelerometer 8 was high, accelerometers 5, 6*, 7 and 8* were replaced to lighter model accelerometers to reduce the effect of the mass of the accelerometers on the panels' response.

Test 1A was the same as test 1 except the lighter accelerometers were used. During test 1A data from accelerometer 6 was lost.

Test 1B was a rerun of test 1A to gain the lost data from accelerometer 6.

Resonances were detected at 23 and 33-35 Hz during test 1B. The train A gas calibration switch panel was then removed and a 3/4" X 3/4" X 17" aluminum angle stiffener was bolted to the backside of the panel with five (5) 10-32 screws.

Test 1C was the same as test 1B except the stiffener was used. Resonances were audible from 31 to 35 Hz on panels that were not monitored with accelerometers and accelerometer #8 still showed resonances at 23 Hz.

Resonances were detected from 22 to 26 Hz during test 2. The added stiffener was used for test 2.

4.2 Multiple Frequency Test Results

Due to AETC shaker table limitations, the Test Response Spectra (TRS) of the SSE tests did not envelop the Required Response Spectra (RRS), Figure 1, at frequencies below 1.2 Hz.

The added stiffener was used for all the multiple frequency tests.

There was no evidence of mechanical damage or deterioration of the hydrogen analyzer assembly as a result of the multiple frequency test specified in section 3.5 above. The operating conditions were set and controlled by General Electric personnel, who retained the brush recording charts of the analyzers' output.

*and 6A and 8A when used.

Report No. 14950



S023-508-17-18-0

Page 8

F-45

TEST EQUIPMENT LIST

1-46


NAME	MFGR.	MODEL	SER. NO.	RANGE	ACCURACY	INV. #	CAL. FREQ.
Accelerometer	PCB	302A	695	0.25 Hz - 5 KHz	+5%	AC385	3 months
"	"	"	2853	1 Hz - 5 KHz	"	AC395	"
"	"	308B	3017	1 - 3000 Hz	"	AC398	"
"	"	"	982	"	"	AC400	"
"	"	"	983	"	"	AC401	"
"	"	"	1068	"	"	AC402	"
"	"	"	1070	"	"	AC404	"
"	"	"	1071	"	"	AC405	"
"	"	"	989	"	"	AC407	"
"	"	"	990	"	"	AC408	"
"	"	"	1073	"	"	AC409	"
"	"	302A	1773	1 Hz - 5 KHz	"	AC416	"
"	"	"	1775	"	"	AC418	"
"	"	"	1813	"	"	AC431	"
"	"	"	1815	"	"	AC433	"
"	"	308B	1782	1 Hz - 3 KHz	"	AC447	"
"	"	"	1783	"	"	AC448	"
"	"	"	1784	"	"	AC449	"
"	"	"	1785	"	"	AC450	"
Filter-Dual	Ithaco	4302	35207	10-1 Mhz	+3%	AM346	6 months
Scope	Tektronix	T912	T912-R011852	DC-10 Mhz Storage	4%	OS302	3 months
Power Supply	Buhr	506/16	322	+15 VDC, 1 ADC	0.5%	PD372	6 months
Function Generator	MTS	410.41	140	0-10 VDC 0-5 KHz Sq. Sine Trigger	0.1%V 0.1%F	PE310	6 months

TEST EQUIPMENT LIST

NAME	MFGR.	MODEL	SER.NO.	RANGE	ACCURACY	INV.#	CAL.FREQ.
Hydraulic Actuator	MTS	204.635		DC-300 Hz, 25K force lbs.	+2%F		
Controller	MTS	443.115		25" DA max.	+5%A		
Shock Spectrum Analyzer	Spec.Dyn.	SD321	18	DC to 2000 Hz	+1%	PE367	6 months
Power Supply & Amplifier	PCB	483M23	288	Input: 0.1 Hz - 10 KHz Sens. 31.6 MV - 100V F.S.	+0.5db	PE381	6 months
Temp Recorder	Brush	280	1132	12 channel X1 & X5 gain filter freq. 50 Hz	N/A	PE384	6 months
Recorder X-Y	MFE	715E	42167	0.5 mv/div	+2%	RE302	3 months
Recorder Tape	Honeywell	5600E	01410CE76	Input: 1-10-100 MV 1-10V both channels	+0.5%	RE340	3 months
Visicorder	Honeywell	1508	161715R	1" tape 7 speeds 14 channel	N/A	RE345	3 months
"	"	"	15-419	12 channel-metric	+1db	RE347	3 months
Recorder	Honeywell	5700E		12 channels 8" paper	"	RE349	" "


Electro Rent #73377

5023-508-17-18-0




ACCELEROMETER LOCATIONS

Report No. 14950




ACCELEROMETER LOCATIONS

Report No. 14950




ACCELEROMETER LOCATIONS

Report No. 14950




ACCELEROMETER LOCATIONS

Report No. 14950




ACCELEROMETER LOCATIONS

Report No. 14950




ACCELEROMETER LOCATIONS

Report No. 14950



SENSOR & TRANSDUCER MOUNTING

Report No. 14950



2 - Buckle stiffener


ADDED STIFFENER

Report No. 14950




S023-506-17-16-0

Page 18



FRONT-TO-BACK & VERTICAL
BIAXIAL DIRECTION OF EXCITATION
TESTS 1, 1A, 1B, 1C & 4

Report No. 14950




RIGHT-TO-LEFT & VERTICAL
BIAXIAL DIRECTION OF EXCITATION
TESTS 2 & 3

Report No. 14950


S023-506-17-18-0

Page 20



LEFT-TO-RIGHT & VERTICAL
BIAXIAL DIRECTION OF EXCITATION
TEST 5

Report No. 14950



BACK-TO-FRONT & VERTICAL
BIAXIAL DIRECTION OF EXCITATION
TEST 6

Report No. 14950



S023-508-17-18-0

Page 22

F-59



Test No. RRS
 Date 7/6/79
 Customer GE 14950
 Test Item P/N
 Test Item S/N
 Type of Test VIB BIAXIAL
 Spec. No.
 Para. No.
 Conditions
 Temperature ROOM
 Period of Test 30 SEC
 Control Axis VERTICAL
 Pick-up No. CONTROL
 Pick-up Axis VERTICAL
 Operator
 Test Engr. ES ES20570

GRMS



ACQUIRED RESPONSE SPECTRA (RRS) $\phi=10$ (5% PMTHING)

DGE	RS	A	COMPRESSIVE	CF ₀	REV A
	5023	-SK	-S - 634	5%	REV A
	5023	-SK	-S - 633	5%	REV A
	5023	-SK	-S - 701	5%	REV A
	5023	-SK	-S - 737	5%	REV A
DGE	RS	A	COMPRESSIVE	CF ₀	REV A
	5023	-SK	-S - 656	5%	REV A
	5023	-SK	-S - 655	5%	REV A
	5023	-SK	-S - 725	5%	REV A
	5023	-SK	-S - 739	5%	REV A

DGE

DGE

TIME

TEST OPERATOR



Test No. 3 Rnd
Date 10-3-79
Customer G.E. PHIL.
Test Item P/N 47E340609
Test Item S/N
Type of Test 1st. OBE
Spec. No.
Para. No.
Conditions OPER.
Temperature Room
Period of Test 30 SEC.
Control Axis R-LEFT
Pick-up No. CONTROL
Pick-up Axis VERTICAL
Operator C. PILONE
Test Engr. R. GILFOL

GRMS

Q=10 5% DAMPING



Test No. 3 Run 2
Date 10-1-78
Customer G.E. PHIL.
Test Item P/N 47E240609
Test Item S/N
Type of Test Random 2nd OSE
Spec. No.
Para. No.
Conditions OVER
Temperature ROOM
Period of Test 30 SEC.
Control Axis R-LT/VERT
Pick-up No. CENTRAL
Pick-up Axis VERTICAL
Operator C. P. H.
Test Engr. R. S. LLOYD

GRMS-

Q=10 5% DAMPING



Test No. 3 Run 3
Date 10-27-79
Customer G.E.-PHIL.
Test Item P/N 47624069
Test Item S/N
Type of Test 3rd PCE
Spec. No.
Para. No.
Conditions QTR.
Temperature Room
Period of Test 30 SEC.
Control Axis R-CLVERT.
Pick-up No. CONTRAC
Pick-up Axis VERTICAL
Operator C. P. H.
Test Engr. R. G. F.

GRMS

S023-508-17-18-0

F-63

Q=10 570 DAMPING

10.

9.5

10



Test No. 3 4th Run
 Date 10-3-79
 Customer B.E. PHIL
 Test Item P/N 47E240609
 Test Item S/N _____
 Type of Test 4th OBE
 Spec. No. _____
 Para. No. _____
 Conditions OPER.
 Temperature Room.
 Period of Test 30 SEC.
 Control Axis R-CLVERT.
 Pick-up No. Control
 Pick-up Axis VERTICAL
 Operator C. D. Hoff
 Test Engr. R. G. Foy

GRMS-

Q=10 570 DAMPING

10.

63

10



Test No. 3 RUN 5
Date 10-5-79
Customer B. E. PHILL
Test Item P/N 47E2V0609
Test Item S/N
Type of Test SHN DDC
Spec. No.
Para. No.
Conditions OPERA.
Temperature ROOM
Period of Test 30 SEC.
Control Axis VERTICAL
Pick-up No. CONTROL
Pick-up Axis VERTICAL
Operator C. P. Galt
Test Engr. R. BILFOL

GRMS

57.2 AMPING

10-10

10.

53


10



Test No. 3 Run 1
Date 10-3-78
Customer G. E. Phil.
Test Item P/N 47E240609
Test Item S/N
Type of Test SE
Spec. No.
Para. No.
Conditions OPER.
Temperature ROOM
Period of Test 30 SEC.
Control Axis R-CLVERT.
Pick-up No. CONTROL
Pick-up Axis VERTICAL
Operator C. Pilote
Test Engr. R. G. Foley

GRMS

CV=10 570 DAMPING



10.

54

10



Test No. 4 151 OBE
Date 10-13-79
Customer G.C. DHILL
Test Item P/N 41E240609
Test Item S/N
Type of Test VST OBE
Spec. No.
Para. No.
Conditions OPER
Temperature ROOM
Period of Test 30 SEC.
Control Axis F-BUCCP
Pickup No. CONTROL
Pick-up Axis VERTICAL
Operator C. PILATE
Test Engr. R. GILFOT

GRMS

$Q=10$ 57g Dampings

10

55

10

S023-508-17-18-0

F-67



Test No. 4-8nd 08E
Date 10-13-79
Customer G.E. Phil.
Test Item P/N 47E2Y0209
Test Item S/N _____
Type of Test 2nd 08E
Spec. No. _____
Para. No. _____
Conditions OPER.
Temperature Room.
Period of Test 30 SEC.
Control Axis F-BYDORL.
Pick-up No. CONTROL
Pick-up Axis VERTICAL
Operator C. RICARTE
Test Engr. R. SICKFOL

GRMS

DEF 10 570 DAMNINS

10

gr

10



Test No. 4 3rd Run
Date 10-13-79
Customer B.E. PHIL
Test Item P/N 475220609
Test Item S/N
Type of Test Random 3rd use
Spec. No.
Para. No.
Conditions OPER.
Temperature Room
Period of Test 30 SEC.
Control Axis F-34/VECT.
Pick-up No. CONTROL
Pick-up Axis VERTICAL
Operator C. DICK
Test Engr. R. S. COY

GRMS





Test No. 41 Run 4
Date 10-3-79
Customer G.E. PHIL.
Test Item P/N 47E240609
Test Item S/N _____
Type of Test 4th DOE
Spec. No. _____
Para. No. _____
Conditions OPER.
Temperature ROOM
Period of Test 30 SEC.
Control Axis F-35 Vert.
Pick-up No. CONTROL
Pick-up Axis VERTICAL
Operator C. PULONE
Test Engr. R. GILFOLY

GRMS-

$\delta = 10$ 570 DAMPING





Test No. 4 5th RUN
Date 10-3-79
Customer G.E. PHIL.
Test Item P/N 47E2Y0609
Test Item S/N
Type of Test 5th OBE
Spec. No.
Para. No.
Conditions OPER.
Temperature ROOM
Period of Test 30 SEC.
Control Axis F-BUVERT.
Pick-up No. CONTROL
Pick-up Axis VERTICAL
Operator C. P. 10th
Test Engr. R. GILFOY

GRMS

Q=10 5th OBE





Test No. 4 6484W
Date 10-3-79
Customer B.E. P.A.C.
Test Item P/N 47E240609
Test Item S/N _____
Type of Test SSE
Spec. No. _____
Para. No. _____
Conditions OPER.
Temperature Room
Period of Test 30 SEC.
Control Axis FORVERT.
Pick-up No. CONTROL
Pick-up Axis VERTICAL
Operator C.P. 10/8
Test Engr. R. GILFOY

GRMS. _____

$Q = 10$ STANDARDING

10.

8i

10



Test No. 5 1st Run
Date 10-3-79
Customer G. E. PHIL
Test Item P/N 47E240609
Test Item S/N
Type of Test 1st OGE
Spec. No.
Para. No.
Conditions OPER.
Temperature Room
Period of Test 30 SEC.
Control Axis L-R + VERT.
Pickup No. Control
Pick-up Axis VERTICAL
Operator C. P. Hoff
Test Engr. R. G. Foy

GRMS-

Q = 10 570 Damping





Test No. 51 2nd Run
Date 10-3-78
Customer G.E. DH:1
Test Item P/N 476240609
Test Item S/N
Type of Test Random 2nd oct
Spec. No.
Para. No.
Conditions OPER.
Temperature room
Period of Test 30 SEC.
Control Axis Control
Pick-up No. Control
Pick-up Axis Vertical
Operator C. Pilote
Test Engr. R. Gilfoy

GRMS

573 Damping

Q = 10



Test No. 5 3rd Run
Date 10-3-79
Customer B.E. PHIL.
Test Item P/N 47870609
Test Item S/N
Type of Test 3rd ODE
Spec. No. _____
Para. No. _____
Conditions OPER.
Temperature Room
Period of Test 30 SEC.
Control Axis L-RTVERT.
Pick-up No. Control
Pick-up Axis VERTICAL
Operator C. Pilote
Test Engr. R. Gilfoy

GRMS

$Q=10$ 5 to DAMPING

10.

5.

10



Test No. 5
Date 10-31-78
Customer B. C. PHIL
Test Item P/N 172240608
Test Item S/N
Type of Test 4th OBE
Spec. No.
Para. No.
Conditions OPER.
Temperature Room
Period of Test 30 SEC.
Control Axis L-R+VERT.
Pick-up No. CENTRAL
Pick-up Axis VERTICAL
Operator C. DiIorio
Test Engr. R. B. Foley

GRMS-

Q = 10 5% Damping

10 55

10



Test No. 5
 Date 10-3-79
 Customer GIC: PHIL.
 Test Item P/N 47E2Y0609
 Test Item S/N
 Type of Test 5th OBS
 Spec. No.
 Para. No.
 Conditions OPER.
 Temperature Room
 Period of Test 30 SEC.
 Control Axis C-210087.
 Pick-up No. CONTROL
 Pick-up Axis Vertical
 Operator C. Pilett
 Test Engr. A. Gilfoy

GRMS

Q=10 50 DAMPING





Test No. 5 614 PUN
Date 10-13-79
Customer G. P. PHIL
Test Item P/N 47E240609
Test Item S/N
Type of Test SSE
Spec. No.
Para. No.
Conditions OPER.
Temperature ROOM
Period of Test 30 SEC.
Control Axis VERTICAL
Pick-up No. CONTROL
Pick-up Axis VERTICAL
Operator C. P. P. P.
Test Engr. R. S. F. F.

GRMS

Q = 10 5% DAMPING

10

5r


10



Test No. 6-15108E
Date 10-3-79
Customer G.E. PHIL.
Test Item P/N Y2E2Y0609
Test Item S/N
Type of Test 15108E
Spec. No.
Para. No.
Conditions OPER.
Temperature ROOM
Period of Test 30 SEC.
Control Axis B-F+VERT.
Pick-up No. CONTROLS
Pick-up Axis VERTICAL
Operator Q. P. LORR
Test Engr. R. GILFOLY

GRMS

CD=10
572 RHMP/K





Test No. 6
Date 10-3-79
Customer G.E. Phil.
Test Item P/N 47E240609
Test Item S/N
Type of Test 2-1/2 DBE
Spec. No.
Para. No.
Conditions OPER.
Temperature Room
Period of Test 30 sec.
Control Axis B-F Vertical
Pick-up No. Control
Pick-up Axis Vertical
Operator C. J. 10/10
Test Engr. R. S. 11/10/1

GRMS

$\Delta = 10$ 5% DAMPING





Test No. 10-3-79 3rd RUN
Date 10-3-79
Customer G.E. PHIL.
Test Item P/N 475240609
Test Item S/N
Type of Test 3rd DGE
Spec. No.
Para. No.
Conditions OPER.
Temperature Room
Period of Test 30 SEC.
Control Axis B-Frequent.
Pick-up No. Control
Pick-up Axis VERTICAL
Operator C. Pilot
Test Engr. R. Gilfoyl

GRMS

Q=10 5-20 Damping



Abstract

NOTES

11


Operator	Engr.	Engr.

GRMS-



Test No. C 5th Run
Date 10-3-79
Customer G.E. Phil.
Test Item P/N 47E 240607
Test Item S/N
Type of Test 5th QBE
Spec. No.
Para. No.
Conditions OPER.
Temperature Room
Period of Test 30 Sec.
Control Axis B-F Vertical
Pick-up No. Control
Pick-up Axis Vertical
Operator C. P. York
Test Engr. A. G. L. Fox

GRMS



Required QBE PSS
(+10% Margin)

508-17-18-1



Test No. 10-3-78
Customer B. E. PHILL
Test Item P/N 41E24060
Test Item S/N
Type of Test Random
Spec. No. 508
Para. No.
Conditions OPER.
Temperature ROOM
Period of Test 30 SEC.
Control Axis B-F-Vent.
Pick-up No. 12
Pick-up Axis Vertical
Operator C. D. Hoff
Test Engr. R. Gilfoy

