#### APPENDIX T

PRESSURE TRANSDUCER AGING REPORT

PHILADELPHIA

PIR NO. U. \_\_ 1850 \_\_ CAMS\_\_ 235

"USE "C" FOR CLASSIFIED AND "U" FOR UNCLASSIFIED

PROGRAM	INFORMATION	REQUEST	/ RELEASE
---------	-------------	---------	-----------

Jerry D. Fuller, Project Engineer Analyzer Programs Room U-3035 - Ext. 2518 Analyzer Programs
Room U-3035 - Ext. 2956

DATE SENT DATE INFO. REQUIRED

PROJECT AND REQ. NO.

REFERENCE DIR. NO.

10/2/80 SUBJECT

2F3

ACCELERATED LIFE TEST REPORT - CEC-1000 PRESSURE TRANSDUCER

INFORMATION REQUESTED/RELEASED

The aging procedure defined in PIR 1B90-CAMS-205 was completed on CEC Pressure Transducer Part Number 1000-173, S/N 4240.

#### RESULTS

- Overall worse case change in performance occurred at 350°F and was a zero shift of -.413% of Full Scale.
- Unit aging is unnecessary since pressure transducer contains no age sensitive materials.
- Aging test served to increase confidence in component reliability.

#### SPECIMEN

The specimen included CEC Transducer S/N 4240, (see Attachment 1) mating connector P/N 17020 and ~50 feet of cable fabricated from Raychem Spec. 44 twisted shielded pair.

#### DISCUSSION

Log of key test activity is summarized in Table 1 and followed by a brief description of each.

TABLE 1

TEST LOG

ACTIVITY	LOCATION	DATE .		
Acceptance Test Procedure Dated 7/7/77	CEC	4/9/79		
Accelerated Life Environment	t GE-SD	8/ 2/79 to 8/17/79		
Radiation Exposure	Isomedix, Inc.	9/79		
Seismic Event	Acton, Acton, Mass.	10/79		
Acceptance Test Procedure Dated 7/7/77	CEC	3/2/80		
L. Heverly F. DiSanto E. Savitsky	J. Murphy J. Fuller E. Wong (CEC) J. Ashly (CEC)	TABLENO. 17 18 - 0 PRETENTION REQUIREMENTS COPIES FOR MASTERS FOR 1 Mo. 3 Mos. 3 Mos. 4 Mos. 1 12 Mos.		
		MOS.   MOS.		

#### Pre and Post Performance Tests

Both tests were performed at CEC to the 1000-04 (173) Acceptance Test Procedure dated 7/7/77 modified to include the linearity and hysteresis run at 250°F. Results were excellent with maximum deviation occurring at 350°F as a zero shift of -.413% of full range relative to the 4/9/79 test. The CEC calibration data summary is included with this report as Attachment 2.

# Accelerated Life Environment, PIR 1890-CAMS-205

To verify the long term operation requirements, the pressure transducer was subjected to the procedure presented in Attachment 3. The aging of the pressure transducer was performed by using present state-of-the-art aging technology. This technology allows acceleration of the time/temperature aging effects artificially by increasing the temperature. The pressure transducer contains both metallic and non-metallic components. The deterioration due to aging effects on the metallic components is judged to be insignificant. The aging of the pressure transducer was therefore based on its non-metallic materials only.

It is known for many non-metallic materials, that the degradation process can be defined by a single temperature-dependent reaction that follows the Arrhenius equation:

k = Ae

(1)

where.

k = reaction rate

A = frequency factor

Ea = activation energy

kB = Boltzmann's Constant (8.617 x 10-5 eV/°K)

T = absolute temperature

It is further noted that, for many reactions, the activation energy can be considered to be constant over the applicable temperature range. Equation (1) can be transformed into a form which yields an acceleration factor to define a given amount of thermal degradation. The form is:

$$\frac{Ea}{k_B} \left( \frac{1}{T_1} - \frac{1}{T_2} \right)$$

$$t_1/t_2 = e$$
(2)

where,

t<sub>1</sub> = accelerated aging time at temperature T<sub>1</sub>

t2 = normal service time at temperature T2

T1 = accelerated temperature T1 (°K)

T<sub>2</sub> = normal service temperature T<sub>2</sub> (°K)

Equation (2) can be used to derive the accelerated aging times for materials with known activation energies.

Normal operating temperature for the transducer is 120°F. The transducer was operated for 14 days at 300°F as presented in Table 2. From equation (2), this would age to greater than 40 years any material with an activation energy less than .81 eV. This would include most organic materials.

## Aging Analysis

Table 3 describes the non-metallics in the pressure transducer. Both materials are included in the following list of materials that are considered to not have significant aging characteristics:

Silicon semi-conductors, resistors; tantalum dry electrolytic capacitors; ceramic capacitors; dry paper and plastic film capacitors; mica capacitors; glass capacitors; integrated micro-electronic devices; hybrid micro-circuits; steel, aluminum, copper, epoxy fiberglass GlO, Gll, or equivalent; brass, ceramic, and glass-filled diallylphthalate.

Since there are no age sensitive materials in the transducer, no aging prior to seismic is required. The temperature aging test serves as a confidence test in the pressure transducer reliability. A detailed "aging" test log is presented in Table 2.

No detectable change observed in unit performance or visual appearance.

TABLE 2
AGING TEST LOG

DATE	ACTIVITY	COMMENTS
7/19/79	Chamber Installation	Chambe
7/19 → 8/2/79	Low Temperature Operation	145°F with chamber total pressure variation of 15.8 to 17.6 PSIA.
8/2/79	Initiate Aging Environment	Chamber was cooled to ambient and opened to allow transducer inspection.  Atmosphere preparation included 1/2 atmosphere of 2% H2/N2 and water vapor (15 ml of water). Chamber was sealed and temperature set for 300°F.
		Temperature Pressure Vo
8-3 8-6 8-7 8-8 8-9 8-10 8-13 8-14 8-15 8-17 (8:30) 8-17 (15:00) 8-17 (15:10) 8-20 (11:45) (11:50)	Aging Environment  ""  ""  ""  ""  Terminate Aging Environment  Terminate Test	302 53.5 18.739 302 55.3 19.241 302 53.5 18.804 302 49.4 17.464 302 49.3 17.364 302 49.4 17.282 302 47.2 16.79 308 49.7 17.574 305 49.5 17.525 305 48.6 17.259 305 48.6 17.259 305 48.4 17.151 Set heat for 125°F  129 26.2 7.839 Shut off heat, open the chamber and remove the specimen

# TABLE 3 PRESSURE TRANSDUCER - NON-METALLICS

COMPONENT	MATERIAL	COMMENTS
Bridge Substrate	Silicon Oxide SiO <sub>2</sub>	Thin coating to which resistors are mounted.
Resistors	"Ceramicite" (CEC) . Ceramic	Resistors are wire wound, nickel coated with Ceramicite which contains Al, Pb. Glass.

#### Radiation Exposure

The Transducer, connector and cable assembly was delivered to Isomedix for a radiation exposure of 1.2 x  $10^6$  Rads/hr. for a total integrated dose of 3.2 x  $10^7$  Rads. Dose certification is included with this report as Attachment 4. No detectable change in unit performance or visual appearance was observed during post exposure evaluation.

## Simulated Siesmic Event

The specimen was subjected to the environment described in GE-SD Procedure 250852 as part of H<sub>2</sub> Analyzer P/N 47E240609 System Seismic Test. Test details are presented in the '609 system Qual Test Report.

Frry D. Fuller, Project Engineer

Analyzer Programs

Room U-3035 - Ext. 2518

Concurred:


Edward J. Savitsky

Analyzer Programs

Room J-3035 - Ext. 2956

/mes

# CEC" 1000-04 Sputtered Thin Film High Temperature Pressure Transducer



- · Long-Term Stability
- · Highly Reliable
- · High Performance
- · Advanced Sensor Design
- Rugged Dual Case Isolation

Providing long-term stability and reliability, CEC Sputtered Gage Pressure Transducers are the most accurate thin film transducers available. Performance stability is  $\pm 0.1\%$  for extended operation at any combination of constant pressure and temperature within the operating range. The CEC 1000–04 has a compensated temperature range of 75°F to  $\pm 400$ °F, and an operable temperature range of  $\pm 65$ °F to  $\pm 450$ °F. The thermal errorband performance is typically better than 0.5% within any 50°F temperature band.


Advanced techniques of sputtered film deposition create sensing elements with a maximum combined error for non-linearity, hysteresis, and con-repeatability of  $\pm 0.25\%$  of the full range output.

Available in many standard ranges from 15 to 10,000 psi, the CEC 1000 Series also feature an innovative double-case isolation. The basic sputtered sensor is electron beam weided to the pressure chamber/adapter which also provides a high degree of mechanical isolation from mounting torque effects. The sputtered sensor is well isolated from external case effects since the case is welded to the pressure chamber/adapter and not in contact with any portion of the sensor.

CEC Sputtered Gage Pressure Transducers are manufactured in accordance with the program quality requirements of MIL-Q-985AA.

For further information about this pressure transducer, or special application designs, contact the nearest Bell & Howell/CEC Division Sales Office or factory in Pasadena, California.

CEC DIVISION



ATTACHMENT 1

#### SPECIFICATIONS

# CEC 1000-04 Sputtered Thin Film High Temperature Pressure Transducer

#### Pressure Ratina

Standard Ranges:

0 to 15, 25, 50, 100, 250, 500, 1000, 1500, 2000, 2500, 5000 and 10,000 pai absolute.

Proof Pressure:

0 to 100 pai and above are available in pais. 200% of rated pressure or 15.000 pai (which-ever is less) will not cause change in per-formance beyond specified tolerances.

Burst Pressure:

300% of reted pressure or 20,000 pel (which-ever is less) will not cause rupture of the sens-ing element or case.

#### Sectrical Characteristics

Excitation:

10 Vdc reled; 15 Vdc maxim

Full Range Output: Residual Unbalance:

30 mV nominal Within ±1%, FRO. 300 to 500 ohms.

Bridge Assistance: Combined Linearity, Hystorease and non-repeatability:

±0.25% FRO. 85L

Insulation Resistance:

100 meganine or greater at 45 Voc.

Connections: Shum Calibration:

8-pin Bendix PCIH-10-6P (101), or seulve Provisions for single-arm, external short call-britton.

#### Mechanical Characteristics

Pressure Chamber Materials:

17-4 PH Stainless Steel.

Pressure Fitting:

7/16-20 male per MS-33656-4, MS-8879 modified per CEC standards.

Weight: Mounting Isolation:

5 oz. maximum excluding mating connector. Double case isolation provides assurance that the sensing element will be unaffected by ex-ternal strasses.

Sensing Element:

4 active-arm andge using southered elements.

#### Environmental Performance

Operating Range:

-65 to -450"F

Compensated Range:

+75 to -400"F

Thermal Zero Shift:

=0.01% FRO/\*F over the compensated temp.

Therinal Sens. Shift:

=0.01% FRO/\*F over the compensated temp.

Therma Zero Stability:

0.25% FRO over the companied temp. range. Thermal Sens, Stability: 0.15% FRO over the compensated tamp, range, threstion: 0.15% FRO over the compensated tamp, range, the partition: 0.15% FRO/g peak from 10 to 2000 Fr (1/4" D.A. MAX.) the output shall not exceed 0.04% FRO/g to 15 psi units decreasing logarithmically to .000% FRO/g for 1000 psi white and above.

NEUTE Frequency:

50 kHz at 5000 psi, decreasing logarithmically to 5kHz at 15 psi.

Humidity:

1009, 11 mosc, had sine were without damage. Per MIL-E-5272C, Procedure 1.


#### Accessories

Calibration record and dust cape (2).

Cononat:


Mating electrical connector Physical Sciences T106-10-45-C-F1 or equivalent, Specify Bell & Howell PN 170200.

In keeping with Bell & Howelf's policy of continuing product improvement, specifications may be changed without notice, if the performance and configuration provided herein for our standard product de not filt your exact needs blease check with us requiring customated transducers. Concact us directly at the factory or through your nearest CSC Sales Office.



#### CEC DIVISION

360 Sierra Macre Villa, Pasaciena, Cartomia 91109



Promo n U.S.A

# BELL & HOWELL

CEC DIVISION

363 SIERRA MADRE VILLA PASACENA, CA 91109 TELEPHONE (213) 796-9381 TELEX: 57-5415

# CALIBRATION DATA SUMMARY

CEC 1000-0173 / S/N 4240 0-100 PSIA

Temperature	*B 77	°F *A	*B +25	0°F *A	350 *B	°F .	77°	F .
Full Scale (MV)	33,389	33.504	34.100	34.260	34.149	34.188	33.368	33.48
Zero (MV)	0.262	0.353	0.855	0.924			14.71	
Sens. (MV)	33.127	33.151	33.245	33.336	33.417	33.594	33.115	
Insulation Resistance	10 ΚΜΩ	iomu	10 ΧΜΩ	101010	2 XC40	5 KM Ω	S XXMΩ	10МΩ
AZero (MV)		+0.091		+0.069		-0.138		+0.09
Sens. (MV)		+0.024		+0.091		+0.177	+	+0.02
Milero (%FR)		+0.275		+0.208		-0.413		+0.29
Sens.(%FR)		+0.072		+0.274		+0.530		+0.06

# LINEARITY AND HYSTERESIS RUN AT +250°F

\$FS	0	20	40	60	80	100	80	60	1 40	20	T
*3	0.855	7.473	14.115	20.769	27.430	34.099	27.438	20.776	14.122	7 482	1
*A	0.924	7.558	14.223	20.896	27.579	34.268	77 596	20 557		1	1

\*B is before radiation 4/09/79

\*A is after radiation 3/20/80

E. Wong

Sr. Product Specialist

I-8

# GENERAL ELECTRIC

SPACE DIVISION PHEADERNIA

CLASS, LTA OPERATION PROGRAM SEQUENCE NO. REV. LTR. 1890 CAMS 205

PROGRAM	INFORMATION	REQUEST	/ RELEASE

AND DESCRIPTION OF THE PARTY OF	RMATION REQUEST / RE	LEASE	"USE "C" FOR C	LASSIFIED AND "U" FOR UNCLASSIFIED	
FROM J. D	. Fuller, Project En	gineer	F. P. Rude	k, Manager - Analyzer Systems	
7-25-79	DATE INFO. REQUIRED	PROJECT AND	REQ. NO.	REFERENCE DIR. NO.	_
SUBJECT	CEC-1000-04(173	) Pressure	Transducer Aging	Procedure	

INFORMATION REQUESTED/RELEASED

The purpose of this test is to subject the transducer proposed for current configuration H2 Analyzers to a combination of environmental conditions simulating long term operation of the transducer.

- 1. Initial Conditions:
  - a. Place 30 ml H20 in the chamber prior to closing.
  - b. Pressurize the chamber to 15 PSIG with 2% H2/N2 then vent to ambient pressure. Close inlet and outlet valves.
  - c. Set the temperature for 135°F + 5°F.
  - d. Record the following data for stabilized sensor performance.
    - Temperature
    - Pressure
    - Transducer Output
    - Time (Date and Time of Day)
- 2. Accelerated Life Temperature, Pressure Conditions:
  - a. Set temperature controller to achieve a chamber temperature of 3000
  - b. Upon achieving a chamber temperature of 300°F, record the time and date. Vent the chamber as required to maintain a chamber pressure < 65 PSIG.
  - c. Maintain the conditions established in the preceding step for 14 days and record the following information daily:
    - Temperature
    - Pressure
    - Sensor Output
    - Time

cc: J. D. Fuller		ar ar her phy		ARTENTION REQUIREMENTS		
	L. R. Heverly	F. P. Rudek		COPIES FOR	MASTERS FOR	
				☐ ····	] 7 ves.	
				1 wes.	-	
			1 2 2	6 wes.	12 wes.	
					- wes.	

- d. Decrease the temperature setting to achieve a chamber temperature of  $125\,\pm\,5^{\circ}\mathrm{F}$  and maintain for 2 days. Daily record the data noted in step 2.c.
- e. Shut off the heat, open the test chamber and remove the transducer for visual inspection.

#### 3. Radiation Exposure:

- a. Subject the transducer to a total integrated dose of 3.2 x 10<sup>7</sup> Rads at a rate of 1.2 megarads/hour.
- b. Perform CEC ATP.

O. D. Fuller, Project Engineer
Analyzer Systems
Poom #11-3035 NESS

Room #U-3035, VFSC-Extension - 2518

h

- d. Decrease the temperature setting to achieve a chamber temperature of  $125 \pm 5^{\circ}$ F and maintain for 2 days. Daily record the data noted in step 2.c.
- e. Shut off the heat, open the test chamber and remove the transducer for visual inspection.

# 3. Radiation Exposure:

- a. Subject the transducer to a total integrated dose of 3.2 x 107 Rads at a rate of 1.2 megarads/hour.
- b. Perform CEC ATP.

O. D. Fuller, Project Engineer Analyzer Systems

Room #U-3035, VFSC Extension - 2518

h



J. J. Collery
General Electric Company
Space Systems
P.O. Box 8535
Philadelphia, Pa. 19101

Dear Mr. Collery:

This will summarize parameters pertinent to the irradiation of CEC XDUCER, calibration cap and cylinder, as per your purchase order A28-A10311, dated August 28, 1979.

The specimens were exposed for 37 hours at an average dose rate of 1.0 Megarads per hour, yielding a dose of 37 Megarads. The specimens were over-irradiated to account for the ±3% accuracy of the the dosimetry system; the reported dose is 32 Megarads.

Halfway through the exposure, the specimens were rotated 180° to give a more uniform dose distribution.

Dosimetry was performed using Harwell Red 4034 Perspex dosimeters, utilizing a Bausch and Lomb Model 710 spectrophotometer as the readout instrument. This system is calibrated directly with NBS, with the last calibration being May 30, 1979. A copy of the dosimetry correlation report is available upon request.

Irradiation was conducted in air at ambient temperature and pressure. Radiant heat from the source heated the samples somewhat, but the temperature did not exceed 130°F, as indicated by previous measurements on an oil solution in the same relative position.

Irradiation was initiated on August 31, 1979, and was completed on September 2, 1979.

Sincerely yours,

ISOMEDIX, INC.

David P. Constantine Production Manager

DPC:vt cc: G. Deitz

I-11