



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

April 13, 1983

Mr. James M. Allan
Acting Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-048/03L-0
ER 100450 FILE 841-23
PLA 1616

Docket No. 50-387
License No. NPF-14

Dear Mr. Allan:

Attached please find a copy of Licensee Event Report No. 83-048/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that less than the required number of channels of Drywell Hydrogen Analyzers for accident monitoring were operable.

H.W. Keiser
Superintendent of Plant-Susquehanna

JTT/pjg

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655