NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | LICENSEE CODE: C T M N S 1 (2) | LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) | LICENSE TYPE: 4 1 1 1 1 (4) | CAT (5)

CON'T 01 | REPORT SOURCE: L (6) | DOCKET NUMBER: 0 5 0 0 0 2 4 5 (7) | EVENT DATE: 0 3 2 4 8 3 (8) | REPORT DATE: 0 4 1 8 8 3 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On March 24, 1983, at 1227 hours, while performing Main Steam Isolation Valve functional Test 1-MS-2C, the outboard isolation valve, closed in 5.31 seconds. Technical Specification, Table 3.7.1 requires a main steam isolation valve closure time of greater than or equal to 3 seconds and less than or equal to 5 seconds from a primary containment isolation signal. 1-MS-2C was immediately placed in the closed position. There were no consequences. See attached sheet.

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
S D (11)	X (12)	Z (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 3	–	0 1 0	/	0 3	L	–	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	Y (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

Investigation revealed that the packing around the valve stem appeared tight. This could cause the valve to close slightly slower than normal. To maintain the integrity of the valve packing seal and simultaneously satisfy the Technical Specification time limit, the speed control on the valve was slightly adjusted. The valve retested satisfactorily.

FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
F (28)	0 3 3 (29)	NA	B (31)	Routine Surveillance

ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION (39)
0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

NUMBER	DESCRIPTION (41)
0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE	DESCRIPTION
Z (42)	NA

PUBLICITY

ISSUED	DESCRIPTION (45)
N (44)	

8304270276 830418
PDR ADOCK 05000245
S PDR

NRC USE ONLY

NAME OF PREPARER: Trudy Schweikert Thull PHONE: (203) 447-1791