

APPENDIX A

NOTICE OF VIOLATION

Philadelphia Electric Company

Docket Nos.: 50-277

50-278

Peach Bottom Units 2 and 3

License Nos.: DPR-44

DPR-56

As a result of the inspection conducted on February 25 - April 1, 1983, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C) published in the Federal Register on March 9, 1982 (47 FR 9987), the following violation was identified:

A.1 Technical Specification 6.8 and Regulatory Guide 1.33 (November 1972) require implementation of written procedures for surveillance testing.

A.1.1 Surveillance Test procedure ST9.12, Revision 5, Reactor Vessel Temperatures, requires performance of the test during heatups and cooldowns and when the reactor is not vented while below 220°F.

Contrary to the above, ST9.12 was not fully performed, in that reviews and signatures required in the test results and plant staff supervision review sections were not completed, during Unit 2 conditions requiring performance of the test on the following dates: June 10-12, 1982, October 23-24, 1982, December 10, 1982, December 13-14, 1982, and January 29, 1983.

A.1.2 Surveillance Test procedure ST3.1.2, Revision 6, SRM Core Monitoring Test, states that Source Range Monitor (SRM) response shall be considered acceptable if a 25 percent increase in count rate is observed during motion of an adjacent control rod.

Contrary to the above, on March 9, 1983, ST3.1.2 was considered acceptable, as evidenced by "completed SATISFACTORILY" signatures by the performer and the shift supervisor, even though Unit 3 SRM 'B' indicated only a 22 percent increase in count rate during motion of an adjacent control rod.

This is a Severity Level V Violation (Supplement I) applicable to DPR-44 and DPR-56.

Pursuant to the provisions of 10 CFR 2.201, Philadelphia Electric Company is hereby required to submit to this office within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further violations, and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

APPENDIX B

NOTICE OF VIOLATION

THIS PAGE, CONTAINING SAFEGUARDS INFORMATION, NOT FOR PUBLIC  
DISCLOSURE, IS INTENTIONALLY LEFT BLANK.