

PRELIMINARY NOTIFICATION

Ess *LCB*

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V:80-79

Date: November 24, 1980

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by IE staff on this date.

DESIGNATED ORIGINAL

Facility: Southern California Edison Company
San Onofre Nuclear Generating Station Unit Nos. 2 and 3
San Clemente, California
Docket Nos. 50-361 and 50-362

certified By *Det Noack*

Subject: Fatality at Construction Site

An electrical worker (licensee employee) was killed Saturday morning, November 22, 1980, when he came in contact with a 4 KV line. The accident occurred at 9:50 a.m. while cleaning breaker cubicles. The individual died at 11:10 a.m. The licensee is investigating the accident and has notified California-OSHA of the accident. Licensee plans to issue a press release.

The foregoing was reported to RV Office by the Headquarters Duty Officer at 12:04 p.m. on November 22, 1980.

CONTACT: R. C. Haynes (FTS 463-3719)

Distribution: Transmitted H St. *12:27 pm*
Chairman Ahearn Commissioner Hendrie
Commissioner Gilinsky Commissioner Bradford
ACRS

S. J. Chilk, SECY
C. C. Kammerer, CA
(For Distribution)

Transmitted: MNBB *12:42* P. Bldg.: *12:38 pm*
W. J. Dircks, EDO H. R. Denton, NRR
C. Michelson, AEOD R. H. Vollmer, NRR
J. J. Fouchard, PA R. J. Mattson, NRR
N. M. Haller, MPA D. F. Ross, NRR
R. G. Ryan, SP D. Eisenhut, NRR
H. K. Shapar, ELD S. H. Hanauer, NRR

IE:Z00S: *12:40 pm* (IE:HQ Dist.)

Landow _____ (6 min/page)
J. J. Cummings, OIA

8304280380 801124
PDR I&E
PNO-V-80-079 PDR

Willste Bldg. *12:33 pm*
J. G. Davis, NMSS
R. J. Budnitz, RES

MAIL:
R. Minogue, SD
IE:X00S
Document Mgt. Br. (For PDR/LPDR)

Regional Offices _____

IE34