

[illegible]

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	6	4	7	0	3	2	6	8	3	8	0	4	2	2	8	3	9
60	61									68	69					74	75							80
DOCKET NUMBER											EVENT DATE						REPORT DATE							

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 1120 on 3/26/83 pressurizer heater group 2A was declared inoperable when the
03 heaters failed to energize. Tech. Spec. 3.4.4, in part, requires pressurizer
04 heater group 2A to be operable. Tech. Spec. 3.4.4 action statement requirements
05 were met. Health/safety of the public was not affected.

0	6
---	---

0	7
---	---

08 _____

7 8

0 9

SYSTEM
CCODE

C A 11

9 10

CAUSE
CODE

E 12

11

CAUSE
SUBCODE

A 13

12

COMPONENT CODE

C K T B K R 14

13 18

COMP.
SUBCODE

E 15

19

VALVE
SUBCODE

Z 16

20

(17)	LER/RO REPORT NUMBER		[8][3]		SEQUENTIAL REPORT NO.		[0][1][8]		OCCURRENCE CODE		[0][3]		REPORT TYPE		[L]		REVISION		[NO]
			21	22	23		24	26	27		28	29		30		31		32	
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT			SHUTDOWN METHOD		HOURS	(22)		ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER			COMPONENT MANUFACTURER				
[E]	[18]	[Z]	[19]		[Z]	[21]	[0][0][0][0]			[N]	(23)	[Y]	[24]		[N]	[25]		[W]	[1][2][0]
33	34	35			36		37		40	41		42		43		44		47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 C This event was due to the failure of breaker EAll to close. The breaker closing
1 1 springs were found discharged due to an out of adjustment microswitch. The
1 2 microswitch was adjusted, the breaker was cycled and pressurizer heater group 2A
1 3 was energized and declared operable at 1400 on 3/26/83.

1 4

FACILITY STATUS			% POWER			OTHER STATUS (30)			METHOD OF DISCOVERY		DISCOVERY DESCRIPTION (32)	
1	5	E (28)	1	0	0 (29)	NA			A (31)	Operational Event		
7	8	9	10	11	12	13	14	15	16	17	18	

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 7 8 9 10 11 NA NA

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	40
				NA	

1 9 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

LOSS OF OR DAMAGE TYPE ACILITY (43) 8305030589 830422
PDR ADOCK 05000364
S PDR

PUBLICITY		ISSUED		DESCRIPTION		NRC USE ONLY	
2	0	N	(44)	NA			

NAME OF PREPARER W. G. Hairston, III

PHONE: (205) 899-5156